

TEST REPORT

PN : 853-A16693-001

DATE&TIME: 19/08/2021 10:48:10

SN : swert

USER NAME: werst

TEST CASES	OVERALL TEST RESULT
CASE 1 (Toggle DO0 to DO7 and read back DI0 to DI7) : FAIL	FAIL
CASE 2 (Toggle DO8 to DO15 and read back DI8 to DI15) : PASS	
CASE 3 (Toggle DO16 to DO23 and read back DI16 to DI23) : PASS	
CASE 4 (Toggle DO24 to DO31 and read back DI24 to DI31) : PASS	
CASE 5 (Toggle DO32 to DO39 and read back DI32 to DI39) : PASS	
CASE 6 (Toggle DO40 to DO47 and read back DI40 to DI47) : PASS	
CASE 7 (Toggle DO48 to DO55 and read back DI48 to DI55) : PASS	
CASE 8 (Toggle DO56 to DO63 and read back DI56 to DI63) : PASS	
CASE 9 (Toggle DO64 to DO71 and read back DI64 to DI71) : PASS	
CASE10 (Toggle DO72 to DO79 and read back DI72 to DI79) : PASS	
CASE11 (Toggle DO80 to DO87 and read back DI80 to DI87) : PASS	
CASE12 (Toggle DO88 to DO95 and read back DI88 to DI95) : PASS	
CASE13 (Toggle AO0 read back AI0) : PASS	
CASE14 (Toggle AO1 read back AI1) : PASS	
CASE15 (Toggle AO2 read back AI2) : PASS	
CASE16 (Toggle AO3 read back AI3) : PASS	
CASE17 (Toggle AO4 read back AI4) : PASS	
CASE18 (Toggle AO5 read back AI5) : PASS	
CASE19 (Toggle AO6 read back AI6) : PASS	
CASE20 (Toggle AO7 read back AI7) : PASS	
CASE21 (Toggle AO8 read back AI8) : PASS	
CASE22 (Toggle AO9 read back AI9) : PASS	
CASE23 (Toggle AO10 read back AI10) : PASS	
CASE24 (Toggle AO11 read back AI11) : PASS	
CASE25 (Toggle AO12 read back AI12) : PASS	