

Confidential synthetic — FIELD INSPECTION FORM (page 1/3)

Plant / Unit: Demo Hydrocracker · Area: North bank

Work order (stub): WO-2026-4417

Asset tag: V-101

Equipment description: Vertical pressure vessel · shell course A

Inspection type: UT thickness survey (spot)

Date (synthetic): 2026-09-18

Inspector (synthetic): Demo Inspector / Contractor Co.

Measured thickness: 7.6 mm

Instrument (stub): UT gauge demo-unit

Location on asset: North quadrant, 1.2 m above grade, near weld toe

Confidential synthetic — FIELD INSPECTION FORM (page 2/3)

Governing procedure: SOP-THK-001 (local KB excerpt)

SOP-THK-001 minimum allowable thickness: 8.0 mm

Finding class (stub): Below minimum — engineering review required

Observation: Localized pit indication adjacent to circumferential weld toe.

No leakage observed at time of survey (synthetic).

Photos attached: scan_vessel_V101_field.png (synthetic raster)

Recommended interim action: Reduce inspection interval pending integrity review.

Do not treat this PDF as a plant SoR or CERT record.

Confidential synthetic — FIELD INSPECTION FORM (page 3/3)

Cite-or-abstain rule: only quote SOP-THK-001 values present in local KB.

Next step for Knowledge Work Bench demo: Confirm extract → retrieve cites → Word DRAFT.

Export leave pack is soft copy for Approver OUTSIDE the application.

Gateway must not call public cloud models.

End of form.