Alfa Laval

SPECIFICATION FOR ALFA LAVAL PLATE HEAT EXCHANGER

Customer: HYUNDAI MIPO DOCKYARD CO., LTD.

Hull No. 1 H2511

Application	MAIN L.O COOLER		NO.1 & NO.2 CENTRAL F.W COOLER	
No. of Units	1		2	
Unit Type	MX25-MFMS		T20-PFG	
No. of Plates/Unit	124		193+1	
Heat Transfer Surface/Unit m2	180.6		170	
Media	L.O	F.W	F.W	S.W
Flowrate m3/h	220.0	94.0	280.0	320.0
Inlet Temperature Deg.C.	52.2	36.0	55.1	32.0
Outlet Temperature Deg.C.	45.0	43.0	36.0	48.9
Pressure Drop mwg	7.00	0.548	6.61	9.96
Heat Transferred Kcal/h	653,600		5,280,000	
K-value (Service) Kcal/m2h.deg.C	397.4		6,221	
K-value (Clean) Kcal/m2h.deg.C	460.7		7,155	
LMTD Deg.C	9.1		5.0	
Max. Design Pressure bar	6	6	6	6
Test Pressure bar	9	9	9	9
Max. Design Temperature Deg.C	90	90	90	90
No. of Passages	1	1	1	1
No. of Channels	62MH	61ML	72H+24ML	72H+24MH
Frame Material	MILD STEEL			
Manuf. No.	30115-97558		30115-97559/60	
Plate Material/Thickness mm	SUS 316 / 0.5 mm		TI / 0.5 mm	
Gasket Material	NBRP			
Fouling margin	15%		15%	
Rule	1 KR (H2511~13, H2517~19, H2547~49), ABS (H2541~46) and LR (H2514~16, H2520~22, H2550~52)			
Colour	1 Munsell No. 7.5 BG 7/2			

Remarks: :

No. 1 / 2

Alfa Laval Korea Ltd.

C.P.O. Box 4285, Seoul 100-642, Korea. Visiting address: 216,1ka Kwanghee-Dong, Chung-Ku,

Seoul 100-710, Korea .Telephone: +82 2 3406 0600 Telefax: +82 2 3406 0701