



GOVERNMENT OF TELANGANA

BOILERS DEPARTMENT

FORM V

[REGULATIONS 381 (c)]

PROVISIONAL ORDER UNDER SECTION 9 OF
THE BOILERS ACT OF 1923

No : JD 22/2021-22

M/s. RAKSHIT DRUGS PVT. LTD., Bonthapally(V), Gummadidala(M), Sangareddy(D)
are hereby permitted to use the Package Boiler - High Risk With Registry No : TS/601 Boiler
rating 135 square meter, made by M/s. THERMAX LIMITED and bearing Maker's No : at
a maximum pressure of 10.54 Kilogram per Square Centimeter. pending the issue or
refusal of a certificate within six months from the date hereof after which period this order will
become void.

This PO is valid from 25/01/2022 to 24/07/2022

Remarks: P.O. issued pending Steam Test.

Fee Paid: Rs. 4300, paid on : 10/01/2022, Challan No : 111383579716

Dated: 27/01/2022

T.E of SPL : Satisfactory

**SREENIVASARA
O MULLAPUDI**

Digitally signed by SREENIVASARA O MULLAPUDI
DN: c=IN, o=THE DIRECTOR OF BOILERS, ou=UC DEPUTY CHIEF
INSPECTOR OF BOILERS SPECIAL OFFICER,
pseudoym=3ee4cdaa6eae47581690fc7a8cd3c143eb35371f8b7c16
622ee39ead72e8ad3,
2.5.4.20=aad80da9735a24662f6c431cf418147bcd42822b4c89e0d7e6a
0768aeff55463, postalCode=500013, st=TELANGANA,
serialNumber=f0863f2ba06cfe60bc5e9c9857025743cadecb2687d618
d91ad4ab097b697f6d, cn=SREENIVASARA O MULLAPUDI
Date: 2022.01.27 16:25:01 +05'30'

Deputy Chief Inspector of Boilers (Special Officer), Hyderabad

**N.B :- This order must be produced on demand by any authorised person and surrendered to
the Director of Boilers on receipt of order.**