The Journal of Open Source Software

VERNIER: an open-source library pushing marker pose estimation to nanometric resolutions

Patrick Sandoz [1], **Antoine N. André** [2], **Sasha Ballet** [1], **Victorien Lanneau** [1], **and Guillaume J. Laurent** [1¶]

1 Université Marie et Louis Pasteur, CNRS, SupMicroTech, Institut FEMTO-ST, Besançon, France **2** National Institute of Advanced Industrial Science and Technology, CNRS-AIST JRL, IRL, Tsukuba, Japan ¶ Corresponding author

DOI: 10.xxxxxx/draft

Software

- Review
- Repository
- Archive

Editor: Open Journals

Reviewers:

- @openjournals

Submitted: 01 January 1970
Published: unpublished

License
Authors of papers retain copyright and release the work under a Creative Commons Attribution 4.0 International License (CC BY 4.0).

Summary

At the small scales, few solutions exist to capture the pose of an object with nanometric and microradian resolutions over relatively large ranges. Over the years, we have proposed several fiducial marker and pattern designs to achieve reliable performance for various microscopy applications. VERNIER is an open source phase processing library designed to provide accurate pose measurement based on these results. Centimeter ranges are possible using binary encoding methods, while nanometer resolutions can be achieved using phase processing of the periodic patterns. Moreover, the detection has proven to be particularly robust to noise, defocus and occlusion thanks to a local thresholding algorithm based on the phase. The paper presents the measurement principles and the patterns implemented in VERNIER addressing different application needs.

Statement of need

The VERNIER library provides a powerful tool to measure the 2D and 3D poses of objects observed through a microscope lens with unprecedented sub-pixel resolutions and ranges. The library works in combination with markers fixed on the objects of interest, allowing accurate measurements even in noisy and blurry imaging conditions which are common in microscopy. The image processing involves two complementary steps, resulting on the one hand in fine but relative position measurement and, on the other hand, a coarser but absolute localization. The fine position process achieves high sub-pixel resolutions thanks to spectral analysis of the imaged periodic pattern of the marker. Complementary coarse measurements are retrieved either from the marker contours or from a binary sequence encrypted within the pattern.

VERNIER works with three different types of markers, designed to meet different application requirements, and whose design can be easily adapted to specific imaging parameters, mainly magnification, field of view (FoV), and expected measurement range and resolution (cf. Figure 1.). Sources and layouts are available on GitHub and can be downloaded for evaluation and testing.

DRAFT




Figure 1: The three marker types (on the left an HP code marker, in the middle a Stamp marker, on the right a Megarena encoded pattern).

State of the field

Computer vision is widely used to track the movement of people and objects in many applications. When the size of the object of interest decreases, pose estimation becomes challenging due to the constraint of microscopy imaging. Unlike regular cameras, microscopes suffer from narrow FoV, short depths of field, low contrasts and out-of-focus blurs, and usual fiducial markers perform poorly in these conditions.

Many vision-based methods have been proposed to tackle pose estimation at the small scales. In 2021, Yao et al. (2021) published a review paper comparing the resolution and the range of state-of-the-art vision-based localization methods. The most precise methods use phase correlation and can achieve sub-nanometer resolutions. However, their measurement ranges are still limited by the microscope's FoV. To overcome this limitation, pseudo-periodic patterns can be used to encode the absolute position over centimetric ranges, while using phase measurement to achieve nanometer resolutions (André et al., 2020b, 2020a). Based on this principle, `VERNIER` proposed processing algorithms for several markers and patterns that ensure reliable performance in various microscopy applications. As reported in Fatikow's survey paper (Yao et al., 2021), this approach achieves a better range-to-resolution ratio compared with other methods, including HORIBA's proprietary NanoGPS solution (Acher et al., 2021).

The measurement principle is mainly suited for in-plane 3 degrees of freedom (DoF) pose estimation under microscopy orthographic projection. However, long-focal perspective projection can be used for retrieving complementary out-of-plane pose parameters with a lower resolution. Full out-of-plane pose estimation details and performances can be found in André et al. (2022).

To achieve the measurement of the 6 DoF, the same approach is applied but with a digital holographic microscope (DHM). The interferometric character of DHM makes the device highly sensitive to out-of-plane motion and the 6 DoF are measured simultaneously in a single image with a high resolution (Ahmad et al., 2024).

Figure 2 presents the mean features and metrics of the pose estimation of all marker types. All the metrics have been validated experimentally with precision stages and robots using the `VERNIER` C++ implementation (André et al., 2020b, 2020a; André, Sandoz, et al., 2022) with the exception of the hologram processing, which was performed beforehand using the DHM's software and MATLAB (Ahmad et al., 2024).

DRAFT

The Journal of Open Source Software




Figure 2: Overview of features and metrics of the marker pose estimation with `VERNIER`.

Software design

`VERNIER` is written in `C++` and provides a class hierarchy for detection and estimating the pose of three kinds of calibrated patterns (Megarena patterns, HP code and Stamp markers). The library is cross-platform. The users can build the examples and unit tests using `CMake`. The library relies on multiple third parties: `OpenCV`, `Eigen`, `FFTW`, `MatIO`, `RapidJSON` and `GDS Tool Kit`.

The class hierarchy is centered on general periodic pattern processing and then extends to the different types of patterns. All pose estimations rely on the Fourier transforms of the entire image. To achieve fast computation times, the current version of the library uses the MIT implementation (FFTW). Future releases will support GPU-based Fourier transform processing.

The library also provides a set of classes for rendering synthetic images and exporting layouts of the different markers presented in the previous section. The synthetic images are used to test the correct functioning of the detectors. The marker layouts can be exported in `PNG`, `SVG`, `GDS` and `OASIS` formats. These files can be used to print the markers on various supports.

As the measurement method is based on the phase of the periodic pattern, the position accuracy is directly related to the scale and quality of the pattern fabrication. To obtain calibrated measures, all the patterns have been realized using a high-resolution maskless aligner (Heidelberg MLA150) on quartz or glass substrates within the MIMENTO facility.

To reach the best resolution, the magnification and the size of the marker should be set so that the period of the marker spans onto 7 to 15 image pixels.

Research impact statement

`VERNIER` has found many applications in microrobotics as presented in Figure 3.

DRAFT

The Journal of Open Source Software




Figure 3: Overview of applications of pose estimation at the small scales with `VERNIER`.

Metrology of precision manipulators

One of the key advantages of Megarena patterns is their ability to perform the metrology of micro and nano stages and precision manipulators. Indeed, few solutions to measure the 3D pose of the manipulator end-effector at the nanoscale are available. The laser interferometers provide a very high range-to-resolution ratio of approximately 10^9 but only along the laser's axis. Setups with several interferometers have demonstrated multiple DoF measurement systems (Lee et al., 2011; Ortlepp, 2024), at the expense of occupied volume and calibration complexity. Moreover, due to the constraints of laser reflection, the range of their angular measurements is very low, not exceeding a magnitude of one milliradian.

The use of Megarena patterns is much simpler and also provides nanometric resolution and centimeter ranges. Moreover, using a DHM, the angular ranges of out-of-plane rotations reach 0.2 rad with resolutions down to 0.1 µrad. The ideal setup consists only of a microscope and a piece of a Megarena pattern attached to the end effector of the manipulator.

For example, the method has been used to evaluate the accuracy of a precision hexapod, showing that it is able to follow millimeter trajectories with deviations of less than one micrometer (Ahmad et al., 2024). It has also been employed to evaluate the accuracy of a serial 6-DoF manipulator over a point matrix of 10 by 10 centimeters (André et al., 2020b). Megarena patterns can also be used to measure the repeatability of positioning of stages and manipulators. For instance, in Gallardo et al. (2021) and Mauzé et al. (2020), the method is used to evaluate the precision of parallel continuum robots.

Multi-DoF stage automation

The Megarena patterns can also be used as position sensors to directly control the position of the motion platform of a multi-DoF manipulator during its operation. This ensures the actual position of the end-effector regardless of the errors introduced by assembly of stages, guidance, compliance, and backlash in the mechanical axis. It could also help to identify and correct cross-axis coupling and unwanted motion in multi-DoF systems, as proposed by Tan et al. (2015).

Micro-assembly

Micro-assembly requires two parts to be positioned relative to each other with high precision. To make assemblies with errors lower than a micrometer, the joint sensors of the manipulators

DRAFT

are not sufficient and it is necessary to use visual servoing to control the relative position of the parts. To this end, markers are placed on each of the parts to assemble and their relative position is monitored in real time during the assembly process. In their study, André et al. (2022), two HP code markers are used to align and bond two parts of a microfluidic chip. This automated assembly achieved a positioning accuracy of better than 50 nm.

Micro-force measurement

Another key application in microrobotics is simultaneous force and displacement sensing. Force sensing has always been an issue for micro- and nanoscale applications. Force ranges from a few mN to a few hundred mN are typically required for manipulation, assembly and characterization tasks in most fields.

André et al. (2022) designed a compliant mechanism with two HP code markers engraved on it. The relative motion between the markers gives an image of the compression force, while the relative position of the markers to the camera frame gives the displacement of the mechanism base. This force sensor has been used experimentally to perform automated compression tests on individual synthetic and natural fibers, providing very rich information and allowing to better understand the mechanical fiber behavior (Govilas et al., 2024).

Previous experiments with this method have shown resolution measurements down to 50 nN with experimental ranges of 50 mN (Guelpa et al., 2015). The same principle has also been applied to multiple directions force sensing by Tiwari et al. (2021).

Correlative microscopy

The pattern-based position measurement was initially developed to perform the repositioning of Petri dishes under a microscope for live cell monitoring (Galeano Zea et al., 2011). Thanks to a pattern similar in principle to the Megarena, regions of interest of a culture dish were easily retrieved after transfers from a cell incubator to the microscope stage. Thanks to this approach, images of single cells can be captured at different time steps in a repeatable manner, as the cells can be identified based on their absolute position in the Petri dish and can also be imaged with various modalities (e.g., electron, confocal, fluorescent microscopes).

AI usage disclosure

No generative AI tools were used in the writing of this manuscript, the preparation of supporting materials, and the development of this software.

Acknowledgements

This work has been supported by the ANR project Holo-Control (ANR-21-CE42-0009), the Bourgogne-Franche-Comté Region (Nano6D), and the Open program of CNRS Innovation. It has been achieved in the frame of the EIPHI Graduate School (ANR-17-EURE-0002). The encoded targets were realized thanks to the RENATECH technological network and its FEMTO-ST facility MIMENTO. The experiments were conducted within the ROBOTEX network (ANR-21-ESRE-0015) and its FEMTO-ST technological facility CMNR.

References

Acher, O., Nguyên, T.-L., Podzorov, A., Leroy, M., Carles, P.-A., & Legendre, S. (2021). An efficient solution for correlative microscopy and co-localized observations based on multiscale multimodal machine-readable nanoGPS tags. *Measurement Science and Technology*, *32*(4), 045402. https://doi.org/10.1088/1361-6501/abce39

DRAFT

Ahmad, B., Sandoz, P., & Laurent, G. J. (2024). 6-DoF motion capture with nanometric resolutions over millimetric ranges using a pseudo-periodic encoded pattern. *IEEE Transactions on Instrumentation and Measurement*. https://doi.org/10.1109/TIM.2024.3523360

André, A. N., Lehmann, O., Govilas, J., Laurent, G. J., Saadana, H., Sandoz, P., Gauthier, V., Lefèvre, A., Bolopion, A., Agnus, J., Placet, V., & Clévy, C. (2022). Automating robotic micro-assembly of fluidic chips and single fiber compression tests based-on Θ visual measurement with high-precision fiducial markers. *IEEE Transactions on Automation Science and Engineering*. https://doi.org/10.1109/TASE.2022.3218686

André, A. N., Sandoz, P., Jacquot, M., & Laurent, G. J. (2022). Pose measurement at small scale by spectral analysis of periodic patterns. *International Journal of Computer Vision*, *130*(6), 1566–1582. https://doi.org/10.1007/s11263-022-01607-7

André, A. N., Sandoz, P., Mauzé, B., Jacquot, M., & Laurent, G. J. (2020a). Robust phase-based decoding for absolute (X, Y, Θ) positioning by vision. *IEEE Transactions on Instrumentation and Measurement*, *70*, 1–12. https://doi.org/10.1109/TIM.2020.3009353

André, A. N., Sandoz, P., Mauzé, B., Jacquot, M., & Laurent, G. J. (2020b). Sensing one nanometer over ten centimeters: A microencoded target for visual in-plane position measurement. *IEEE/ASME Transactions on Mechatronics*, *25*(3), 1193–1201. https://doi.org/10.1109/TMECH.2020.2965211

Galeano Zea, J., Sandoz, P., Gaiffe, E., Launay, S., Robert, L., Jacquot, M., Hirchaud, F., Prétet, J.-L., & Mougin, C. (2011). Position-referenced microscopy for live cell culture monitoring. *Biomedical Optics Express*, *2*(5), 1307–1318. https://doi.org/10.1364/BOE.2.001307

Gallardo, O. F., Mauzé, B., Dahmouche, R., Duriez, C., & Laurent, G. J. (2021). Turning an articulated 3-PPSR manipulator into a parallel continuum robot. *Proceedings of the IEEE/RSJ International Conference on Intelligent Robots and Systems*, 4955–4960. https://doi.org/10.1109/IROS51168.2021.9636596

Govilas, J., Chevallier, A., Akleh, W., Beaugrand, J., Clévy, C., & Placet, V. (2024). Mechanical behavior and apparent stiffness of flax, hemp and nettle fibers under single fiber transverse compression tests. *Composites Part A: Applied Science and Manufacturing*, *185*, 108321. https://doi.org/10.1016/j.compositesa.2024.108321

Guelpa, V., Laurent, G. J., Sandoz, P., & Clévy, C. (2015). Vision-based microforce measurement with a large range-to-resolution ratio using a twin-scale pattern. *IEEE/ASME Transactions on Mechatronics*, *20*(6), 3148–3156. https://doi.org/10.1109/TMECH.2015.2407053

Lee, C., Kim, G. H., & Lee, S.-K. (2011). Design and construction of a single unit multi-function optical encoder for a six-degree-of-freedom motion error measurement in an ultraprecision linear stage. *Measurement Science and Technology*, *22*(10), 105901. https://doi.org/10.1088/0957-0233/22/10/105901

Mauzé, B., Dahmouche, R., Laurent, G. J., André, A. N., Rougeot, P., Sandoz, P., & Clévy, C. (2020). Nanometer precision with a planar parallel continuum robot. *IEEE Robotics and Automation Letters*, *5*(3), 3806–3813. https://doi.org/10.1109/LRA.2020.2982360

Ortlepp, I. (2024). High-precision nanopositioning and nanomeasuring machines for alternative nanofabrication. *Novel Patterning Technologies 2024*, *12956*, 90–106. https://doi.org/10.1117/12.3010844

Tan, N., Clévy, C., Laurent, G. J., Sandoz, P., & Chaillet, N. (2015). Accuracy quantification and improvement of serial micropositioning robots for in-plane motions. *IEEE Transactions on Robotics*, *31*(6), 1497–1507. https://doi.org/10.1109/TRO.2015.2498301

Tiwari, B., Blot, M., Laurent, G. J., Agnus, J., Sandoz, P., Lutz, P., & Clévy, C. (2021). A high

DRAFT

range-to-resolution multiaxis μforce and torque sensing platform. *IEEE/ASME Transactions on Mechatronics*, *26*(4), 1837–1845. https://doi.org/10.1109/TMECH.2021.3071444

Yao, S., Li, H., Pang, S., Zhu, B., Zhang, X., & Fatikow, S. (2021). A review of computer microvision-based precision motion measurement: Principles, characteristics, and applications. *IEEE Transactions on Instrumentation and Measurement*, *70*, 1–28. https://doi.org/10.1109/TIM.2021.3065436

DRAFT