

VERNIER: an open-source library pushing marker pose estimation to nanometric resolutions

Patrick Sandoz¹, Antoine N. André², Sasha Ballet¹, Victorien Lanneau¹, and Guillaume J. Laurent^{1¶}

¹ Université Marie et Louis Pasteur, CNRS, SupMicroTech, Institut FEMTO-ST, Besançon, France ² National Institute of Advanced Industrial Science and Technology, CNRS-AIST JRL, IRL, Tsukuba, Japan ¶ Corresponding author

DOI: [10.xxxxxx/draft](https://doi.org/10.xxxxxx/draft)

Software

- [Review](#)
- [Repository](#)
- [Archive](#)

Editor: [Open Journals](#)

Reviewers:

- [@openjournals](#)

Submitted: 01 January 1970

Published: unpublished

License

Authors of papers retain copyright and release the work under a Creative Commons Attribution 4.0 International License ([CC BY 4.0](#)).

Summary

At the small scales, few solutions exist to capture the pose of an object with nanometric and microradian resolutions over relatively large ranges. Over the years, we have proposed several fiducial marker and pattern designs to achieve reliable performance for various microscopy applications. VERNIER is an open source phase processing library designed to provide accurate pose measurement based on these results. Centimeter ranges are possible using binary encoding methods, while nanometer resolutions can be achieved using phase processing of the periodic patterns. Moreover, the detection has proven to be particularly robust to noise, defocus and occlusion thanks to a local thresholding algorithm based on the phase. The paper presents the measurement principles and the patterns implemented in VERNIER addressing different application needs.

Statement of need

The VERNIER library provides a powerful tool to measure the 2D and 3D poses of objects observed through a microscope lens with unprecedented sub-pixel resolutions and ranges. The library works in combination with markers fixed on the objects of interest, allowing accurate measurements even in noisy and blurry imaging conditions which are common in microscopy. The image processing involves two complementary steps, resulting on the one hand in fine but relative position measurement and, on the other hand, a coarser but absolute localization. The fine position process achieves high sub-pixel resolutions thanks to spectral analysis of the imaged periodic pattern of the marker. Complementary coarse measurements are retrieved either from the marker contours or from a binary sequence encrypted within the pattern.

VERNIER works with three different types of markers, designed to meet different application requirements, and whose design can be easily adapted to specific imaging parameters, mainly magnification, field of view (FoV), and expected measurement range and resolution (cf. [Figure 1](#)). Sources and layouts are available on [GitHub](#) and can be downloaded for evaluation and testing.




Figure 1: The three marker types (on the left an HP code marker, in the middle a Stamp marker, on the right a Megarena encoded pattern).

State of the field

Computer vision is widely used to track the movement of people and objects in many applications. When the size of the object of interest decreases, pose estimation becomes challenging due to the constraint of microscopy imaging. Unlike regular cameras, microscopes suffer from narrow FoV, short depths of field, low contrasts and out-of-focus blurs, and usual fiducial markers perform poorly in these conditions.

Many vision-based methods have been proposed to tackle pose estimation at the small scales. In 2021, Fatikow published a review paper comparing the resolution and the range of state-of-the-art vision-based localization methods (Yao et al., 2021). The most precise methods use phase correlation and can achieve sub-nanometer resolutions. However, their measurement ranges are still limited by the microscope's FoV. To overcome this limitation, pseudo-periodic patterns can be used to encode the absolute position over centimetric ranges, while using phase measurement to achieve nanometer resolutions (Antoine N. André et al., 2020b, 2020a). Based on this principle, VERNIER proposed processing algorithms for several markers and patterns that ensure reliable performance in various microscopy applications. As reported in Fatikow's survey paper (Yao et al., 2021), this approach achieves a better range-to-resolution ratio compared with other methods, including HORIBA's proprietary NanoGPS solution (Acher et al., 2021).

The measurement principle is mainly suited for in-plane 3 degrees of freedom (DoF) pose estimation under microscopy orthographic projection. However, long-focal perspective projection can be used for retrieving complementary out-of-plane pose parameters with a lower resolution. Full out-of-plane pose estimation details and performances can be found in (Antoine N. André et al., 2022b).

To achieve the measurement of the 6 DoF, the same approach is applied but with a digital holographic microscope (DHM). The interferometric character of DHM makes the device highly sensitive to out-of-plane motion and the 6 DoF are measured simultaneously in a single image with a high resolution (Ahmad et al., 2024).

Figure 2 presents the mean features and metrics of the pose estimation of all marker types. All the metrics have been validated experimentally with precision stages and robots using the 'VERNIER' C++ implementation (Antoine N. André et al., 2020b, 2020a, 2022b) with the exception of the hologram processing, which was performed beforehand using the DHM's software and MATLAB (Ahmad et al., 2024).



	Optical microscopy (orthographic projection)	Digital holographic microscopy (orthographic projection + interferometry)	Long-focus lens (perspective projection without distortion)
Absolute pose estimation 	2D (x, y, rz) Resolutions: 1nm, 4μrad Ranges: 110mm, 2π rad	3D (x, y, z, rx, ry, rz) In-plane res: 1nm, 4μrad In-plane ranges: 110mm, 2π Out-of-plane res: 1nm, 0.1μrad Out-of-plane ranges: 0.2mm, 0.2rad	3D (x, y, z, rx, ry, rz) In-plane res: 0.1μm, 4μrad In-plane ranges: 150mm, 2π Out-of-plane res: 0.1mm, 0.1mrad Out-of-plane ranges: 10mm, 0.4rad
Relative pose estimation 	2D (x, y, rz) Resolutions: 5nm, 10μrad Ranges: fov, 2π rad	3D (x, y, z, rx, ry, rz) Resolutions: not evaluated yet In-plane ranges: fov, 2π rad Out-of-plane ranges: 0.2mm, 0.2rad	3D (x, y, z, rx, ry, rz) Resolutions: not evaluated yet In-plane ranges: fov, 2π rad Out-of-plane ranges: dof, 0.4rad

Figure 2: Overview of features and metrics of the marker pose estimation with VERNIER.

65 **Software design**

66 VERNIER is written in C++ and provides a class hierarchy for detection and estimating the pose
67 of three kinds of calibrated patterns (Megarena patterns, HP code and Stamp markers). The
68 library is cross-platform. The users can build the examples and unit tests using CMake. The
69 library relies on multiple third parties: OpenCV, Eigen, FFTW, MatIO, RapidJSON and GDS Tool
70 Kit.

71 The class hierarchy is centered on general periodic pattern processing and then extends to the
72 different types of patterns. All pose estimations rely on the Fourier transforms of the entire
73 image. To achieve fast computation times, the current version of the library uses the MIT
74 implementation (FFTW). Future releases will support GPU-based Fourier transform processing.

75 The library also provides a set of classes for rendering synthetic images and exporting layouts
76 of the different markers presented in previous section. The synthetic images are used to test
77 the correct functioning of the detectors. The marker layouts can be exported in PNG, SVG, GDS
78 and OASIS formats. These files can be used to print the markers on various supports.

79 As the measurement method is based on the phase of the periodic pattern, the position
80 accuracy is directly related to the scale and quality of the pattern fabrication. To obtain
81 calibrated measures, all the patterns have been realized using a high-resolution maskless aligner
82 (Heidelberg MLA150) on quartz or glass substrates within the [MIMENTO facility](#).

83 To reach the best resolution, the magnification and the size of the marker should be set so
84 that the period of the marker spans onto 7 to 15 image pixels.

85 **Research impact statement**

86 VERNIER has found many applications in microrobotics as presented in [Figure 3](#).




Figure 3: Overview of applications of pose estimation at the small scales with VERNIER.

Metrology of precision manipulators

One of the key advantages of Megarena patterns is their ability to perform the metrology of micro and nano stages and precision manipulators. Indeed, few solutions to measure the 3D pose of the manipulator end-effector at the nanoscale are available. The laser interferometers provide a very high range-to-resolution ratio of approximately 10^9 but only along the laser's axis. Setups with several interferometers have demonstrated multiple DoF measurement systems (Lee et al., 2011; Ortlepp, 2024), at the expense of occupied volume and calibration complexity. Moreover, due to the constraints of laser reflection, the range of their angular measurements is very low, not exceeding a magnitude of one milliradian.

The use of Megarena patterns is much simpler and also provides nanometric resolution and centimeter ranges. Moreover, using a DHM, the angular ranges of out-of-plane rotations reach 0.2 rad with resolutions down to 0.1 μ rad. The ideal setup consists only of a microscope and a piece of a Megarena pattern attached to the end effector of the manipulator.

For example, the method has been used to evaluate the accuracy of a precision hexapod, showing that it is able to follow millimeter trajectories with deviations of less than one micrometer (Ahmad et al., 2024). It has also been employed to evaluate the accuracy of a serial 6-DoF manipulator over a point matrix of 10 by 10 centimeters (Antoine N. André et al., 2020b). Megarena patterns can also be used to measure the repeatability of positioning of stages and manipulators. For instance, in (Gallardo et al., 2021; Mauzé et al., 2020), the method is used to evaluate the precision of parallel continuum robots.

Beyond stages and manipulators metrology, the method could also be useful for measuring the deviation of CNC machines and vision measuring machines.

Multi-DoF stage automation

The Megarena patterns can also be used as position sensor to directly control the position of the motion platform of a multi-DoF manipulator during its operation. This ensures the actual position of the end-effector regardless of the errors introduced by assembly of stages, guidance, compliance, and backlash in the mechanical axis. It could also help to identify and correct cross-axis coupling and unwanted motion in multi-DoF systems, as proposed in (Tan et al., 2015).

As no internal additional sensors are required, pattern-based direct measurement can be applied

117 to an existing manipulator to improve its accuracy and to carry on precision tasks such as
118 micro-assembly.

119 **Micro-assembly**

120 Micro-assembly requires two parts to be positioned relatively to each other with high precision.
121 To make assemblies with errors lower than a micrometer, the joint sensors of the manipulators
122 are not sufficient and it is necessary to use visual servoing to control the relative position of the
123 parts. To that extent, markers are placed on each of the parts to assemble and their relative
124 position is monitored in real time during the assembly process. In (Antoine N. André et al.,
125 2022a), two HP code markers are used to align and bond two parts of a microfluidic chip.
126 This automated assembly achieved a positioning accuracy of better than 50 nm.

127 Beyond this assembly example, HP code and Stamp markers could also be useful for wafer
128 alignment in photolithography processes, die assembly in the semiconductor industry, and
129 stitching in high-resolution 3D printing and laser processing.

130 **Micro-force measurement**

131 Another key application in microrobotics is simultaneous force and displacement sensing. Force
132 sensing has always been an issue for micro- and nanoscale applications. Force ranges from a few
133 mN to a few hundred mN are typically required for manipulation, assembly and characterization
134 tasks in most fields.

135 In (Antoine N. André et al., 2022a), two HP code markers have been attached to a compliant
136 mechanism. The relative motion between the markers gives an image of the compression
137 force, while the relative position of the markers to the camera frame gives the displacement of
138 the mechanism base. This force sensor has been used experimentally to perform automated
139 compression tests on individual synthetic and natural fibers, providing very rich information
140 and allowing to better understand the mechanical fiber behavior (Govilas et al., 2024).

141 Previous experiments with this method have shown resolution measurements down to 50 nN
142 with experimental ranges of 50 mN (Guelpa et al., 2015). The same principle has also been
143 applied to multiple directions force sensing in (Tiwari et al., 2021).

144 **Correlative Microscopy**

145 The pattern-based position measurement was initially developed to perform the repositioning
146 of Petri dishes under a microscope for live cell monitoring (Galeano Z et al., 2011). Thanks
147 to a pattern similar in principle to the Megarena, regions of interest of a culture dish were
148 easily retrieved after transfers from a cell incubator to the microscope stage. Thanks to this
149 approach, images of single cells can be captured at different time steps in a repeatable manner,
150 as the cells can be identified based on their absolute position in the Petri dish.

151 In this way, Megarena patterns could also be used in correlative microscopy, to retrieve the
152 position of the very same cell or tissue area and image it with various modalities (e.g. electron,
153 confocal, fluorescent microscopes).

154 **AI usage disclosure**

155 No generative AI tools were used in the writing of this manuscript, the preparation of supporting
156 materials, and the development of this software (release v0.0.1 main@0b25da7).

157 **Acknowledgements**

158 This work has been supported by the ANR project Holo-Control (ANR-21-CE42-0009), the
159 Bourgogne-Franche-Comté Region (Nano6D), and the Open program of CNRS Innovation.
160 It has been achieved in the frame of the EIPHI Graduate School (ANR-17-EURE-0002).

The encoded targets were realized thanks to the RENATECH technological network and its FEMTO-ST facility MIMENTO. The experiments were conducted within the ROBOTEX network (ANR-21-ESRE-0015) and its FEMTO-ST technological facility CMNR.

References

- Acher, O., Nguyễn, T.-L., Podzorov, A., Leroy, M., Carles, P.-A., & Legendre, S. (2021). An efficient solution for correlative microscopy and co-localized observations based on multiscale multimodal machine-readable nanoGPS tags. *Measurement Science and Technology*, 32(4), 045402. <https://doi.org/10.1088/1361-6501/abce39>
- Ahmad, B., Sandoz, P., & Laurent, G. J. (2024). 6-DoF motion capture with nanometric resolutions over millimetric ranges using a pseudo-periodic encoded pattern. *IEEE Transactions on Instrumentation and Measurement*. <https://doi.org/10.1109/TIM.2024.3523360>
- André, Antoine N., Lehmann, O., Govilas, J., Laurent, G. J., Saadana, H., Sandoz, P., Gauthier, V., Lefèvre, A., Bolopion, A., Agnus, J., Placet, V., & Clévy, C. (2022a). Automating robotic micro-assembly of fluidic chips and single fiber compression tests based-on XYΘ visual measurement with high-precision fiducial markers. *IEEE Transactions on Automation Science and Engineering*. <https://doi.org/10.1109/TASE.2022.3218686>
- André, Antoine N., Sandoz, P., Jacquot, M., & Laurent, G. J. (2022b). Pose measurement at small scale by spectral analysis of periodic patterns. *International Journal of Computer Vision*, 130(6), 1566–1582. <https://doi.org/10.1007/s11263-022-01607-7>
- André, Antoine N., Sandoz, P., Mauzé, B., Jacquot, M., & Laurent, G. J. (2020a). Robust phase-based decoding for absolute (x, y, Θ) positioning by vision. *IEEE Transactions on Instrumentation and Measurement*, 70, 1–12. <https://doi.org/10.1109/TIM.2020.3009353>
- André, Antoine N., Sandoz, P., Mauzé, B., Jacquot, M., & Laurent, G. J. (2020b). Sensing one nanometer over ten centimeters: A microencoded target for visual in-plane position measurement. *IEEE/ASME Transactions on Mechatronics*, 25(3), 1193–1201. <https://doi.org/10.1109/TMECH.2020.2965211>
- Galeano Z, J. A., Sandoz, P., Gaiffe, E., Launay, S., Robert, L., Jacquot, M., Hirschaud, F., Prétet, J.-L., & Mougin, C. (2011). Position-referenced microscopy for live cell culture monitoring. *Biomedical Optics Express*, 2(5), 1307–1318. <https://doi.org/10.1364/BOE.2.001307>
- Gallardo, O. F., Mauzé, B., Dahmouche, R., Duriez, C., & Laurent, G. J. (2021). Turning an articulated 3-PPSR manipulator into a parallel continuum robot. *Proceedings of the IEEE/RSJ International Conference on Intelligent Robots and Systems*, 4955–4960. <https://doi.org/10.1109/IROS51168.2021.9636596>
- Govilas, J., Chevallier, A., Akleh, W., Beaugrand, J., Clévy, C., & Placet, V. (2024). Mechanical behavior and apparent stiffness of flax, hemp and nettle fibers under single fiber transverse compression tests. *Composites Part A: Applied Science and Manufacturing*, 185, 108321. <https://doi.org/10.1016/j.compositesa.2024.108321>
- Guelpa, V., Laurent, G. J., Sandoz, P., & Clévy, C. (2015). Vision-based microforce measurement with a large range-to-resolution ratio using a twin-scale pattern. *IEEE/ASME Transactions on Mechatronics*, 20(6), 3148–3156. <https://doi.org/10.1109/TMECH.2015.2407053>
- Lee, C., Kim, G. H., & Lee, S.-K. (2011). Design and construction of a single unit multi-function optical encoder for a six-degree-of-freedom motion error measurement in an ultraprecision linear stage. *Measurement Science and Technology*, 22(10), 105901. <https://doi.org/10.1088/0957-0233/22/10/105901>

- 208 Mauzé, B., Dahmouche, R., Laurent, G. J., André, A. N., Rougeot, P., Sandoz, P., & Clévy, C.
209 (2020). Nanometer precision with a planar parallel continuum robot. *IEEE Robotics and*
210 *Automation Letters*, 5(3), 3806–3813. <https://doi.org/10.1109/LRA.2020.2982360>
- 211 Ortlepp, I. (2024). High-precision nanopositioning and nanomeasuring machines for alternative
212 nanofabrication. *Novel Patterning Technologies 2024*, 12956, 90–106. [https://doi.org/10.](https://doi.org/10.1117/12.3010844)
213 [1117/12.3010844](https://doi.org/10.1117/12.3010844)
- 214 Tan, N., Clévy, C., Laurent, G. J., Sandoz, P., & Chaillet, N. (2015). Accuracy quantification
215 and improvement of serial micropositioning robots for in-plane motions. *IEEE Transactions*
216 *on Robotics*, 31(6), 1497–1507. <https://doi.org/10.1109/TRO.2015.2498301>
- 217 Tiwari, B., Blot, M., Laurent, G. J., Agnus, J., Sandoz, P., Lutz, P., & Clévy, C. (2021). A high
218 range-to-resolution multiaxis μ force and torque sensing platform. *IEEE/ASME Transactions*
219 *on Mechatronics*, 26(4), 1837–1845. <https://doi.org/10.1109/TMECH.2021.3071444>
- 220 Yao, S., Li, H., Pang, S., Zhu, B., Zhang, X., & Fatikow, S. (2021). A review of
221 computer microvision-based precision motion measurement: Principles, characteristics,
222 and applications. *IEEE Transactions on Instrumentation and Measurement*, 70, 1–28.
223 <https://doi.org/10.1109/TIM.2021.3065436>

DRAFT