

Bar bending schedule

Sattva Court



Project Sattva Court (SC-001)
 Client Sattva Holdings
 Site Bashundhara R/A, Dhaka

Drawings Issued Structural drawings, revision 2, pinned 22 Sep 2026
 24 Sep 2026
 Cut from Stock bars of 12,000 mm; each length rounded once, up to the next 25 mm

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
C1 • Column • FDN									3 members	
C1-d	Main	16		11 A 1,854.2, B 192	2,014.2	2,025	2,014.2	8	24	76.329
Lap		16		800 × 1 per bar						30.318
C1-t	Tie	10		51 A 320, B 320, C 320, D 320, E 100, F 100	1,380	1,400	1,360	7	21	17.853
C2 • Column • FDN									8 members	
C2-d	Main	20		11 A 1,854.2, B 240	2,039.2	2,050	2,054.2	10	80	402.296
Lap		20		1,000 × 1 per bar						197.280
C2-t	Tie	10		51 A 220, B 520, C 220, D 520, E 100, F 100	1,580	1,600	1,560	7	56	54.504
C3 • Column • FDN									6 members	
C3-d	Main	20		11 A 1,854.2, B 240	2,039.2	2,050	2,054.2	8	48	241.374
Lap		20		1,000 × 1 per bar						118.368
C3-t	Tie	10		51 A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	7	42	35.706
C4 • Column • FDN									7 members	
C4-d	Main	25		11 A 1,854.2, B 300	2,085.45	2,100	2,104.2	12	84	675.136
Lap		25		1,250 × 1 per bar						404.670

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
C4 • Column • FDN									7 members	
C4-t	Tie	10		51 A 370, B 520, C 370, D 520, E 100, F 100	1,880	1,900	1,860	7	49	56.749
C6 • Column • FDN									1 member	
C6-d	Main	20		11 A 1,854.2, B 240	2,039.2	2,050	2,054.2	8	8	40.229
Lap		20		1,000 × 1 per bar						19.728
C6-t	Tie	10		51 A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	7	7	5.951
C7 • Column • FDN									1 member	
C7-d	Main	20		11 A 1,854.2, B 240	2,039.2	2,050	2,054.2	8	8	40.229
Lap		20		1,000 × 1 per bar						19.728
SW1 • Shear wall • FDN									2 members	
SW1-v	Main	12		00 A 609.6	609.6	625	609.6	36	72	38.976
Lap		12		600 × 1 per bar						38.362
SW1-h	Horizontal	10		11 A 2,648.4, B 120	2,748.4	2,750	2,748.4	8	16	27.088
SW1 • Shear wall • FDN									2 members	
SW1-v	Main	12		00 A 609.6	609.6	625	609.6	34	68	36.810
Lap		12		600 × 1 per bar						36.230
SW1-h	Horizontal	10		11 A 2,453.2, B 120	2,553.2	2,575	2,553.2	8	16	25.164
C1 • Column • GF									3 members	
C1-v	Main	16		00 A 3,352.8	3,352.8	3,375	3,352.8	8	24	127.059
Lap		16		800 × 1 per bar						30.318
C1-t	Tie	10		51 A 320, B 320, C 320, D 320, E 100, F 100	1,380	1,400	1,360	30	90	76.506

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
C2 • Column • GF									8 members	
C2-v	Main	20		A 3,352.8	3,352.8	3,375	3,352.8	10	80	661.440
Lap		20		1,000 × 1 per bar						197.280
C2-t	Tie	10		A 220, B 520, C 220, D 520, E 100, F 100	1,580	1,600	1,560	32	256	249.160
C3 • Column • GF									6 members	
C3-v	Main	20		A 3,352.8	3,352.8	3,375	3,352.8	8	48	396.864
Lap		20		1,000 × 1 per bar						118.368
C3-t	Tie	10		A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	31	186	158.112
C4 • Column • GF									5 members	
C4-v	Main	25		A 3,352.8	3,352.8	3,375	3,352.8	12	60	775.300
Lap		25		1,250 × 1 per bar						289.050
C4-t	Tie	10		A 370, B 520, C 370, D 520, E 100, F 100	1,880	1,900	1,860	31	155	179.500
C4 • Column • GF									2 members	
C4-v	Main	25		A 3,352.8	3,352.8	3,375	3,352.8	12	24	310.120
Lap		25		1,250 × 1 per bar						115.620
C4-t	Tie	10		A 370, B 520, C 370, D 520, E 100, F 100	1,880	1,900	1,860	33	66	76.434
C6 • Column • GF									1 member	
C6-v	Main	20		A 3,352.8	3,352.8	3,375	3,352.8	8	8	66.144
Lap		20		1,000 × 1 per bar						19.728
C6-t	Tie	10		A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	30	30	25.502

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
C7 • Column • GF										1 member
C7-v	Main	20		A 3,352.8	3,352.8	3,375	3,352.8	8	8	66.144
Lap		20		1,000 × 1 per bar						19.728
SW1 • Shear wall • GF										2 members
SW1-v	Main	12		A 3,352.8	3,352.8	3,375	3,352.8	34	68	202.456
Lap		12		600 × 1 per bar						36.230
SW1-h	Horizontal	10		A 2,523.4, B 120	2,623.4	2,625	2,623.4	44	88	142.210
SW1 • Shear wall • GF										1 member
SW1-v	Main	12		A 3,352.8	3,352.8	3,375	3,352.8	34	34	101.228
Lap		12		600 × 1 per bar						18.115
SW1-h	Horizontal	10		A 2,453.2, B 120	2,553.2	2,575	2,553.2	44	44	69.202
C1 • Column • 1F										3 members
C1-v	Main	16		A 3,048	3,048	3,050	3,048	8	24	115.506
Lap		16		800 × 1 per bar						30.318
C1-t	Tie	10		A 320, B 320, C 320, D 320, E 100, F 100	1,380	1,400	1,360	28	84	71.406
C2 • Column • 1F										8 members
C2-v	Main	20		A 3,048	3,048	3,050	3,048	10	80	601.312
Lap		20		1,000 × 1 per bar						197.280
C2-t	Tie	10		A 220, B 520, C 220, D 520, E 100, F 100	1,580	1,600	1,560	30	240	233.584
C3 • Column • 1F										6 members
C3-v	Main	20		A 3,048	3,048	3,050	3,048	8	48	360.786
Lap		20		1,000 × 1 per bar						118.368

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
C3 • Column • 1F									6 members	
C3-t	Tie	10		51 A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	29	174	147.912
C4 • Column • 1F									7 members	
C4-v	Main	25		00 A 3,048	3,048	3,050	3,048	12	84	986.748
Lap		25		1,250 × 1 per bar						404.670
C4-t	Tie	10		51 A 370, B 520, C 370, D 520, E 100, F 100	1,880	1,900	1,860	29	203	235.088
C5 • Column • 1F									1 member	
C5-v	Main	20		00 A 3,048	3,048	3,050	3,048	8	8	60.131
Lap		20		1,000 × 1 per bar						19.728
C5-t	Tie	10		51 A 220, B 370, C 220, D 370, E 100, F 100	1,280	1,300	1,260	27	27	21.289
C6 • Column • 1F									1 member	
C6-v	Main	20		00 A 3,048	3,048	3,050	3,048	8	8	60.131
Lap		20		1,000 × 1 per bar						19.728
C6-t	Tie	10		51 A 220, B 420, C 220, D 420, E 100, F 100	1,380	1,400	1,360	28	28	23.802
SW1 • Shear wall • 1F									2 members	
SW1-v	Main	12		00 A 3,048	3,048	3,050	3,048	34	68	184.050
Lap		12		600 × 1 per bar						36.230
SW1-h	Horizontal	10		11 A 2,523.4, B 120	2,623.4	2,625	2,623.4	40	80	129.282
SW1 • Shear wall • 1F									1 member	
SW1-v	Main	12		00 A 3,048	3,048	3,050	3,048	34	34	92.025
Lap		12		600 × 1 per bar						18.115

DRAFT — UNSIGNED

Bar mark	Role	Dia (mm)	Shape	Dimensions (mm)	Cutting length (mm)	Rounded (mm)	IS 2502 (mm)	In each	Total	Mass (kg)
SW1 · Shear wall · 1F										1 member
SW1-h	Horizontal	10		A 2,453.2, B 120	2,553.2	2,575	2,553.2	40	40	62.911

Declared, not scheduled

This bar is bent to a shape the schedule's BS 8666 roster does not hold, so it is declared here and its mass is left out of every total.

Bar mark	Member	Role	Dia (mm)	Shape	Cutting length (mm)	Total	Mass (kg)
C7-h	C7 · Column · FDN, 1 member	Tie	10	CH	1,322.389	7	5.702
C7-h	C7 · Column · GF, 1 member	Tie	10	CH	1,322.389	34	27.696
Excluded from the total mass							33.398

Cutting stock by diameter

Dia (mm)	Mass (kg)	Stock bars	Pieces	Offcut (m)
10	2,124.915	306	1,998	185.700
12	838.825	68	344	73.150
16	409.845	20	72	37.200
20	4,062.392	116	432	171.600
25	3,961.314	68	252	99.900
Total mass	11,397.291	Excludes the 33.398 kg declared, not scheduled		

Stock bars, pieces and offcut describe what a site cuts from a stock bar. They are informational and are never billed.

DRAFT — UNSIGNED

Prepared by

Name _____

Signature _____

Date _____

Checked by

Name _____

Signature _____

Date _____

Completed by hand. This schedule is a draft: it names no surveyor and certifies no quantity.

