

DESIGN CRITERIA:	
PROJECT NAME: NORTEX STOCK 2860	BUILDING SQUARE FOOTAGE: 1650 SF
2002 NEC	2003 IBC
2003 IMC	2003 IPC
2003 IECC	1994 TAS
USE GROUP: B	
CONSTRUCTION TYPE: IBC, V-B	
OCCUPANT LOAD: 17	
PERMISSIBLE GAS TYPE: <input type="checkbox"/> LP <input type="checkbox"/> NATURAL <input checked="" type="checkbox"/> NA	
DESIGN LOADS:	
ROOF LIVE LOAD: 30 PSF	FLOOR LIVE LOAD: 100 PSF (SEE S-101 FOR 50 PSF SPACING)
CONC. FLOOR LIVE LOAD: 2000 LBS	WIND LOAD: (130 MPH 3-SEC GUST)
EXPOSURE: B	SEISMIC DESIGN CATEGORY: 1-D
SPECIAL CONDITIONS AND/OR LIMITATIONS:	
1. HANDICAP ACCESS TO BE PROVIDED AS REQUIRED BY OTHERS.	
2. THE BUILDING IS TO BE LOCATED PER THE REQUIREMENTS OF TABLE 602 OF THE 2003 IBC.	
3. ANY REQUIRED ALARM SYSTEM WILL BE INSTALLED ONSITE BY OTHERS.	
FOUNDATION NOTES:	
1. THE DOWN ANCHORING SEE SHEET S-101	
2. GRAVEL SPACE VENTILATION TO BE PROVIDED BY SITE INSTALLER PER 1203.3.1 OF 2003 IBC.	
SCOPE OF WORK:	
NOT INCLUDED IN SCOPE OF WORK	
1. UTILITIES AND UTILITY CONNECTIONS	
2. POURED CONCRETE (DRIVEWAY, SIDEWALK, SLABS, FOOTINGS, ECT.)	
3. SITE PREPARATION	
4. TAX OF ANY KIND	
5. BUILDING PERMITS	
SITE WORK	
1. NO PROVISION FOR SITE WORK HAS BEEN INCLUDED. IT IS PRESUMED THE SITE WILL PROVIDE CLEAR ACCESS FOR TRUCKS AND MODULES.	
2. ADEQUATE DRAINAGE TO BE PROVIDED.	
3. ALL ELECTRICAL, PLUMBING, SEWER, & GAS SERVICE CONNECTIONS AND ALL CONCRETE WORK ONSITE. TO INCLUDE POURED FOOTINGS, SLABS, FOUNDATIONS, SIDEWALKS. DRIVEWAYS OF WHATEVER KIND ARE THE RESPONSIBILITY OF OTHERS.	
IDENTIFICATION:	
STATE DECAL: TDLR, TEXAS ENGINEER, DATA PLATE PLACED IN PANEL BOX.	
DECAL: NORTEX	
FRAME / CHASSIS:	
OUTRIGGERS: 48" O.C.	
CROSSMEMBERS: 48" O.C.	
BEAM: 12" JR. L-BEAM	
HITCH: DETACHABLE HITCH	
AXLES: (5) AXLES- (3) BRAKE AND (2) DRAG	
TIRES: L (10-PLY)	
FRAME: HEAVY	

FLOOR:	
BOTTOM BOARD: ROLL POLYETHYLENE FIBER MESH	INSULATION: R-19 FACED
JOIST: 2X8 #2SYP OR BETTER AT 16" O.C.	SIDE BAND JOIST (RM): 2X8 #2SYP OR BETTER
DECKING: 3/4" T&G OSB (DRY GLUED) GLUED WITH SCREWS	UNDERLAYMENT: 1/4" HARDE PANEL, SCREWED
COVERING: 1/8" TILE WHITE #51899, OFFICES 260Z CARPET= SAND PEBBLES	BASE COVE: 4" RUBBER, COLOR= GREY

EXTERIOR WALLS:	
SIDEWALL HEIGHT: FULL HEIGHT REFERENCE SHEET A-301	
STUDS: 2X4 #2SYP 16" O.C. DOUBLE WHERE HEIGHT EXCEEDS 11'9.65"	
BOTTOM PLATE: SINGLE 2X4 #3SYP	
TOP PLATES: DOUBLE 2X4 #3SYP	
HEADERS: DOUBLE 2X6 W/ 7/16" FILLER	
JACK STUDS: SINGLE EACH SIDE 2X4 #2SYP	
FIRE BLOCKING: 2X4 ON EDGE AT THE CEILING LINE	
INSULATION: R-13 FACED	
SHEATHING: NONE	
SIDING: 7/16" SMART PANEL	
COLOR: SEE SHEET A-201	
TRIM: 1X4 SMART PANEL	
COLOR: SEE SHEET A-201	
SKIRTING: SHIP LOOSE (12) 4X12 SHTS SMART PNL PAINTED TO MATCH BODY IF ORDERED	
IF SKIRTING IS ORDERED, 12" X12" VENTS TO BE SHIPPED WITH MATERIAL.	

INTERIOR WALLS:	
WALL HEIGHT: FULL HEIGHT	
STUDS 2X4 #2SYP 16" O.C.	
BOTTOM PLATE: SINGLE 2X4 #3SYP	
TOP PLATES: DOUBLE 2X4 #3SYP	
FIRE BLOCKS: 2X4 ON EDGE AT CEILING LINE	
COVERING: 5/8" FIRE X VOC COLOR: HAMTOM GRAY	
5/8" GREEN BOARD AT RESTROOM COVERED WITH FRP	
TRIM: STANDARD VCG BATTENS	
FRP: FULL HEIGHT AT RESTROOM	
INSULATION: R-11 UNFACED THROUGHOUT.	
MSC:	

WINDOWS:	
SIZE/TYPER: (9) 24"X32" V.S. BRONZE/CLEAR LOW E GLASS, SCREW ATTACHED	
BRAND: HR	
COVERING: (9) ALUMINUM MINI-BLINDS	
COLOR: GRAY	
MSC: N/A	

DOORS:	
EXTERIOR (2) 1/1R 36"X80" 18GA STEEL W/ 5"X20" PENCL WINDOW (TEMP)	
EXTERIOR HARDWARE:	
(2) DEADBOLT (SCHLAGE) B660 BD x 26D W/IC CONSTR. CORE	
(2) 9305BC x AL NORTON CLOSURER	
(2) HOLLOW METAL FRAME	
(4) PULL PLATES ROCKWOOD #107 x 70C X US28	
(2) PEMCO THRESHOLD 170A-36	
(2) PEMCO SWEEP 315CN-36	
(2) SET PEMKO WEA THERSTRIP 303A V-3070	
INTERIOR (6) 36"X80" MOHA WK SOLID CORE DOORS 2R2L W/ 5X20 PENCL WINDOW	
(2) 24"X80" RIMCHA WK SOLID CORE DOOR	
(6) 3680 REDIFRAMES 478 BROWN 20GA	
(2) 2468 REDIFRAME 478 BROWN 20GA	
INTERIOR HARDWARE: LEVER HANDLES	
(2) HEAVY DUTY PRIVACY ND40S X RHODES x 26D (SCHLAGE) RESTROOM	
(6) HEAVY DUTY ENTRY ND53BD X RHODES x 26D (SCHLAGE) OFFICES	
W/IC CONSTRUCTION CORE	

ROOF:	
RAFTER: 2X8 #2SYP 16" O.C.	RM: SINGLE 2X8 #2SYP
SHEATHING: 7/16" FR DECK	5/8" FIRE X SHEETROCK
BOTTOM RAFTER SHEATHING: .045 EPDM	COLOR: BLACK
COVERING: .25/12 TRANSVERSE	ROOF PITCH: 8-8" HEIGHT, 2X4 ARMSTRONG RADAR
CEILING: R-19 FACED	INSULATION: AREA ABOVE CEILING GRID TO BE A PLENUM RETURN
PLENUM: VENTS: N/A	

ELECTRICAL:	
SERVICE: 120/230V SINGLE PHASE	
LOAD CENTER: (2) 200 AMP, INT MOUNT LOA D CNT.	
ENTRANCE: WITH SURGE SUPPRESSION BY INTERMATIC	
WIRING: 2 1/2" NIPPLE DOWN- PVC STUB FOR FEEDERS	
LIGHTS: MC CABLE W/#12 (#6 AT HVAC)	
(22) 48" T-8 4 TUBE FLOURESCENT TROFFERS,	
(2) LUMARK PHOTO CELL EXTERIOR LIGHT	
(2) 24" T-8U TUBE FLOURESCENT TROFFER IN RESTROOM	
FANS: (2) 90 CFM EXHAUST IN BATHROOM VENT THRU ROOF NUTONE 671R	
SURGE PROTECT: (2) INTERMATIC WIRED INTO SERVICE PANEL.	
EXT/EMERG. LIGHT: (2) EXT/EMERGENCY LIGHT BATTERY BACK UP.	
RECEIPTS: (10) STD. 120V DUPLEX RECP (10) SURGE BLOCK DUPLEX RECT.	
(6) GFCI 120V STD DUPLEX RECEPTACLES	
(2) W.P. EXT. GFCI 120V RECEPTACLE	
(2) DEDICATED 120V STD. RECEPTACLE (TELECOM RM)	
SWITCHES: (8) OCCUPANCY SENSORS (INFRARED ULTRASONIC)	
J-BOXES: ALL PLATES TO BE IVORY	
ALARM: N/A	
MSC: GROUNDING ON SITE TO BE PER NEC 2002, 250-96	

PLUMBING:	
WATER SUPPLY: TYPE "L" COPPER	
WASTE: PVC SCHEDULE 40	
WATER HEATER: (2) BAXX SP5 SUPPLY TO BOTH SINKS	
WATER CLOSET: (2) HANDCAP FLUSH VALVE ELONGATED L/HANDLE	
LAVATORY: (2) WALL HUNG, COVER UNDERNEATH HANDLES	
BAR SINK: (2) STAINLESS STEEL COUNTER LAV, DUAL LEVER FAUCET.	
NOTE: ALL FIXTURE MOUNTING PER TAG 1994	

HVAC:	
HVAC: (2) 3 1/2 TON WITH 10KW HEAT STRIP W/ DISCONNECTS AND ECONOMIZER	
BARD COLOR: TAN	
THERMOSTAT: (2) PROGRAMABLE	
DUCTS: MAWVILLE DUCT BOARD, FLEX TO GRILLS	
SUPPLY REGISTERS: 24X24 W/ ADJUSTABLE DIFFUSERS	
RETURN REGISTERS: 24X24, ABOVE CEILING PLENUM WITH PLENUM WALL CUT OUTS	
MSC: FRESH AIR MAKEUP IS PROVIDED THRU MANUAL DAMPER IN HVAC	

FURNITURE OR MISC EACH UNIT:	
24" BASE CABINET, WITH ADA TOE KICK AND THREE DRAWERS.	
24" AND 42" WALL HUNG CABINETS W/SHelves	
66" OF COUNTER TOP	
24"X48" MIRROR AT BATHROOMS	

NOTE: ALL SIGNAGE BY OTHERS.

TELECOM EACH UNIT:	
WIRE: TELEPHONE CAT 6 PLENUM	COLOR: WHITE
LAN: CAT 6 PLENUM	COLOR: BLUE
JACKS: TELEPHONE	LAN: CAT6
J-BOXES: WIRED FOR (1) DATA, (1) VOICE	
VOICE DATA HOUSING: 28" WITH LOCKING COVER	
MODULES: 24 PORT COMBINATION	
8 PORT	
4 PORT ROUTER	
CONNECTION: CONNECT A CLOSET TO B CLOSET	
PUNCH DOWN: DATA TO BE PUNCHED AS T-568A	
DEMARCA: MOUNTED AT HITCH END, WIRED TO CLOSET.	
CAT6, CAT6 AND RJ45 RUNS TO CLOSET	
PLATES: IVORY 4-PORT, (2) COVERED	

TRANSPORTATION:		
7/16	ROOF DECK	0.0416667
2X8	ROOF RAFTER	0.6041667
5/8 GYP	UNDERSIDE RAFTER	0.0520833
10'-8"	TALLEST WALL	10.666667
1/4"	FLOOR COVER	0.020833
3/4"	FLOOR DECK	0.0625
2X8	FLOOR JOIST	0.6041667
2'-8"	TO ROAD APPROX	2.625
TOTAL		14.67083 FT
WEIGHT APPROX.		49500 LBS
EACH UNIT		24750 LBS

NOTE: ALL NAILING PATTERNS SHOWN ON SF PAGES SHALL OVERRIDE DESIGN MANUAL.

DRAWING INDEX:	
G-001	= COVER
A-101	= FLOOR PLAN
A-201	= EXTERIOR ELEVATIONS
A-202	= EXTERIOR ELEVATIONS
A-203	= INTERIOR ELEVATIONS
A-301	= SECTIONS
A-601	= ADA (TAS)
E-101	= ELECTRICAL PLAN
M-101	= MECHANICAL (HVAC) PLAN
P-101	= PLUMBING PLAN
P-601	= NOT USED
SF-101	= FLOOR FRAMING PLAN
SF-102	= FLOOR DECKING/WALL LAYOUT PLAN
SF-103	= ROOF FRAMING PLAN
SF-201	= WALL FRAMING PLAN
SF-202	= WALL FRAMING PLAN
SF-203	= WALL FRAMING PLAN
S-101	= FOUNDATION PLAN
S-102	= NOT USED
S-501	= NOT USED
T-101	= TELECOM PLAN

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611


NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704



AREA SCHEDULE FOR EACH UNIT ROOMS							
DESIGNATION	DESCRIPTION	FLOOR AREA	CUBIC AREA	FLOOR	WALL	CEILING	BASE
100-A,B	OFFICE	121	1051	CARPET	$\frac{5}{8}$ " VINYL COVERED GYPSUM TYPE X	2'X4' LAY IN	4" RUBBER BASE
101-A,B	BATHROOM	42	364	TILE	FRP OVER $\frac{5}{8}$ " GYPSUM TYPE X	2'X4' LAY IN	4" RUBBER BASE
102-A,B	WORK AREAS AND SINK AREA	449	3891	TILE	$\frac{5}{8}$ " VINYL COVERED GYPSUM TYPE X	2'X4' LAY IN	4" RUBBER BASE
103-A,B	OFFICE	121	1051	CARPET	$\frac{5}{8}$ " VINYL COVERED GYPSUM TYPE X	2'X4' LAY IN	4" RUBBER BASE
104-A,B	TELECOM	5	43	TILE	$\frac{5}{8}$ " VINYL COVERED GYPSUM TYPE X	2'X4' LAY IN	4" RUBBER BASE

WINDOW SCHEDULE				
DESIGNATION	DESCRIPTION	RD	QTY	
W1	2044 ALUMINUM BRONZE FRAME, DOUBLE INSULATED LOW E GLASS W/ ALUMINUM MINI BLINDS	24½" X 52½"	9	

DOOR SCHEDULE					
DESIGNATION	SIZE	DOOR MATERIAL	FRAME	RD	QTY
D1,D6	D1:3068L,D2:3068R	STEEL W/ PENCIL VISION	STEEL	40½" X 82½"	2
D2	3068L	MOHAWK SOLID CORE W/ VISION GLASS	REDIFRAME	37" X 81"	2
D3	3068R	MOHAWK SOLID CORE W/ VISION GLASS	REDIFRAME	37" X 81"	2
D4	3068L	MOHAWK SOLID CORE	REDIFRAME	37" X 81"	2
D5	2068R	MOHAWK SOLID CORE	REDIFRAME	25" X 81"	2




FLOOR PLAN

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:
				REW	NORTEX MODULAR SPACE	STOCK 2860 FLOOR PLAN-"J" SERIES
				DATE: 05/21/07	SCALE: 3/16" = 1'-0"	DWG# 2860STK SHEET: A-101




JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611

NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704



BACK ELEVATION



FRONT ELEVATION


HITCH END ELEVATION

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 ELEVATIONS-"J" SERIES	A-201
			DATE:	05/21/07	SCALE:	DWG#	
					3/16" = 1'-0"	2860STK	




NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



BACK END ELEVATION




HITCH END ELEVATION

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
		REW	4/13/07	REW	NORTEx MODULAR SPACE	STOCK 2860 ELEVATIONS-"J" SERIES	A-202
				DATE: 05/21/07	SCALE: 3/16" = 1'-0"	DWG# 2860STK	


JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



NORTEx MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704




CABINET WALL ELEVATION
SCALE: $\frac{1}{4}" = 1'-0"$

LTR				DRAWN BY:	PROJECT:		TITLE:
	REVISION	BY	DATE	REW	NORTEX MODULAR SPACE		STOCK 2860 ELEVATIONS-"J" SERIES
				DATE:	SCALE:	DWG#	SHEET:
				05/21/07	AS NOTED	2860STK	A-202
							
NORTEX MODULAR SPACE							
555 JUBILEE LANE LEWISVILLE, TX 75056 PHONE: 972-492-4040 FAX: 972-492-2704							



NORTEx MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704



SECTION VIEW





LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 SECTION-"J" SERIES	
				DATE:	SCALE:	DWG#	A-301
				05/22/07	3/8" = 1'-0"	2860STK	

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

ADA DETAILS



LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 ADA-"J" SERIES	
				DATE: 05/23/07	SCALE: N/A	DWG# 2860STK	A-601



NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611

TYPICAL PANEL LABELING, BREAKER
AND WIRE SIZES

EO	ELECTRICAL DUPLEX OUTLET	AMPS EA.	ITEM	WATTS EA
SBO	SURGE BLOC DUPLEX OUTLET	1.5	RECEPTS	180
SS	MAIN SURGE SUPPRESSION	1.2	LIGHTS 2'X4' 4-TUBE T-8	144
DO	DEDICATED OUTLET QUAD	0.8	90 CFM EXHAUST FAN	96
HVAC	HEATING AND AIR UNIT	0.6	LIGHT 2'X2' 2-TUBE T-8	72
LF	LIGHT FIXTURE	0.0333333	EMERGENCY/EXIT	4
GF	GROUND FAULT INTERRUPT OUTLET	1	PORCH LIGHT	120
EF	EXHAUST FAN	22.9	EeMAX	2748
WP	WEATHER PROOF			0
PL	PORCH LIGHT			0
SP	SERVICE PANEL			0
\$	OCCUPANCY SENSOR SWITCH			0
EeMAX	INSTANT WATER HEATER			0
EX/EML	EXIT/EMERGENCY LIGHT			0


MIN WIRE SIZE	150 AMP 2-POLE 120V/230V SINGLE PHASE MAIN BREAKER				MIN WIRE SIZE
	FA"	EB"	BREAKER		
10	EeMAX	30	2P	1	6
12	RECEPTS	20	5	4	12
12	RECEPTS	20	7	8	12
12	DEDICATED QUAD OUTLET	20	9	10	12
12	EXHAUST FAN AND LIGHTS	0	13	12	12
12		0	15	14	NOT USED
12		0	17	16	NOT USED
12		0	19	18	NOT USED
12		0	21	20	NOT USED
12		0	23	22	NOT USED
		0	23	24	NOT USED

PANEL SP-1 MAIN BREAKER		150 AMP 2-POLE	115V/230V	SINGLE PHASE LOAD CALCULATIONS
LEG	CKT	DESCRIPTION	LEG A-AMPS	LEG B-AMPS
A	1 EeMAX	30.00	3,450.00	
A	2 HVAC	60.00	6,900.00	
B	3 EeMAX	30.00	3,450.00	
B	4 HVAC	60.00	6,900.00	
A	5 RECEPTS	9.00	1,035.00	
A	6 LIGHTS	6.30	724.50	
B	7 RECEPTS	9.00	1,035.00	
B	8 GFI'S	3.00	345.00	
A	9 DEDICATED	3.00	345.00	
A	10 EMERGENCY/EXIT	1.80	207.00	
B	11 EXHAUST	1.80	207.00	
	12 LIGHTS	1.80	207.00	
		110.10	12,661.50	12,615.50
		109.70	12,661.50	12,615.50

PANEL SP-2 MAIN BREAKER		150 AMP 2-POLE	115V/230V	SINGLE PHASE LOAD CALCULATIONS
LEG	CKT	DESCRIPTION	LEG A-AMPS	LEG B-AMPS
A	1 EeMAX	30.00	3,450.00	
A	2 HVAC	60.00	6,900.00	
B	3 EeMAX	30.00	3,450.00	
B	4 HVAC	60.00	6,900.00	
A	5 RECEPTS	9.00	1,035.00	
A	6 LIGHTS	6.30	724.50	
B	7 RECEPTS	9.00	1,035.00	
B	8 GFI'S	3.00	345.00	
A	9 DEDICATED	3.00	345.00	
A	10 EMERGENCY/EXIT	1.80	207.00	
B	11 EXHAUST	1.80	207.00	
	12 LIGHTS	1.80	207.00	
		110.10	12,661.50	12,615.50
		109.70	12,661.50	12,615.50

AMPS	110.10	TOTALS	25,277.00 WATTS
W/20%	132.12	DIFF B-A	31,596.25 W/25%
150AMP	OK	+/- 20%	0.15% OK

AMPS	110.10	TOTALS	25,277.00 WATTS
W/20%	132.12	DIFF B-A	31,596.25 W/25%
150AMP	OK	+/- 20%	0.15% OK



ELECTRICAL PLAN

- NOTES:
1. MOUNT ALL OUTLET BOXES TO 16" AFF TO TOP OF BOX.
 2. COUNTER TOP OUTLET TO BE 42" AFF TO BOTTOM OF BOX.
 3. BATHROOM OUTLET TO BE 42" AFF TO BOTTOM OF BOX.

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611

NORTHEX MODULAR SPACE



555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTHEX MODULAR SPACE	STOCK 2860 ELECTRICAL PLAN-"J" SERIES	
				DATE:	SCALE:	DWG#	
				05/24/07	3/16" = 1'-0"	2860STK	E-101

W:\STOCK DESIGNS\STOCK\2860A\B128X60A\B.dwg, E-101, 5/29/2007 11:01:45 AM

MECHANICAL SCHEDULE	
DESIGN ACTION	COMMENTS
SA1	2X2 SUPPLY AIR REGISTER ADJUSTABLE
SA2	12X12 SUPPLY GRILL NONE
RA1	2X2 RETURN AIR REGISTER NONE
T	THERMOSTAT PROGRAMMABLE W/RECONDIMIZER
3 1/2 TON W/10KW	90 CFM EXHAUST FAN THRU ROOF
EX1	

SEE HEATLOSS
CALCULATIONS AND
COMCHECK RESULTS FOR
CODE COMPLIANCE
INFORMATION.




- NOTES:
1. PLENUM CAVITY ABOVE LAY IN CEILING.
 2. PLENUM WALL TO HAVE OPENINGS CUT AND GYPED TO ACHIEVE 30X16 AREA.
 3. OFFICE WALLS AND 2X6 WALL TO HAVE OPENING FOR DUCT TO PASS THRU FABRICATED INTO FRAMING.
 4. FLEX DUCTS NOT TO BE CUT INTO MAIN DUCT LESS THAN 12" FROM A TRANSITION.

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 MECHANICAL PLAN-"J" SERIES	M-101
				DATE:	SCALE:	DWG#	
				05/21/07	3/16" = 1'-0"	2860STK	



NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



2X8 #2SYP X13'-3" @16" O.C. TYP.


FLOOR JOIST PLAN

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 FLOOR JOIST PLAN-"J" SERIES	
				DATE:	SCALE:	DWG#	SHEET:
				05/21/07	3/16" = 1'-0"	2860STK	SF-101



NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611




2X8 #2SYP RIM


2X8 #2SYP JOIST 16" O.C.

ROOF JOIST PLAN

- NOTES:
1. FILL CAVITY WITH R22.
 2. BOTTOM OF JOIST TO BE 8"GYPSUM.
 3. ROOF DECK TO BE FR 1 7/8" DECK PANEL.
 4. ROOF DECK NAILING TO BE 4"OC EDGE & 8"OC IN FIELD WITH 2 1/4" SCREWS.
 5. ROOF IS BUILT IN 30' HALFS.



1460A-J



1460B-J


LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 1460 ROOF JOIST PLAN-"J" SERIES	
				DATE:	SCALE:	DWG#	SHEET:
				02/19/07	3/16" = 1'-0"	1460STK	SF-103




NORTEX MODULAR SPACE

555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



2 SIDEWALL




1 SIDEWALL

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
1				REW	NORTEX MODULAR SPACE	STOCK 1460 WALL FRAMING-"J" SERIES	SF-201
				DATE:	SCALE:	DWG#	
				02/19/07	3/16" = 1'-0"	1460STK	




NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704


JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611




1 HITCH END WALL




2 PLENUM WALL




3 OFFICE WALL




4 OFFICE WALL




5 WET WALL




6 BATHROOM ENTRY WALL



7 CLOSET SIDE WALL



8 CLOSET




9 END WALL

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 WALL FRAMING-"J" SERIES	SF-202
				DATE: 05/23/07	SCALE: 3/16" = 1'-0"	DWG# 2860STK	




NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



2 SIDEWALL





1 SIDEWALL

NOTES:
ALL WINDOWS AND DOOR OPENINGS TO HAVE DOUBLE STUDS AT EXTERIOR WALLS.
ALL HEADERS ARE (2X)2X6'S.
ALL WALLS EXCEPT HITCH END REQUIRE BLOCKING AT 8'-8" ELEV.
SMART PANEL SIDING TO BE INSTALLED FROM MID-FLOOR JOIST TO TOP OF ROOF LINE.
ALL STUDS OVER 119.67' SHALL BE DOUBLED.

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:	SHEET:
				REW	NORTEX MODULAR SPACE	STOCK 2860 WALL FRAMING-"J" SERIES	SF-203
				DATE:	SCALE:	DWG#	
				05/24/07	3/16" = 1'-0"	2860STK	
				NORTEX MODULAR SPACE			
				555 JUBILEE LANE LEWISVILLE, TX 75056 PHONE: 972-492-4040 FAX: 972-492-2704			

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611



146□A-J

146□B-J

NOTES:
1. SOIL ASSUMED AT 2000PSI
2. PAD SPACING SHOWN IS FOR 50PSF FLOOR LOADS.
SPACING OF PADS CHANGES TO 4.7' O.C. FOR 100PSF FLOOR LOADS.





FOUNDATION PLAN

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:
				REW	NORTEX MODULAR SPACE	STOCK 2860 FOUNDATION PLAN-"J" SERIES
				DATE:	SCALE:	DWG#
				05/23/07	3/16" = 1'-0"	2860STK
						SHEET: S-101




JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611

NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704



DATA CABLE TO BE CAT 6
UNSHIELDED, PLENUM
RATED. VOICE CABLE TO BE
CAT 5E UNSHIELDED
PLENUM RATED.
ALL PENETRATIONS IN
CEILING TO BE FIRE
CAULKED TO MAINTAIN
PLENUM INTERGERTY.
VOICE CABLE TO BE WHITE,
DATA CABLE TO BE BLUE.

TELECOM PLAN

LTR	REVISION	BY	DATE	DRAWN BY:	PROJECT:	TITLE:
1	ADDED SLEEVE FOR POWER, MOVE OUTLET	REW	04/25/07	REW	NORTEIX MODULAR SPACE	STOCK 2860 TELECOM PLAN-"J" SERIES
				DATE:	SCALE:	DWG#
				05/23/07	3/16" = 1'-0"	2860STK
						SHEET: T-101

JOE STEEDE, P.E.
13999 GOLDMARK, SUITE 374
DALLAS, TX 75250 PHONE 972-238-1611

NORTEX MODULAR SPACE
555 JUBILEE LANE
LEWISVILLE, TX 75056
PHONE: 972-492-4040
FAX: 972-492-2704

