
CAUTION! POWER TO THIS SERVICE IS ALSO SUPPLIED FROM THE FOLLOWING SOURCE WITH DISCONNECTS LOCATED AS SHOWN



LABEL LOCATION:

EACH SERVICE EQUIPMENT LOCATION AND AT THE LOCATION(S) OF THE SYSTEM DISCONNECT(S) FOR ALL ELECTRIC POWER PRODUCTION SOURCES CAPABLE OF BEING INTERCONNECTED (PER CODE: NEC 705.10)



SYSTEM INFO

(14) URECO FBM445M7G-BB

(14) ENPHASE IQ8PLUS -72-2-US (240V)

DC SYSTEM SIZE: 6.230 kWDC

AC SYSTEM SIZE: 4.060 kWAC

| REVISIONS | | |
|-------------|------|-----|
| DESCRIPTION | DATE | REV |
| | | |
| | | |
| | | |

PROJECT NAME & ADDRESS

3312 DELANA WAY, ALVA, FL 33920, USA EMAIL ID: AVA.MORALESCARDENEZ@VA.GOV PHONE NO. (615) 717-8056 AVA MORALES RESIDENCE

DATE: 8/20/2024

SHEET NAME

SIGNAGE

SHEET SIZE

ANSI B 11" X 17"

SHEET NUMBER

PV-10