

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Numbers 19166 and PSD-TX-760M6

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

### AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	<u>Emission Rates *</u>	
Point No. (1)	Name (2)	Name (3)	lb/hr (4)	TPY(5)
**				
—				
Turbines, Case I: Turbines Only - No Duct Burner Firing				
7A	88 MW (ISO) Gas Turbine GE Model PG7111 (EA)	NO <sub>x</sub>	102.00	385.44
		CO	58.00	223.38
		VOC	0.90	3.94
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub>	0.73	3.20
7B	88 MW (ISO) Gas Turbine GE Model PG7111 (EA)	NO <sub>x</sub>	102.00	385.44
		CO	58.00	223.38
		VOC	0.90	3.94
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub>	0.73	3.20
7C	88 MW (ISO) Gas Turbine GE Model PG7111 (EA)	NO <sub>x</sub>	102.00	385.44
		CO	58.00	223.38
		VOC	0.90	3.94
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub>	0.73	3.20
7D	88 MW (ISO) Gas Turbine GE Model PG7111 (EA)	NO <sub>x</sub>	115.00	455.52
		CO	57.00	227.76
		VOC	0.90	3.94
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub>	0.73	3.20

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

## AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr (4)	TPY(5)**
7E	88 MW (ISO) Gas Turbine GE Model PG7111 (EA)	NO <sub>x</sub>	115.00	455.52
		CO	57.00	227.76
		VOC	0.90	3.94
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub>	0.73	3.20
7G	No. 6 Cogen without Duct Burners	NO <sub>x</sub>	38.00	166.44
		CO	62.00	271.56
		VOC 0.55	2.41	
		PM and PM <sub>10</sub>	5.00	21.90
		SO <sub>2</sub> 0.62	2.69	
Turbines, Case II: Turbines with Duct Burners Firing				
7A	88 MW (ISO) Gas Turbine GE Model PG7111 (EA) with 141.8 MMBtu/hr Duct Burner Firing Hydrogen, Natural Gas or Process Gas	NO <sub>x</sub>	119.02	460.00
		CO	60.13	232.71
		VOC	1.75	7.66
		PM and PM <sub>10</sub>	5.71	25.01
		SO <sub>2</sub>	0.83	3.64
7B	88 MW (ISO) Gas Turbine GE Model PG7111 (EA) with 141.8 MMBtu/hr Duct Burner Firing Hydrogen, Natural Gas or Process Gas	NO <sub>x</sub>	119.02	460.00
		CO	60.13	232.71
		VOC	1.75	7.66
		PM and PM <sub>10</sub>	5.71	25.01
		SO <sub>2</sub>	0.83	3.64
7C	88 MW (ISO) Gas Turbine GE Model PG7111 (EA) with 141.8 MMBtu/hr Duct Burner Firing Hydrogen, Natural Gas or Process Gas	NO <sub>x</sub>	119.02	460.00
		CO	60.13	232.71
		VOC	1.75	7.66
		PM and PM <sub>10</sub>	5.71	25.01
		SO <sub>2</sub>	0.83	3.64
7D	88 MW (ISO) Gas Turbine	NO <sub>x</sub>	132.02	530.07

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

## AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			lb/hr (4)	TPY(5)**
	GE Model PG7111 (EA) with 141.8 MMBtu/hr Duct Burner Firing Hydrogen, Natural Gas or Process Gas	CO VOC PM and PM <sub>10</sub> SO <sub>2</sub>	59.13 1.75 5.71 0.83	237.09 7.66 25.01 3.64
7E	88 MW (ISO) Gas Turbine GE Model PG7111 (EA) with 141.8 MMBtu/hr Duct Burner Firing Hydrogen, Natural Gas or Process Gas	NO <sub>x</sub> CO VOC PM and PM <sub>10</sub> SO <sub>2</sub>	132.02 59.13 1.75 5.71 0.83	530.07 237.09 7.66 25.01 3.64
7F	Package Boiler	NO <sub>x</sub> CO VOC PM and PM <sub>10</sub> SO <sub>2</sub>	12.50 25.00 0.34 1.25 0.10	54.75 109.50 1.51 5.48 0.43
CWTP1	Combined Wastewater Treatment Plant	VOC	6.25	27.3
TTW-15A	Diesel Storage Tank	VOC	0.06	0.01
TTW-15B	Diesel Storage Tank	VOC	0.06	0.01
TTW-15C	Diesel Storage Tank	VOC	0.06	0.01
TTW-15D	Diesel Storage Tank	VOC	0.06	0.01
TTW-15E	Diesel Storage Tank	VOC	0.06	0.01
UT-F02A	Diesel Storage Tank	VOC	0.06	0.01
UT-F02B	Diesel Storage Tank	VOC	0.06	0.01
UT-F02C	Diesel Storage Tank	VOC	0.06	0.01
FPM-02A	Diesel Firewater Pump	NO <sub>x</sub>	8.36	0.11

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

## AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			lb/hr (4)	TPY(5)**
		CO	3.19	0.04
		VOC	0.18	0.01
		PM	0.66	0.01
		SO <sub>2</sub>	2.06	0.03
FPM-02B	Diesel Firewater Pump	NO <sub>x</sub>	8.36	0.11
		CO	3.19	0.04
		VOC	0.18	0.01
		PM	0.66	0.01
		SO <sub>2</sub>	2.06	0.03
FPM-02C	Diesel Firewater Pump	NO <sub>x</sub>	8.36	0.11
		CO	3.19	0.04
		VOC	0.18	0.01
		PM	0.66	0.01
		SO <sub>2</sub>	2.06	0.03
FPM-02D	Diesel Firewater Pump	NO <sub>x</sub>	8.36	0.11
		CO	3.19	0.04
		VOC	0.18	0.01
		PM	0.66	0.01
		SO <sub>2</sub>	2.06	0.03
FPM-02E	Diesel Firewater Pump	NO <sub>x</sub>	8.36	0.11
		CO	3.19	0.04
		VOC	0.18	0.01
		PM	0.66	0.01
		SO <sub>2</sub>	2.06	0.03
UP-F02A	Diesel Firewater Pump	NO <sub>x</sub>	8.68	0.11
		CO	1.87	0.02
		VOC	0.69	0.01
		PM	0.62	0.01
		SO <sub>2</sub>	1.42	0.02

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

## AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			lb/hr (4)	TPY(5)**
UP-F02B	Diesel Firewater Pump	NO <sub>x</sub>	8.68	0.11
		CO	1.87	0.02
		VOC	0.69	0.01
		PM	0.62	0.01
		SO <sub>2</sub>	1.42	0.02
UP-F02C	Diesel Firewater Pump	NO <sub>x</sub>	8.68	0.11
		CO	1.87	0.02
		VOC	0.69	0.01
		PM	0.62	0.01
		SO <sub>2</sub>	1.42	0.02
XZ-OS01	Waste Oil Storage Tank	VOC	0.01	0.01
XZ-WS01	Oil-Water Separation System	VOC	0.11	0.25
PCDIESELFUG	PC Plant Fire Water System Fugitives	VOC	0.04	0.16
EXPDIESELFUG	Expansion Plant Fire Water System Fugitives	VOC	0.06	0.27

(1) Emission point identification - either specific equipment designation or emission point number from a plot plan.

(2) Specific point source names.

(3) NO<sub>x</sub> - total oxides of nitrogen

CO - carbon monoxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

PM - particulate matter, suspended in the atmosphere, including PM<sub>10</sub>

PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted.

SO<sub>2</sub> - sulfur dioxide

- (4) Maximum hourly emissions based on an ambient temperature of 20°F for Emission Point No. (EPN) 7A through 7C and 30°F for EPN 7D through 7E.
- (5) Annual emissions based on 70°F ambient temperature for EPN 7A through 7E.

\* Emission rates are based on continuous operation (8,760 hours/year) except for the diesel firewater pumps, which are based on operating for 26 hours/year each.

\*\* Compliance with annual emission limits is based on a rolling 12-month period.

Dated\_\_\_\_\_