

Emission Sources - Maximum Allowable Emission Rates

Permit Number 44652

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
BL-CHP4	Boiler 4 67.7 MMBtu/hr	NO _x	2.38	10.38
		CO	2.42	10.67
		VOC	0.30	1.31
		PM ₁₀	0.47	2.08
		SO ₂	0.04	0.18
BL-CHP5	Boiler 5 67.7 MMBtu/hr	NO _x	2.38	10.38
		CO	2.42	10.67
		VOC	0.30	1.30
		PM ₁₀	0.47	2.08
		SO ₂	0.04	0.18
BL-CHP4 & BL-CHP5	Combined Annual Emission Limitation (5)	NO _x	-	11.42
		CO	-	11.64
		VOC	-	1.45
		PM ₁₀	-	2.28
		SO ₂	-	0.20

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

SO₂ - sulfur dioxide

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

CO - carbon monoxide

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

(5) Combined annual emission rate is based upon a fuel usage limitation of 652,375 MMBtu/yr for both boilers.

Emission Sources - Maximum Allowable Emission Rates

Date: _____