

# EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 40782

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

## AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY
T2001	1 <sup>st</sup> Step Aeration Tank 1	VOC	2.41	7.62
T2002	1 <sup>st</sup> Step Aeration Tank 2	VOC	2.41	7.62
T2003	1 <sup>st</sup> Step Aeration Tank 3	VOC	2.41	7.62
TK4101	2 <sup>nd</sup> Step Aeration Tank 1	VOC	0.21	0.65
TK4102	2 <sup>nd</sup> Step Aeration Tank 2	VOC	0.21	0.65
TK4103	2 <sup>nd</sup> Step Aeration Tank 3	VOC	0.21	0.65
TK4104	2 <sup>nd</sup> Step Aeration Tank 4	VOC	0.21	0.65
TK4105	2 <sup>nd</sup> Step Aeration Tank 5	VOC	0.21	0.65
TK4106	2 <sup>nd</sup> Step Aeration Tank 6	VOC	0.21	0.65
TK4107	2 <sup>nd</sup> Step Aeration Tank 7	VOC	0.21	0.65
CLRIFIER1	Clarifier 1	VOC	<0.01	<0.01
CLRIFIER2	Clarifier 2	VOC	<0.01	<0.01
CLRIFIER3	Clarifier 3	VOC	<0.01	<0.01
CLRIFIER4	Clarifier 4	VOC	0.09	0.28
CLRIFIER5	Clarifier 5	VOC	0.09	0.28
CLRIFIER6	Clarifier 6	VOC	0.10	0.31

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY
CLRIFIER7	Clarifier 7	VOC	0.10	0.31
CHLORINESP	Chlorine Sump	VOC	<0.01	0.01
CHLORINETK	Chlorine Tank	VOC	0.04	0.12
CHLORINETK	Chlorine Tank	Hypochlorite	0.04	0.18
		Chlorine	<0.01	<0.01
POLYMERR	Raw Polymer Tank	VOC	<0.01	<0.01
POLYMERD	Dilute Polymer Tank	VOC	<0.01	<0.01
BLCHTK1	Bleach Tank 1	Hypochlorite	0.03	0.11
		Chlorine	<0.01	<0.01
BLCHTK2	Bleach Tank 2	Hypochlorite	0.03	0.11
		Chlorine	<0.01	<0.01
NH4OHTK	Ammonium Hydroxide Tank	Ammonia	0.09	0.39
H2PO4TK	Phosphoric Acid Tank	Phosphoric Acid	<0.01	<0.01
SPLITRBX	Splitter Box	VOC	<0.01	<0.01
CHANNEL	Clean Stream	VOC	<0.03	0.13
POND3	Pond No. 3	VOC	0.03	0.12
POND6	Pond No. 6	VOC	0.03	0.11
POND7	Pond No. 7	VOC	1.17	3.63
POND9	Pond No. 9	VOC	0.68	2.08
COOLTWER	Cooling Tower	VOC	0.05	0.24
		PM	0.02	0.09
BPBASN601	B-Plant Basin No. 601	VOC	<0.01	<0.01

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

### AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY
BPBASN602	B-Plant Basin No. 602	VOC	<0.01	<0.01
BPBASN603	B-Plant Basin No. 603	VOC	<0.01	<0.01
BPBASN604	B-Plant Basin No. 604	VOC	<0.01	<0.01
BPBASN605	B-Plant Basin No. 605	VOC	<0.01	<0.01
BPBASN606	B-Plant Basin No. 606	VOC	<0.01	<0.01
BPBASN607	B-Plant Basin No. 607	VOC	<0.01	<0.01
BPBASN608	B-Plant Basin No. 608	VOC	<0.01	<0.01
STLTNK	Steel Tank	VOC	<0.01	<0.01
A-PLANT	A-Plant	VOC	<0.01	<0.01
BPRESS810	Belt Press No. 810	VOC	<0.01	<0.01
BPRESS820	Belt Press No. 820	VOC	<0.01	<0.01

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan  
 (2) Specific point source name. For fugitive sources use area name or fugitive source name.  
 (3) VOC - volatile organic compounds as defined in 30 Texas Administrative Code Section 101.1  
 PM - particulate matter

\* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

24 Hrs/day 7 Days/Week 52 Weeks/Year 8,760 Hrs/Year

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			<u>lb/hr</u>	<u>TPY</u>

Dated \_\_\_\_\_