Emission Sources - Maximum Allowable Emission Rates

Permit Number 2339A

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
263	Emergency Generator (500 kW)	СО	1.18	0.03
		NO _x	19.33	0.48
		PM	0.15	0.01
		PM ₁₀	0.15	0.01
		PM _{2.5}	0.15	0.01
		SO ₂	0.52	0.01
		VOC	0.08	0.01
354	Emergency Generator (750 kW)	СО	1.13	0.03
		NO _x	17.02	0.43
		PM	0.13	0.01
		PM ₁₀	0.13	0.01
		PM _{2.5}	0.13	0.01
		SO ₂	0.40	0.01
		VOC	0.15	0.01
EGEN-3	Emergency Generator (1,000 kW)	СО	9.02	0.23
		NO _x	41.85	1.05
		PM	2.97	0.07
		PM ₁₀	2.97	0.07
		PM _{2.5}	2.97	0.07
		SO ₂	2.77	0.07
		VOC	3.33	0.08
300	60" Hydrogen Stack	PM	0.03	0.03
		PM ₁₀	0.03	0.03
		PM _{2.5}	0.03	0.03

Project Number: 292966

Emission Sources - Maximum Allowable Emission Rates

301	10" Hydrogen Stack	PM	0.03	0.03
		PM ₁₀	0.03	0.03
		PM _{2.5}	0.03	0.03
302	Emergency Vent Scrubber	Cl ₂	<0.01	0.04
303	CVS After Scrubber	Cl ₂	1.55	0.37
304	Elephant Trunk Scrubber	Cl ₂	0.92	0.01
351	Asbestos HEPA Filter	PM (Asbestos)	<0.01	<0.01
		PM ₁₀ (Asbestos)	<0.01	<0.01
		PM _{2.5} (Asbestos)	<0.01	<0.01
356	East Drying Oven	PM (Asbestos)	<0.01	<0.01
		PM ₁₀ (Asbestos)	<0.01	<0.01
		PM _{2.5} (Asbestos)	<0.01	<0.01
		VOC (6)	0.54	0.05
357	West Drying Oven	PM (Asbestos)	<0.01	<0.01
		PM ₁₀ (Asbestos)	<0.01	<0.01
		PM _{2.5} (Asbestos)	<0.01	<0.01
		VOC (6)	0.54	0.05
OVENCAP	East and West Drying Ovens VOC CAP	VOC (6)	-	0.05
110	Chlorine Recovery Fugitives (5)	Cl ₂	0.16	0.68
120	Fugitives (5)	Cl ₂	0.22	0.94
130	Loading Area Fugitives (5)	Cl ₂	0.19	0.85
135	Chlorine Sniff Scrubber	Cl ₂	0.03	0.13
		HCI	0.02	0.09

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) Cl₂ - chlorine

- carbon monoxide CO - hydrogen chloride HCI - total oxides of nitrogen NO_x

PM- total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$ - particulate matter equal to or less than 10 microns in diameter, including PM_{2.5} PM_{10}

 $PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter

- sulfur dioxide SO₂

Project Number: 292966

Emission Sources - Maximum Allowable Emission Rates

	VOC	- volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
(4)	Compliance with	annual emission limits (tons per year) is based on a 12-month rolling period.

- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) The total combined annual emissions from EPNs 356 and 357 shall not exceed the emission rate listed for EPN OVENCAP (0.05 TPY).

Date: O	ctober 30, 2019
---------	-----------------

Project Number: 292966