

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 2153

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR

CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			<u>lb/hr</u>	<u>TPY</u>
Boiler-14	Boiler 14	NO _x	322.25	1411.46
		CO	23.44	102.67
		SO ₂	14.76	32.33
		PM	2.93	12.83
		VOC	1.00	4.38
Boiler-15	Boiler 15	NO _x	322.25	1411.46
		CO	23.44	102.67
		SO ₂	14.76	32.33
		PM	2.93	12.83
		VOC	1.00	4.38

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources use area name or fugitive source name.

(3) PM - particulate matter

VOC - volatile organic compounds as defined in General Rule 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

CO - carbon monoxide

* Emission rates are based on continuous operation (8,760 hours per year).

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Source Name (3)	Air Contaminant lb/hr	Air Contaminant TPY	<u>Emission Rates *</u>
---------------------------	--------------------	--------------------	--------------------------	------------------------	-------------------------

Dated_____