

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 6269

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY
1	Unit 1 Boiler Stack	NO _x	4090	17914
		CO	541	2370
		SO ₂	8180	35829
		VOC	25	46.9
		PM/PM ₁₀	682	2987
2	Fly Ash Handling System	PM/PM ₁₀	7.2	31.5

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) PM - particulate matter
 PM₁₀ - particulate matter less than 10 microns in diameter
 VOC - volatile organic compounds as defined in General Rule 101.1
 NO_x - total oxides of nitrogen
 SO₂ - sulfur dioxide
 CO - carbon monoxide
- (4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

24 Hrs/day 7 Days/week 52 Weeks/year or
8,760 Hrs/year

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Source Name (3)	Air Contaminant lb/hr TPY	<u>Emission Rates *</u>
---------------------------	--------------------	--------------------	---------------------------------	-------------------------

Dated _____