

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 5455

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY
SRB3A, SRB3B, SRB4A, and SRB4B	Unit 3 and 4 Stacks	PM ₁₀	---	21.6
SRB3A	Unit 3 - Stack A	PM ₁₀	25.0	---
SRB3B	Unit 3 - Stack B	PM ₁₀	25.0	---
SRB4A	Unit 4 - Stack A	PM ₁₀	25.0	---
SRB4B	Unit 4 - Stack B	PM ₁₀	25.0	---

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) PM₁₀ - particulate matter (PM) equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no PM greater than 10 microns is emitted.

* Emission rates are based on boiler-cleaning-wastewater injection into only Unit 3 or Unit 4 at any one time for a maximum combined total of 687 Hrs/year of injection at 25 gallons per minute.

Dated_____