

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 933

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr**	TPY***
S-1	Steam Generator Unit No. 1 (Coal-Fired Steam Generator)	CO	9,174	40,183
		NO _x	5,118	16,813
		PM 853	3,736	
		SO ₂ 10,236	44,834	
		VOC 473	207	
		Lead 2.2	1	
		HF 177	777	
		H ₂ SO ₄ 57	251	
S-2	Steam Generator Unit No. 2 (Coal-Fired Steam Generator)	CO	9,174	40,183
		NO _x	5,118	16,813
		PM 853	3,736	
		SO ₂ 10,236	44,834	
		VOC 473	207	
		Lead 2.2	1	
		HF 177	777	
		H ₂ SO ₄ 57	251	
S-3	Steam Generator Unit No. 3 (Coal-Fired Steam Generator)	CO	9,174	40,183
		NO _x	5,118	16,813
		PM 853	3,736	
		SO ₂ 10,236	44,834	
		VOC 473	207	
		Lead 2.2	1	
		HF 177	777	
		H ₂ SO ₄ 57	251	

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			lb/hr**	TPY***
S1 A and B	Auxiliary Boiler A (250 MMBtu/hr)	CO	90.6	
		NO _x	43.5	
		PM	3.6	
		SO ₂	142.2	
		VOC	3.6	
		Lead	0.01	
S1 A and B	Auxiliary Boiler B (250 MMBtu/hr)	CO	90.6	
		NO _x	43.5	
		PM	3.6	
		SO ₂	142.2	
		VOC	3.6	
		Lead	0.01	
LMA1F	Limestone System - Transfer from Railcar to A Side Receiving Hopper	PM	0.02	0.01
		PM ₁₀	0.01	0.01
LMA2F	Limestone System - Transfer from Receiving Hopper A to Conveyor C-30	PM	0.02	0.01
		PM ₁₀	0.01	0.01
LMA3F	Limestone System - Transfer from Conveyor C-30 to Conveyor C-4	PM	0.02	0.01
		PM ₁₀	0.01	0.01
LMA4F	Limestone System - Transfer from Conveyor C-30 to Pile	PM	0.05	0.03
		PM ₁₀	0.02	0.01
LMA5WF/	Limestone System - Limestone Storage	PM	0.29	1.28
LMA5MF	Pile A/Wind and Maintenance Fugitives	PM ₁₀	0.15	0.64
LMA6F	Limestone System - Underground Reclaim Transfer to Conveyor 2A	PM	0.01	0.01
		PM ₁₀	0.003	0.01

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			lb/hr**	TPY***
LMB1F	Limestone System - Transfer from Railcar B Side Receiving Hopper	PM PM ₁₀	0.02 0.01	0.01 0.01
LMB2F	Limestone System - Transfer from Receiving Hopper B to Conveyor C-1A	PM PM ₁₀	0.02 0.01	0.01 0.01
LMB3F	Limestone System - Tower No. 1 Transfers (C-1A and C-4) to Conveyor C-1B	PM PM ₁₀	0.02 0.01	0.01 0.01
LMB4F	Limestone System - Shuttle Conveyor C-1B to Conveyor C-1C	PM PM ₁₀	0.10 0.05	0.03 0.01
LMB5F	Limestone System - Conveyor C-1C Transfer to System B Storage Pile	 PM ₁₀	PM 0.24	0.50 0.13 0.06
LMB6F	Limestone System - Transfer from System B to Storage Pile to Conveyor C-2	PM PM ₁₀	0.08 0.04	0.13 0.06
LMB7F	Limestone System - Tower No. 2 Transfer from Conveyor C-2 to C-3	PM PM ₁₀	0.01 0.003	0.01 0.01
LMB8F	Limestone System - Conveyors C-3 and C-24 Transfers into Surge Bins	PM PM ₁₀	0.004 0.002	0.01 0.003
LMB9F	Limestone System - Transfer from Ball Mill Surge Silos to Conveyors A, B, C, and D	PM PM ₁₀	0.06 0.03	0.13 0.06

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr**	TPY***
LMB10F	Limestone System - Transfer from Conveyors A, B, C, and D into Ball Mills	PM PM ₁₀	0.06 0.03	0.13 0.06

- (1) Emission point identification - either specific equipment designation or emission point number from a plot plan.
- (2) Specific point source names. For fugitive sources, use an area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM - particulate matter, suspended in the atmosphere, including PM₁₀.
- PM₁₀ - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted.
- CO - carbon monoxide
- HF - hydrogen fluoride
- H₂SO₄ - sulfuric acid

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

_____Hrs/day ____Days/week ____Weeks/year or 8,760 Hrs/year

Fugitive emissions are an estimate only and should not be considered a maximum allowable emission rate.

** Compliance with NO_x, PM, PM₁₀, SO₂, VOC and lead hourly emission limits is determined on a three-hour average basis. Compliance with the CO hourly emission limit is determined on a 30-day average basis.

*** Compliance with all annual emission rates is based on a calendar year. Only for purposes of demonstrating compliance for EPN S1A and B, total combined actual annual emissions from EPNs S1A and B, S-1, S-2, and S-3 shall not exceed the total allowable annual emissions rates for EPNs S-1, S-2, and S-3.

Permit Number 933
Page 5

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			<u>lb/hr**</u>	<u>TPY***</u>

Dated September 3, 2004