#### AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	Emission I	Rates *
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY**

### EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

### Permit Numbers 41249 and PSD-TX-940

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

# AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	Emission	Rates *
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY **
STACK1	GT/Unfired HRSG	CO	86.17	338.68
		$NO_x$	63.4	252.91
		$PM_{10}$	18.0	78.84
		SO <sub>2</sub>	11.19	4.47
		VOC	2.8	10.75
STACK2	GT/Unfired HRSG	CO	86.17	338.68
		$NO_x$	63.4	252.91
		$PM_{10}$	18.0	78.84
		SO <sub>2</sub>	11.19	4.47
		VOC	2.8	10.75
STACK3	GT/Unfired HRSG	CO	86.17	338.68
		$NO_x$	63.4	252.91
		$PM_{10}$	18.0	78.84
		SO <sub>2</sub>	11.19	4.47
		VOC	2.8	10.75

# AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	Emission Rates *	
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY**
STACK4	GT/Unfired HRSG	$CO$ $NO_x$ $PM_{10}$ $SO_2$ $VOC$	86.17 63.4 18.0 11.19 2.8	338.68 252.91 78.84 4.47 10.75
STACK5	Auxiliary Boiler	$CO$ $NO_x$ $PM_{10}$ $SO_2$ $VOC$	4.48 3.90 0.48 0.04 0.35	0.95 0.82 0.10 0.01 0.07
CT-1	Cooling Tower (7)	$PM_{10}$	1.31	5.75
CT-2	Cooling Tower (7)	$PM_{10}$	1.31	5.75
TOMV1	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TOMV2	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TOMV3	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TOMV4	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TOMV5	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TOMV6	Turbine Oil Mist Vent Fugitives (4)	VOC	0.03	0.15
TANK1	Sodium Hypochlorite	NaOCI	<0.01	<0.01

# AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	Emission Rates *	
Point No. (1)	Name (2)	Name (3)	<u>lb/hr</u>	TPY**
	Storage Tank			
TANK2	Sodium Hypochlorite Storage Tank	NaOCI	<0.01	<0.01
TANK3	Sulfuric Acid Storage Tank	<0.01	H <sub>2</sub> SO <sub>4</sub>	<0.01
TANK5	Caustic Storage Tank	<0.01	NaOH	<0.01
TANK7	Diesel Fuel Storage Tank	VOC	0.09	<0.01
TANK8	Sulfuric Acid Storage Tank	<0.01	H <sub>2</sub> SO <sub>4</sub>	<0.01
TANK9	Sulfuric Acid Storage Tank	<0.01	H <sub>2</sub> SO <sub>4</sub>	<0.01
FUG-1	Natural Gas Pipeline Fugitive Emissions (6)	VOC	0.03	0.11
FUG-2	Natural Gas Pipeline Fugitive Emissions (6)	VOC	0.02	0.10
FUG-3	Natural Gas Pipeline Fugitive Emissions (6)	VOC	0.01	0.03
DFWP1	Diesel Firewater Pump (5	) $CO$ $NO_x$ $PM_{10}$ $SO_2$ $VOC$	3.13 10.48 0.20 0.74 0.13	0.16 0.55 0.01 0.04 0.01

#### AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	Emission I	Rates *
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY**

- (1) Emission point identification either specific equipment designation or emission point number (EPN).
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) VOC volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO<sub>X</sub> - total oxides of nitrogen

CO - carbon monoxide SO<sub>2</sub> - sulfur dioxide

PM - particulate matter, suspended in the atmosphere, including PM<sub>10</sub>

PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted.

 $H_2SO_4$  - sulfuric acid

NaOH - sodium hydroxide NaOCl - sodium hypochlorite Permit Nos. 41249 and PSD-TX-940 Page 5

# EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- (4) Turbine oil mist-vent emissions are estimates only based on mist-vent eliminator manufacturer data.
- (5) Emissions are based on non-emergency operation of 104 operating hours per year.
- (6) Fugitive emissions are an estimate based on component count and applicable fugitive emission factors.
- (7) Cooling tower PM<sub>10</sub> emissions are an estimate only based on manufacturers' data. Cooling tower assembly has 10 vent fan exhausts; emissions are sum-total of all 10 exhausts.
- \* Emission rates are based on an operating schedule of <u>8,760</u> hours/year.
- \*\* Compliance with the annual emission limits shall be based on a rolling 12-month year rather than the calendar year.

_				
	10	te	~	
	_			