

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Numbers 735B and PSDTX908

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY**
12-2-B20A	Boiler B-20A (213 MMBtu/hr)	CO	40.7	175.0
		NO _x	92.52	535
		PM ₁₀	1.59	6.95
		SO ₂	3.13	13.72
		VOC	1.15	5.04
12-2-B20C	Boiler B-20C (325 MMBtu/hr)	CO	36.4	159.2
		NO _x (4)	24.38	106.76
		PM ₁₀	4.0	17.5
		SO ₂	0.23	1.02
		VOC	1.76	7.69
15-2-1	Heat Recovery Steam Generator Stack (with Duct Burner Firing)	CO	106.83	313.96
		NO _x	117.11	238.82
		PM ₁₀	12.57	40.73
		SO ₂	0.83	3.04
		VOC	15.98	33.09
15-2-1	Heat Recovery Steam Generator Stack (without Duct Burner Firing)	CO	62.23	233.32
		NO _x	61.35	138.02
		PM ₁₀	7.0	30.66
		SO ₂	0.56	2.43
		VOC	2.04	7.88
UTILMSS	Utilities Solvent Usage (5)	VOC	0.21	0.22

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name.
- (3) CO - carbon monoxide - PSD regulated pollutant
NO_x - total oxides of nitrogen
PM₁₀ - particulate matter (PM) equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted.
SO₂ - sulfur dioxide
VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1.
- (4) Based on natural gas and up to 300,000 scf/hr hydrogen.
- (5) Planned maintenance, startup, and shutdown activities and emissions authorized from this emission point number.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day 24 Days/week 7 Weeks/year 52

** Compliance with annual emission limits is based on a rolling 12-month period.

Dated March 12, 2010