## Permit Number 83550

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

# AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates			
(1)			lbs/hour	TPY (4)		
The emission rates shown below are effective until the combined cycle electric generating unit authorized via Standard Permit No. 95640 becomes operational. Standard Permit No. 95640 authorizes modifications to be made to Combustion Turbine 2 in order to convert it to a combined cycle electric generating unit.						
HCCT1	Combustion Turbine 1 - General Electric (GE) 7EA, 73.1 MW (approx)	со	58.45			
		CO (5)	467.60			
		NOx	34.57			
		NO <sub>x</sub> (5)	96.04			
		VOC	9.35			
		VOC (5)	33.40			
		PM <sub>10</sub>	13.94			
		SO <sub>2</sub>	1.47			
		H <sub>2</sub> SO <sub>4</sub>	0.11			
HCCT2	Combustion Turbine 2 - General Electric (GE) 7EA, 73.1 MW (approx)	со	58.45			
		CO (5)	467.60			
		NOx	34.57			
		NO <sub>x</sub> (5)	96.04			
		voc	9.35			
		VOC (5)	33.40			
		PM <sub>10</sub>	13.94			
		SO <sub>2</sub>	1.47			
		H <sub>2</sub> SO <sub>4</sub>	0.11			

HCCT1/HCCT2	Combustion Turbine	СО		99.37
	1			
	and Combustion Turbine 2	NO <sub>X</sub>		45.23
		VOC		12.79
		PM <sub>10</sub>		15.86
		SO <sub>2</sub>		1.67
		H <sub>2</sub> SO <sub>4</sub>		0.13
LUBVNT1	Combustion Turbine	PM <sub>10</sub>	0.05	0.06
	Lube Vent	voc	0.05	0.06
LUBVNT2	Combustion Turbine 2 Lube Vent	PM <sub>10</sub>	0.05	0.06
		voc	0.05	0.06
HCHTR1	Fuel Gas Pre-heater	NO <sub>X</sub>	0.39	1.72
		со	0.33	1.45
		voc	0.02	0.10
		PM <sub>10</sub>	0.03	0.13
		SO <sub>2</sub>	<0.01	0.01
		H <sub>2</sub> SO <sub>4</sub>	<0.01	<0.01
HCHTR2	Fuel Gas Pre-heater 2	NO <sub>X</sub>	0.39	1.72
		СО	0.33	1.45
		voc	0.02	0.10
		PM <sub>10</sub>	0.03	0.13
		SO <sub>2</sub>	<0.01	0.01
		H <sub>2</sub> SO <sub>4</sub>	<0.01	<0.01

The emission rates shown below are effective after the combined cycle electric generating unit authorized via Standard Permit No. 95640 becomes operational. Combustion Turbine 2 will no longer be authorized in this permit.

HCCT1	Combustion Turbine	со	58.45	49.69
	- General Electric (GE) 7EA, 73.1	CO (5)	467.60	
	MW (approx)	NO <sub>X</sub>	34.57	22.62
	(αρριολ)	NO <sub>x</sub> (5)	96.04	
		voc	9.35	6.40
		VOC (5)	33.40	
		PM <sub>10</sub>	13.94	7.93
		SO <sub>2</sub>	1.47	0.84
		H <sub>2</sub> SO <sub>4</sub>	0.11	0.07
LUBVNT1	Combustion Turbine	PM <sub>10</sub>	0.05	0.06
	Lube Vent	voc	0.05	0.06
LUBVNT2	Combustion Turbine 2	PM <sub>10</sub>	0.05	0.06
	Lube Vent	voc	0.05	0.06
HCHTR1	Fuel Gas Pre-heater	NO <sub>X</sub>	0.39	1.72
		со	0.33	1.45
		voc	0.02	0.10
		PM <sub>10</sub>	0.03	0.13
		SO <sub>2</sub>	<0.01	0.01
		H <sub>2</sub> SO <sub>4</sub>	<0.01	<0.01
HCHTR2	Fuel Gas Pre-heater 2	NO <sub>X</sub>	0.39	1.72
		со	0.33	1.45
		VOC	0.02	0.10
		PM <sub>10</sub>	0.03	0.13
		SO <sub>2</sub>	<0.01	0.01
		H <sub>2</sub> SO <sub>4</sub>	<0.01	<0.01

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO<sub>x</sub> - total oxides of nitrogen

SO<sub>2</sub> - sulfur dioxide

PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter

CO - carbon monoxide  $H_2SO_4$  - sulfuric acid

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Start-up and shutdown emission rates.