

Emission Sources - Maximum Allowable Emission Rates

Permit Number 739

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

| Emission Point No. (1) | Source Name (2) | Air Contaminant Name (3) | Emission Rates (7) | |
|---------------------------|---|--------------------------|--------------------|---------|
| | | | lbs/hour | TPY (4) |
| RWM-B3 | Unit No. 3 Stack while Burning Natural Gas | NO _x | 444.72 | 1275.00 |
| | | CO | 183.12 | 525.00 |
| | | CO (5) | 839.10 | --- |
| | | CO (6) | 3500.00 | --- |
| | | VOC | 11.99 | 34.38 |
| | | SO ₂ | 1.40 | 3.75 |
| | | PM ₁₀ | 16.57 | 47.50 |
| RWM-B3 | Unit No. 3 Stack while Burning No. 2 Fuel Oil | NO _x | 323.70 | 120.00 |
| | | CO | 80.92 | 30.00 |
| | | VOC | 5.50 | 2.04 |
| | | SO ₂ | 728.32 | 270.00 |
| | | PM ₁₀ | 32.37 | 12.00 |

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
- CO - carbon monoxide
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Rapid Response Operating Scenario is limited to 450 hours per year (based on a 12 month rolling period).
- (6) Maximum Load Rapid Response Operating Scenario is limited to 40 hours per year (based on a 12 month rolling period).
- (7) Planned maintenance, startup, and shutdown emissions are included.

Date: August 24, 2015