Permit Number 107569

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name	Emission Rates	
		(3)	lb/hour	TPY (4)
DC-CTS5	Unit 5 Turbine Model Option 1:	NO _x (6)	74.98	40.79
	GE 7FA.05 (approximately 225 MW)	NO _x (Peak Firing) (6), (7)	120	
		NO _x (MSS) (6)	100	
		CO (6)	36.59	43.79
		CO (MSS) (6)	714	
		VOC	3.53	4.83
		VOC (MSS)	79.44	
		SO ₂	6.45	3.50
		РМ	10.29	5.83
		PM ₁₀	10.29	5.83
		PM _{2.5}	10.29	5.83
		H ₂ SO ₄	0.99	0.54
DC-CTS6	Unit 6 Turbine Model Option 1:	NO _x (6)	74.98	40.79
	GE 7FA.05 (approximately 225 MW)	NO _x (Peak Firing) (6), (7)	120	
		NO _x (MSS) (6)	100	
		CO (6)	36.59	43.79
		CO (MSS) (6)	714	
		VOC	3.53	4.83
		VOC (MSS)	79.44	
		SO ₂	6.45	3.50
		PM	10.29	5.83
		PM ₁₀	10.29	5.83
		PM _{2.5}	10.29	5.83
		H ₂ SO ₄	0.99	0.54

Project Number: 187007

DC-CTS5	Unit 5 Turbine Model Option 2:	NO _x (6)	82.24	42.13
	Siemens SGT6-5000F(5)/(5)ee	NO _x (Ramping) (6), (8)	120	
	(approximately 230 MW)	NO _x (MSS) (6)	100	
		CO (6)	28.73	72.90
		CO (Ramping) (6), (8)	815	
		CO (MSS) (6)	1,824	
		VOC	3.19	8.46
		VOC (MSS)	214	
		SO ₂	7.05	3.53
		РМ	11.08	5.80
		PM ₁₀	11.08	5.80
		PM _{2.5}	11.08	5.80
		H ₂ SO ₄	1.08	0.54
DC-CTS6	Unit 6 Turbine Model Option 2:	NO _x (6)	82.24	42.13
	Siemens SGT6-5000F(5)/(5)ee	NO _x (Ramping) (6), (8)	120	
	(approximately 230 MW)	NO _x (MSS) (6)	100	
		CO (6)	28.73	72.90
		CO (Ramping) (6), (8)	815	
		CO (MSS) (6)	1,824	
		VOC	3.19	8.46
		VOC (MSS)	214	
		SO ₂	7.05	3.53
		РМ	11.08	5.80
		PM ₁₀	11.08	5.80
		PM _{2.5}	11.08	5.80
		H ₂ SO ₄	1.08	0.54

DC-CT5LOV	Unit 5 Lube Oil Vent	VOC	< 0.01	0.01
		PM	< 0.01	0.01
		PM ₁₀	< 0.01	0.01
		PM _{2.5}	< 0.01	0.01
DC-CT6LOV	Unit 6 Lube Oil Vent	VOC	< 0.01	0.01
		PM	< 0.01	0.01
		PM ₁₀	< 0.01	0.01
		PM _{2.5}	< 0.01	0.01
DC-NGFUG	Units 5 and 6 Natural Gas Component Fugitives (5)	voc	0.01	0.03
DC-LOFUG	Units 5 and 6 Lube Oil Component Fugitives (5)	voc	0.50	2.18
DC-MSSFUG	Units 5 and 6 Planned Maintenance Activities Fugitives (5)	NO _x	< 0.01	< 0.01
		со	< 0.01	< 0.01
		VOC	0.08	< 0.01
		PM	< 0.01	< 0.01
		PM ₁₀	< 0.01	< 0.01
		PM _{2.5}	< 0.01	< 0.01

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 - NO_x total oxides of nitrogen
 - SO₂ sulfur dioxide
 - PM total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 - PM₁₀ total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
 - PM_{2.5} particulate matter equal to or less than 2.5 microns in diameter
 - CO carbon monoxide
 - H₂SO₄ sulfuric acid
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) For each pollutant whose emissions during planned MSS activities are measured using a CEMS, the MSS lb/hr limits apply only during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the lb/hr limits for normal operations, peak firing operations, and transitional load operations apply, as applicable, subject to the qualifying requirements in Special Condition Nos. 5 and 6.

Project Number: 187007

- (7) This hourly emission rate is authorized only during periods of peak firing operation of the GE model turbine, when turbine operation is above base load, subject to the qualifying requirements in Special Condition No. 5.
- (8) This hourly emission rate is authorized only during periods of transitional load operation of the Siemens model turbine, other than periods of planned MSS, when the turbine ramp rate is greater than 5 MW/minute, subject to the qualifying requirements in Special Condition No. 6.

Date:	August 29, 2013
-------	-----------------

Project Number: 187007