

Emission Sources - Maximum Allowable Emission Rates

Permit Number 36765

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
1	Loading Losses	VOC	33.28	27.84
		Benzene	0.30	0.25
2	Tank No. 1	VOC	1.23	1.16
		Benzene	0.01	0.01
3	Tank No. 2	VOC	2.10	1.97
		Benzene	0.02	0.02
4	Tank No. 3	VOC	1.18	1.04
		Benzene	0.01	0.01
5	Tank No. 4	VOC	2.05	1.83
		Benzene	0.02	0.02
6	Tank No. 5	VOC	2.02	1.80
		Benzene	0.02	0.02
7	Tank No. 6	VOC	1.90	1.62
		Benzene	0.02	0.01
8	Tank No. 7	VOC	1.14	0.92
		Benzene	0.01	0.01
9	Tank No. 8	VOC	1.12	0.91
		Benzene	0.01	0.01
10	Tank No. 9	VOC	1.17	0.95
		Benzene	0.01	0.01
11	Tank No. 10	VOC	1.18	0.85
		Benzene	0.01	0.01
12	Tank No. 11	VOC	1.18	0.85

Emission Sources - Maximum Allowable Emission Rates

		Benzene	0.01	0.01
13	Tank No. 12	VOC	1.29	0.94
		Benzene	0.01	0.01
14	Tank No. 13	VOC	1.32	0.96
		Benzene	0.01	0.01
15	Tank No. 14	VOC	1.21	0.79
		Benzene	0.01	0.01
16	Tank No. 15	VOC	1.18	0.76
		Benzene	0.01	0.01
17	Tank No. 16	VOC	1.50	0.69
		Benzene	0.01	0.01
18	Tank No. 17	VOC	1.50	0.69
		Benzene	0.01	0.01
19	Tank No.18	VOC	1.77	0.12
		Benzene	0.02	<0.01
25	Tank No. 20	VOC	1.14	1.08
		Benzene	0.01	0.01
26	Tank No. 21	VOC	1.14	1.08
		Benzene	0.01	0.01
27	Tank No. 22	VOC	1.14	1.08
		Benzene	0.01	0.01
29	Tank No. 23	VOC	1.14	1.08
		Benzene	0.01	0.01
30	Tank No. 30	VOC	1.75	0.01
		Benzene	0.00	0.00
1200	Additive tanks	VOC	0.36	0.01
1210		VOC	0.04	0.01
1220		VOC	0.10	0.01
1230		VOC	0.10	0.01

Emission Sources - Maximum Allowable Emission Rates

1240		VOC	9.19	0.29
1270		VOC	0.53	<0.01
21	Oil/Water Separator	VOC	1.20	0.10
		Benzene	<0.01	<0.01
23	Water Tank	VOC	0.02	0.10
		Benzene	<0.01	<0.01
28	Facility Filter	VOC	17.36	1.10
		Benzene	0.16	0.01
CE/SV01	Vapor Combustor Unit (VCU)	VOC	14.67	30.00
		Benzene	0.10	0.15
		CO	4.90	6.21
		NO _x	8.09	7.75
		SO ₂	0.02	0.11
		PM	0.01	0.06
		PM ₁₀	<0.01	0.04
		PM _{2.5}	<0.01	0.01
24	Facility Fugitives (5)	VOC	0.75	3.27
		Benzene	0.01	0.03
TL/FE-MSS	Tank Landing and Floating Emissions	VOC	193.45	17.40
		Benzene	1.74	0.16

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
- PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented
- PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
- CO - carbon monoxide
- Benzene - speciated pollutant from VOC
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

Emission Sources - Maximum Allowable Emission Rates

- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

Date: October 20, 2016