

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 35617

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lb/hr	TPY
	30-Hp Boiler (4)	PM ₁₀	0.02	0.02
		VOC	<0.01	<0.01
		NO _x	0.13	0.13
		CO	0.03	0.03
		SO ₂	<0.01	<0.01
12	Room Air Scrubber	Odor	***	

(1) Emission point identification - either specific equipment designation or emission point no. from plot plan.

(2) Specific point source name. For fugitive sources use area name or fugitive source name.

(3) PM₁₀ - particulate matter equal to or less than 10 microns in diameter. Where particulate matter (PM) is not listed, it shall be assumed that no PM greater than 10 microns is emitted.

VOC - volatile organic compounds as defined in General Rule 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

CO - carbon monoxide

(4) Emissions are based on and the facility is limited to an operating schedule of 8 hrs/day, 5 days/week, 50 weeks/yr, or 2,000 hours per year.

*** Odors shall be maintained at a minimum level.

Dated_____