

Emission Sources - Maximum Allowable Emission Rates

Permit Number 48056

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B-2	Boiler No. 2	Natural Gas-Fired		
		NO _x	1.63	2.29
		CO	4.28	6.02
		PM	0.39	0.54
		PM ₁₀	0.39	0.54
		SO ₂	0.03	0.04
		VOC	0.28	0.39
		Fuel Oil Fired		
		NO _x	3.30	1.19
		CO	3.27	1.18
		PM	1.31	0.47
		PM ₁₀	0.85	0.31
		SO ₂	2.12	0.76
		VOC	0.16	0.06
B-3	Boiler No. 3	Natural Gas-Fired		
		NO _x	1.73	2.35
		CO	3.94	5.38
		PM	0.34	0.49
		PM ₁₀	0.34	0.49
		SO ₂	0.03	0.04

Emission Sources - Maximum Allowable Emission Rates

		VOC	0.24	0.35
		Fuel Oil Fired		
		NO _x	2.81	1.01
		CO	2.79	1.00
		PM	1.12	0.40
		PM ₁₀	0.73	0.26
		SO ₂	1.81	0.65
		VOC	0.14	0.05
B-4	Boiler No. 4	Natural Gas-Fired		
		NO _x	1.80	4.20
		CO	4.10	9.60
		PM	0.35	0.87
		PM ₁₀	0.35	0.87
		SO ₂	0.03	0.07
		VOC	0.25	0.63
		Fuel Fired Oil		
		NO _x	1.63	0.59
		CO	1.62	0.58
		PM	0.65	0.23
		PM ₁₀	0.42	0.15
		SO ₂	1.05	0.38
		VOC	0.08	0.03

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

Emission Sources - Maximum Allowable Emission Rates

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

CO - carbon monoxide

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

Date: December 9, 2011