Permit Numbers 1467, PSDTX1090M1, and N284

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
SC-7	Mitsubishi M501 GAC	NO _x	25.2	72.00
		CO	18.4	237.02
		VOC	7.00	113.99
		PM	7.00	30.66
		PM ₁₀	7.00	30.66
		PM _{2.5}	7.00	30.66
		SO ₂	1.54	6.75
		NH ₃	18.7	81.91
		H ₂ SO ₄	1.41	6.18
		HAPs	1.40	6.33
SC-7	Mitsubishi M501 GAC (MSS)	NO _x	58.50	
		CO	555.67	
		VOC	312.92	
		HAPs	2.09	
FIRE-2	Emergency Diesel Firewater Pump Engine	NO _x	0.60	0.028
		CO	0.13	0.007
		VOC	0.05	0.003
		PM	0.03	0.002
		PM ₁₀	0.03	0.002
		PM _{2.5}	0.03	0.002
		SO ₂	<0.01	<0.01
		HAPs	<0.01	<0.01
LH-1	Forced Draft Line Heater	NO _x	0.118	0.515
		CO	0.145	0.635
		VOC	0.031	0.137
		PM	0.019	0.083
		PM ₁₀	0.019	0.083
		PM _{2.5}	0.019	0.083
		SO ₂	<0.01	0.017
Project Number: 334179		HAPs	<0.01	0.032

FUG-7	Unit 7 Piping Fugitives (10)	VOC	0.029	0.13
Unit 4				
S4-1	Westinghouse W501-B6 69 MW Turbine	NO _x (12)	188	674
	with 124 MMBtu/hr Duct Burner (11)	CO (12)	840	1,665
		SO ₂	17	12
		VOC	12	44
		PM/PM ₁₀ / PM _{2.5}	2	6
S4-2	Westinghouse W501-B6 69 MW Turbine	NO _x (12)	188	674
	with 124 MMBtu/hr Duct Burner (11)	CO (12)	840	1,665
		SO ₂	17	12
		VOC	12	44
		PM/PM ₁₀ / PM _{2.5}	2	6
Unit 6 Simple	e Cycle			
SC-S6A	GE Frame 7EA 70 MW Turbine	NO _x	174	-
	without Duct Burner	СО	233	-
	High Load Operation (8)	VOC	8	-
		PM/PM ₁₀ / PM _{2.5}	9	-
		SO ₂	14	-
		H ₂ SO ₄	2	-

00.004	05.5			
SC-S6A	GE Frame 7EA 70 MW Turbine without Duct Burner Startup, Shutdown, and Low Load	NO _x	180	-
		СО	386	-
	Operation (9)	VOC	5	-
	(Limited to 2,500 hours per year)	PM/PM ₁₀ / PM _{2.5}	9	-
		SO ₂	14	-
		H ₂ SO ₄	2	-
SC-S6A	Annual Emissions from EPN SC-S6A (11)	NO _x	-	283 (6)
	(11)	СО	-	363
		VOC	-	8
		PM/PM ₁₀ / PM _{2.5}	-	29
		SO ₂	-	13
		H ₂ SO ₄	-	2
SC-S6B	GE Frame 7EA 70 MW Turbine without Duct Burner High Load Operation (8)	NO _x	174	-
		со	233	-
		VOC	8	-
		PM/PM ₁₀ / PM _{2.5}	9	-
		SO ₂	14	-
		H ₂ SO ₄	2	-
SC-S6B	GE Frame 7EA 70 MW Turbine without Duct Burner Startup, Shutdown, and Low Load Operation (9) (Limited to 2,500 hours per year)	NO _x	180	-
		со	386	-
		voc	5	-
		PM/PM ₁₀ / PM _{2.5}	9	-
		SO ₂	14	-
		H ₂ SO ₄	2	-

SC-S6B	Annual Emissions from EPN SC-S6B (11)	NO _x	-	283 (6)
		со	-	363
		VOC	-	8
		PM/PM ₁₀ / PM _{2.5}	-	29
		SO ₂	-	13
		H ₂ SO ₄	-	2
Unit 6 Combine C	Cycle			
CC-S6A	GE Frame 7EA 70 MW Turbine with 285 MMBtu/hr Duct Burner High Load Operation (8)	NO _x	42	-
		СО	326	-
		VOC	18	-
		PM/PM ₁₀ / PM _{2.5}	15	-
		SO ₂	20	-
		H ₂ SO ₄	3.8	-
		NH ₃	20	-
CC-S6A	GE Frame 7EA 70 MW Turbine with 285 MMBtu/hr Duct Burner Startup, Shutdown, and Low Load Operation (9)	NO _x	180	-
		СО	518	-
		voc	18	-
		PM/PM ₁₀ / PM _{2.5}	15	-
		SO ₂	20	-
		H ₂ SO ₄	3.8	-

CC-S6A	Annual Emissions from EPN CC-S6A (11)	NO _x	-	165 (7)
		СО	-	456
		VOC	-	25
		PM/PM ₁₀ / PM _{2.5}	-	38
		SO ₂	-	16
		H ₂ SO ₄	-	3.1
		NH ₃	-	50
CC-S6B	GE Frame 7EA 70 MW Turbine with 285 MMBtu/hr Duct Burner High Load Operation (8)	NO _x	42	-
		со	326	-
		voc	18	-
		PM/PM ₁₀ / PM _{2.5}	15	-
		SO ₂	20	-
		H ₂ SO ₄	3.8	-
		NH ₃	20	-
CC-S6B	GE Frame 7EA 70 MW Turbine with 285 MMBtu/hr Duct Burner Startup, Shutdown, and Low Load Operation (9)	NO _x	180	-
		со	518	-
		voc	18	-
		PM/PM ₁₀ / PM _{2.5}	15	-
		SO ₂	20	-
		H ₂ SO ₄	3.8	-

CC-S6B	Annual Emissions from EPN CC-S6B (11)	NO _x	-	165 (7)
		СО	-	456
		VOC	-	25
		PM/PM ₁₀ / PM _{2.5}	-	38
		SO ₂	-	16
		H ₂ SO ₄	-	3.1
		NH ₃	-	50
FIRE	Firewater Pump Engine	NO _x	9.3	0.9
		СО	2.0	0.2
		VOC	0.8	<0.1
		PM/PM ₁₀ / PM _{2.5}	0.7	<0.1
		SO ₂	0.1	<0.1
		H ₂ SO ₄	<0.1	<0.1
OTD-1	Diesel Storage Tank 1	VOC	<0.1	<0.1
OTD-2	Diesel Storage Tank 2	VOC	<0.1	<0.1
OTD-3	Diesel Storage Tank 3	VOC	<0.1	<0.1
LO-1	Gas Turbine GT-6A Lube Oil Vent	VOC	<0.1	0.2
		PM/PM ₁₀ / PM _{2.5}	<0.1	0.2
LO-2	Gas Turbine GT-6B Lube Oil Vent	VOC	<0.1	0.2
		PM/PM ₁₀ / PM _{2.5}	<0.1	0.2
LO-3	Steam Turbine Lube Oil Vent	VOC	<0.1	0.2
		PM/PM ₁₀ / PM _{2.5}	<0.1	0.2
FUG-6	Unit 6 Piping Fugitives (10)	VOC	0.3	1.5
		H ₂ S	<0.1	0.1
		NH ₃	0.5	2.2
		Cl ₂	<0.1	0.4

OTA-1	Ammonia Storage Tank 1	NH ₃	<0.1	0.4
CT-1467-4	Cooling Tower 4	PM	5.94	26.04
		PM ₁₀	0.38	1.67
		PM _{2.5}	0.01	0.03
		HOCI (5)	<0.1	<0.1
CT-1467-6	Cooling Tower 6	PM	1.49	6.51
		PM ₁₀	0.10	0.42
		PM _{2.5}	0.002	0.01
		HOCI (5)	<0.1	<0.1
FUG-4	Unit 4 Fugitives (10)	VOC	0.5	2.2
		Cl ₂	0.08	0.35
MSSFUG	MSS Fugitive Emissions (ILE) (10)	NO _x	<0.01	<0.01
		СО	<0.01	<0.01
		PM	<0.01	<0.01
		PM ₁₀	<0.01	<0.01
		PM _{2.5}	<0.01	<0.01
		VOC	7.00	1.07
		NH ₃	<0.01	<0.01

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO_x total oxides of nitrogen

CO - carbon monoxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$ PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

 $\begin{array}{cccc} H_2SO_4 & - & sulfuric \ acid \\ H_2S & - & hydrogen \ sulfide \\ NH_3 & - & anhydrous \ ammonia \end{array}$

Cl₂ - chlorine

HOCI - hypochlorous acid

- HAPs hazardous air pollutants
- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
- (5) Inorganic compounds calculated at HOCI.
- (6) For Unit 6, the annual NO_x emissions for Simple Cycle Operations assumes up to 2,500 hours of startup, shutdown, and low load operation per turbine.
- (7) For Unit 6, the annual NO_x emissions after HRSG installation is determined assuming a limitation of 2,500 hours of simple cycle operation and up to 2,500 hours of startup, shutdown, and low load operation per turbine.
- (8) High Load Operation is defined in Special Condition No. 6(A)(1).
- (9) Low Load Operation is defined in Special Condition No. 6(A)(2).
- (10) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (11) The tpy emission limit specified in the MAERT for this facility includes emissions from the facility during both normal operations and planned MSS activities.
- (12) The NO_x and CO lb/hr and tpy emission rates are authorized by Standard Permit Registration No. 114528.

Permit Number GHGPSDTX199

This table lists the maximum allowable emission rates of greenhouse gas (GHG) emissions, as defined in Title 30 Texas Administrative Code § 101.1, for sources of GHG air contaminants on the applicant's property authorized by this permit. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
		Name (5)	TPY (4)	
SC-7	Mitsubishi M501 GAC High	CO ₂	790,000	
	Load Operation (GHG)	CH ₄	625.66	
		N_2O	2.66	
		CO ₂ e	806,434	
FIRE-2	Emergency Diesel Firewater Pump Engine	CO ₂	5.65	
		CH ₄	<0.01	
		N ₂ O	<0.01	
		CO ₂ e	5.67	
LN-1	Forced Draft Line Heater	CO ₂	1822.72	
		CH ₄	0.03	
		N ₂ O	<0.01	
		CO ₂ e	1824.61	
FUG-7	Unit 7 Piping Fugitives (5)	CO ₂	0.04	
		CH ₄	6.66	
		CO ₂ e	169.97	

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) CO₂ carbon dioxide N_2O nitrous oxide

CH₄ methane

carbon dioxide equivalents, based on the following Global Warming Potentials from 40 CFR CO₂e Part 98, subpart A, Table A-1, effective January 1, 2015: CO₂ (1), CH₄ (25), N₂O (298), and

SF₆ (22,800)

- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period. Annual emission limits include both normal and maintenance, startup, and shutdown (MSS) emissions.
- (5) Fugitive emission rates are estimates and are enforceable through compliance with the applicable special conditions and permit application representations.

Date: November 23, 2021