

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 2401

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

### AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
				lb/hr
	TPY**			
B3	Unit No. 3 Boiler (4)	NO <sub>x</sub>	5,523	24,190
		SO <sub>2</sub>	9,468	41,479
		PM	800	3,504
		CO	9,098	39,849
		VOC	38	153
B2S	No. 2 Start-up Boiler (4) (5)	NO <sub>x</sub>	110	
		SO <sub>2</sub>	293	
		PM	37	
		CO	17	
		VOC	1	
B3S	No. 3 Start-up Boiler (4) (5)	NO <sub>x</sub>	110	
		SO <sub>2</sub>	293	
		PM	37	
		CO	17	
		VOC	1	

- (1) Emission point identification - either specific equipment designation or emission point number from a plot plan.
- (2) Specific point source names. For fugitive sources, use an area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in 30 Texas Administrative Code §101.1  
 NO<sub>x</sub> - total oxides of nitrogen  
 SO<sub>2</sub> - sulfur dioxide  
 PM - particulate matter, suspended in the atmosphere, including PM<sub>10</sub>.  
 PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted  
 CO - carbon monoxide
- (4) Compliance with NO<sub>x</sub>, PM, PM<sub>10</sub>, SO<sub>2</sub>, and VOC hourly emissions is determined on a 3-hour average basis. Compliance with the CO hourly emission limit is determined on a 30-day average basis.

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY**

(5) The combined total annual emissions from EPNs B2S, B3S, and B3 shall not exceed the allowable annual emission rates for EPN B3.

\* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

\_\_\_\_Hrs/day \_\_\_\_Days/week \_\_\_\_Weeks/year or 8,760 Hrs/year

\*\* Annual emission limits (in tons per year) are applicable on a calendar year basis.

Dated August 25, 2004