

Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 156787

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
B-600	North Boiler 600 (5)	NO _x	3.53	-
		NO _x (MSS)	12.90	-
		CO	5.45	-
		CO (MSS)	48.56	-
		VOC	0.53	-
		PM	0.60	-
		PM ₁₀	0.60	-
		PM _{2.5}	0.60	-
		SO ₂	0.06	-
B-700	South Boiler 700 (5)	NO _x	3.53	-
		NO _x (MSS)	12.90	-
		CO	5.45	-
		CO (MSS)	48.56	-
		VOC	0.53	-
		PM	0.60	-
		PM ₁₀	0.60	-
		PM _{2.5}	0.60	-
		SO ₂	0.06	-
B-600B700	Boiler Annual Emissions Routine and MSS emissions	NO _x	-	5.31
		CO	-	19.03
		VOC	-	2.64
		PM	-	3.00
		PM ₁₀	-	3.00
		PM _{2.5}	-	3.00
		SO ₂	-	0.29
FUG-NG	Natural Gas Fugitives (6)	VOC	<0.01	<0.01

Emission Sources - Maximum Allowable Emission Rates

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3)

NO _x	- total oxides of nitrogen
CO	- carbon monoxide
VOC	- volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
PM	- total particulate matter, suspended in the atmosphere, including PM ₁₀ and PM _{2.5}
PM ₁₀	- total particulate matter equal to or less than 10 microns in diameter, including PM _{2.5}
PM _{2.5}	- particulate matter equal to or less than 2.5 microns in diameter
SO ₂	- sulfur dioxide
MSS	- maintenance, startup, and shutdown
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Planned maintenance, startup and shutdown (MSS) emissions for all pollutants are authorized even if not specifically identified as MSS. During any clock hour that includes one or more minutes of planned MSS that pollutant's maximum hourly emission rate shall apply during that clock hour.
- (6) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.

Date: October 24, 2019