## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

## 20862/PSD-TX-799

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

## AIR CONTAMINANTS DATA

Emission	Source			Air Contaminant		Emission Rates **	
Point No. (1)	Name (2)	Name (3	s) <u>lb/hr</u>	<u>TPY</u>			
GTG-1	40 MW GE Frame 6 Gas-Fired Turbine and 270 MMBtu/hr Duct Burner			NOx CO * PM10 * VOC	39.0 32.6 7.9 13.1	136.7 126.1 31.5 48.4	
NH3				SO2 SO3 H2SO4 11.4	27.5 2.0 2.0 44.5	86.7 4.4 4.4	
FUG-1	Cogener	ation Unit ugitives (4) H2S	VOC NH3	1.8 <0.1 <0.001	7.9 <0.2 <0.001		

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) PM10 particulate matter less than 10 microns
  - VOC volatile organic compounds as defined in General Rule 101.1
  - NOx total oxides of nitrogen
  - SO2 sulfur dioxide
  - SO3 sulfur trioxide
  - H2SO4 sulfuric acid mist
  - CO carbon monoxide
  - NH3 ammonia
  - H2S hydrogen sulfide
- (4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
- (5) The hourly emission rates are based on 20°F ambient temperature using the worst-case (short-term) fuel, high hydrogen fuel.
- (6) The annual emission rates are based on 69°F ambient temperature using the worst-case (long-term) fuel, rated refinery fuel gas.
- \* PSD regulated contaminant

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

**	Emission rate schedule:		n and the facilit	ies are limited	by the following	maximum operating
	Hrs/day	_Days/week	Weeks/year	or Hrs/year_	<u>8,760</u>	