

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

6721

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY

CASE 1 - CONTINUOUS FIRING ON 100 PERCENT NATURAL GAS

B-5	Boiler	NO _x	4.27	18.70
		SO ₂	0.02	0.08
		CO	1.07	4.68
		VOC	0.08	0.37
		PM	0.23	1.00

CASE 2 - 8,520 HOURS OF NATURAL GAS FIRING AND 240 HOURS OF FIRING NO. 2 FUEL OIL

B-5	Boiler (Natural Gas)	NO _x	4.27	18.19
		SO ₂	0.02	0.08
		CO	1.07	4.55
		VOC	0.08	0.36
		PM	0.23	0.97
B-5	Boiler (No. 2 Fuel Oil)	NO _x	4.36	0.52
		SO ₂	9.28	1.11
		CO	1.09	0.13
		VOC	0.04	0.005
		PM	0.44	0.05

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) PM - particulate matter
VOC - volatile organic compounds as defined in General Rule 101.1

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

CO - carbon monoxide

(4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day___Days/week___Weeks/year___or Hrs/year 8,760