Permit Numbers 76474 and PSDTX1056

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emissions rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

| Emission | Source | Air Contaminant | Emission | Rates ** |
|---------------|---------------------------|----------------------------------|----------|----------|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* |
| E 0011 | Dulyarized Coal (Lignita) | NO | 1 000 | 2 1 42 |
| E-OGU1 | Pulverized Coal (Lignite) | NO _x | 1,800 | 3,143 |
| | Boiler (8,970 MMBtu/hr) | SO ₂ | 5,382 | 7,543 |
| | | PM/PM ₁₀ (filter) (4) | 135 | 589 |
| | | PM/PM_{10} (total) | 449 | 1,572 |
| | | CO | 6,100 | 13,358 |
| | | VOC | 47 | 176 |
| | | H_2SO_4 | 165 | 481 |
| | | NH_3 | 55 | 96 |
| | | HF | 64 | 140 |
| | | HCI | 110 | 241 |
| | | Pb | 0.26 | 0.38 |
| | | Hg | 0.93 | 0.36 |
| E-OGU2 | Pulverized Coal (Lignite) | NO_x | 1,800 | 3,143 |
| | Boiler (8,970 MMBtu/hr) | SO_2 | 5,382 | 7,543 |
| | | PM/PM_{10} (filter) (4) | 135 | 589 |
| | | PM/PM_{10} (total) | 449 | 1,572 |
| | | CO | 6,100 | 13,358 |
| | | VOC | 47 | 176 |
| | | H_2SO_4 | 165 | 481 |
| | | NH ₃ | 55 | 96 |
| | | HF | 64 | 140 |
| | | HCI | 110 | 241 |
| | | Pb | 0.26 | 0.38 |
| | | Hg | 0.93 | 0.36 |

| Emission | Source | Air Contaminant Emission Rates ** | | ates ** |
|---------------|--|---|--|---|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* |
| E-OGAB | Natural Gas-Fired Auxiliary Boiler (365 MMBtu/hr) (Phase 1 - PC Boiler Construction Phase) | NO_{x} (4) (5) NO_{x} (4) (6) CO (5) CO (6) SO_{2} PM/PM_{10} VOC | 13.1 36.5 13.5 135.0 5.1 2.7 2.0 | 57.6 59.1 22.4 11.9 8.6 |
| E-OGAB | Natural Gas-Fired Auxiliary Boiler (365 MMBtu/hr) (Phase 2 - 10 percent Annual Capacity Factor) | NO_{x} (5) NO_{x} (6) CO (5) CO (6) SO_{2} PM/PM_{10} VOC | 13.1 36.5 13.5 135.0 5.1 2.7 2.0 | 5.8 5.9 2.2 1.2 0.9 |
| E-OGLTHF | Railcar Coal Unloading | PM | 1.34 | 1.65 |
| | Building Fugitives (7) | PM ₁₀ | 0.26 | 0.31 |
| E-OGLTHBF | Railcar Coal Unloading - Track | C PM | 0.01 | 0.02 |
| | Hopper Fugitives (7) | PM ₁₀ | 0.01 | 0.01 |
| E-OGLSILO | Lignite Storage Silo | PM | 0.01 | 0.01 |
| | Bin Vent Filter | PM ₁₀ | 0.01 | 0.01 |
| E-OGSSPRF | Reclaim from Silo and | PM | 0.01 | 0.02 |
| | Stackout Pile Fugitives (7) | PM ₁₀ | 0.01 | 0.01 |
| E-OGLSPF | Lignite Stackout Pile | PM | 0.16 | 0.21 |
| | Fugitives (7) | PM ₁₀ | 0.03 | 0.04 |
| E-OGCHBV | Lignite Crusher House | PM | 0.01 | 0.01 |
| | Surge Bin Vent Filter | PM ₁₀ | 0.01 | 0.01 |

| Emission | Source | Air Contaminant | Emission Rates ** | | |
|---------------|--|------------------------|-------------------|--------------|--|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* | |
| E-OGCHF | Lignite Crusher House | PM | 1.20 | 2.25 | |
| | Fugitives (7) | PM ₁₀ | 0.23 | 0.43 | |
| E-OGSBTTBV | Surge Bin Transfer Tower | PM | 0.01 | 0.01 | |
| | Bin Vent Filter | PM ₁₀ | 0.01 | 0.01 | |
| E-OGSBTTF | Surge Bin Transfer Tower Fugitives (7) | PM PM ₁₀ | 0.01 0.01 | 0.01 0.01 | |
| E-OGTT4F | Transfer Tower 4 Fugitives (7) | PM PM ₁₀ | 0.01 0.01 | 0.01 0.01 | |
| E-OGU1SSV | Unit 1 South Side Tripper | PM | 0.01 | 0.01 | |
| | House Baghouse Vent | PM ₁₀ | 0.01 | 0.01 | |
| E-OGTT2F | Transfer Tower 2 | PM | 0.01 | 0.01 | |
| | Fugitives (7) | PM ₁₀ | 0.01 | 0.01 | |
| E-OGU1NSV | Unit 1 North Side Tripper | PM | 0.01 | 0.01 | |
| | House Baghouse Vent | PM ₁₀ | 0.01 | 0.01 | |
| E-OGU2SSV | Unit 2 South Side Tripper | PM | 0.01 | 0.01 | |
| | House Baghouse Vent | PM ₁₀ | 0.01 | 0.01 | |
| E-OGTT3F | Transfer Tower 3 Fugitives (7) | PM PM ₁₀ | 0.01 0.01 | 0.01 0.01 | |
| E-OGU2NSV | Unit 2 North Side Tripper | PM | 0.01 | 0.01 | |
| | House Baghouse Vent | PM ₁₀ | 0.01 | 0.01 | |
| E-OGLDSPF | Lignite Dead Storage Pile | PM | 1.48 | 5.18 | |
| | Dust Fugitive (7) | PM ₁₀ | 0.28 | 0.98 | |
| E-OGLSSF | Limestone Storage | PM | 0.11 | 0.16 | |
| | Shed Fugitives | PM ₁₀ | 0.05 | 0.08 | |
| E-OGSLSAF | Secondary Limestone Storage | PM | 1.49 | 2.17 | |

| Emission | Source | Air Contaminant | Emission Rates ** | | |
|---------------|--|------------------------|-------------------|--------------|--|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* | |
| | Pile Dust Fugitives (7) | PM ₁₀ | 0.75 | 1.09 | |
| E-OGLSPRF | Limestone Storage Reclaim | PM | 0.02 | 0.01 | |
| | Belt Fugitives (7) | PM ₁₀ | 0.01 | 0.01 | |
| E-OGLSSB1V | Limestone Storage Silo 1 | PM | 0.01 | 0.01 | |
| | Bin Vent Filter | PM ₁₀ | 0.01 | 0.01 | |
| E-OGLSSB2V | Limestone Storage Silo 2 | PM | 0.01 | 0.01 | |
| | Bin Vent Filter | PM ₁₀ | 0.01 | 0.01 | |
| E-OGLSSB3F | Limestone Storage Conveyor | PM | 0.01 | 0.01 | |
| | Transfer Fugitives (7) | PM ₁₀ | 0.01 | 0.01 | |
| E-OGSSSV | Sorbent Storage Silo Baghouse Vent | PM ₁₀ | 0.06 | 0.24 | |
| E-OGVS1V1 | Unit 1 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | |
| E-OGVS1V2 | Unit 1 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | |
| E-OGVS1V3 | Unit 1 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | |
| E-OGFAS1V1 | Fly Ash Silo 1 | PM | 0.99 | 1.80 | |
| | Bin Vent Filter | PM ₁₀ | 0.36 | 0.63 | |
| E-OGSLS1V | Fly Ash Silo 1 Loading | PM | 0.03 | 0.11 | |
| | Spout Baghouse Vent | PM ₁₀ | 0.03 | 0.11 | |
| E-OGWFAU1F | Fly Ash Silo 1 Loading | PM | 0.03 | 0.06 | |
| | Dust Fugitive (7) | PM ₁₀ | 0.01 | 0.01 | |

| Emission | Source | Air Contaminant | Emission Rates ** | | | |
|----------------------|---|------------------------|-------------------|--------------|--|--|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* | | |
| E-OGVS2V1 | Unit 2 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | | |
| E-OGVS2V2 | Unit 2 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | | |
| E-OGVS2V3 | Unit 2 Fly Ash Filter Separators Baghouse Vent | PM PM ₁₀ | 0.20 0.07 | 0.89 0.31 | | |
| E-OGFAS2V1 | Fly Ash Silo 2 Bin Vent Filter | PM PM ₁₀ | 0.33 0.12 | 0.60 0.21 | | |
| E-OGFAS2V2 | Fly Ash Silo 2 Bin Vent Filter | PM PM ₁₀ | 0.33 0.12 | 0.60 0.21 | | |
| E-OGFAS2V3 | Fly Ash Silo 2 Bin Vent Filter | PM PM ₁₀ | 0.33 0.12 | 0.60 0.21 | | |
| E-OGSLS2V | Fly Ash Silo 2 Loading Spout Baghouse Vent | PM PM ₁₀ | 0.03 0.03 | 0.11 0.11 | | |
| E-OGWFAU2F | Fly Ash Silo 2 Loading Dust Fugitive (7) | PM PM ₁₀ | 0.03 0.01 | 0.06 0.01 | | |
| E-OGLDLF E-OGRDLF | Landfill Areas - Active Working Faces - Dust Fugitive (7) | PM PM ₁₀ | 0.26 0.14 | 1.16 0.58 | | |
| E-OGLDLF E-OGRDLF | Landfill Areas - Inactive Working Faces - Dust Fugitive (7) | PM PM ₁₀ | 0.08 0.04 | 0.32 0.16 | | |

Permit Numbers 76474 and PSDTX1056 Page 6

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

| Emission | Source | Air Contaminant | Emission Rates ** | | | |
|---------------|------------------------|-----------------|-------------------|------|--|--|
| Point No. (1) | Name (2) | Name (3) | lb/hr | TPY* | | |
| | | | | | | |
| E-OGGHSF | Gypsum Handling System | PM | 0.01 | 0.01 | | |
| | Dust fugitive (7) | PM_{10} | 0.01 | 0.01 | | |
| E-OGAMM | Ammonia Fugitive (7) | NH_3 | 0.04 | 0.19 | | |
| | 5 () | | | | | |
| E-OGCT1 | Cooling Tower | PM | 0.02 | 0.09 | | |
| | | PM_{10} | 0.01 | 0.02 | | |

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.

(3) NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - particulate matter, suspended in the atmosphere, including PM₁₀

PM₁₀ - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no PM greater than 10 microns is emitted.

CO - carbon monoxide

VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

H₂SO₄ - sulfuric acid mist

NH₃ - ammonia

HF - hydrogen fluorideHCl - hydrogen chloride

Pb - lead Hg - mercury

- (4) Compliance with the hourly emission limit is based on a three-hour block average of the CEMS data.
- (5) Hourly limit applies when auxiliary boiler is operating at or above 25 percent load.
- (6) Hourly limit applies when auxiliary boiler is operating below 25 percent load and during startup and shutdown.
- (7) Fugitives emission rate is an estimate and compliance is demonstrated by meeting the requirements of the applicable special conditions and permit application representations.
- * For combustion sources and storage tanks, compliance with annual emission limits is based on a rolling 12-month period. For material handling sources, compliance with annual emission limits is based on applicable special conditions and permit application representations.
- ** Except as otherwise specified in special conditions, emission rates are based on and the facilities are limited by the following maximum operating schedule:

| Hrs/day | 24 | Days/ | /week | 7 | Weeks/ | year | 52 | or Hrs/y | r 8 | 3,760 | |
|---------|----|-------|-------|---|--------|------|----|----------|-----|-------|--|
| | | | | | | | | | | | |