Permit Number 83550

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		
			lbs/hour	TPY (4)	
The emission rates shown below are effective until the combined cycle electric generating unit authorized via Standard Permit No. 95640 becomes operational. Standard Permit No. 95640 authorizes modifications to be made to Combustion Turbine 2 in order to convert it to a combined cycle electric generating unit.					
1 - Ge	Combustion Turbine 1 - General Electric (GE) 7EA, 73.1 MW (approx)	со	58.45		
		CO (5)	467.60		
		NO _X	34.57		
	(αρριολ)	NO _x (5)	96.04		
		voc	9.35		
		VOC (5)	33.40		
		PM ₁₀	13.94		
		SO ₂	1.47		
		H ₂ SO ₄	0.11		
2 - (0 MV	Combustion Turbine 2 - General Electric (GE) 7EA, 73.1 MW (approx)	со	58.45		
		CO (5)	467.60		
		NOx	34.57		
		NO _x (5)	96.04		
		voc	9.35		
		VOC (5)	33.40		
		PM ₁₀	13.94		
		SO ₂	1.47		

		H ₂ SO ₄	0.11	
HCCT1/HCCT2	Combustion Turbine 1	со		99.37
	and Combustion Turbine 2	NOx		45.23
	Turbline 2	voc		12.79
		PM ₁₀		15.86
		SO ₂		1.67
		H ₂ SO ₄		0.13
LUBVNT1	Combustion Turbine	PM ₁₀	0.05	0.06
	Lube Vent	voc	0.05	0.06
LUBVNT2	Combustion Turbine 2	PM ₁₀	0.05	0.06
	Lube Vent	voc	0.05	0.06
HCHTR1	Fuel Gas Pre-heater	NO _X	0.39	1.72
		со	0.33	1.45
		voc	0.02	0.10
		PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01
		H ₂ SO ₄	<0.01	<0.01
HCHTR2	Fuel Gas Pre-heater 2	NOx	0.39	1.72
		со	0.33	1.45
		voc	0.02	0.10
		PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01
		H ₂ SO ₄	<0.01	<0.01
MSS-FUG1/MSS- FUG2	Fugitive Emissions from Maintenance	VOC	0.08	<0.01

		РМ	<0.01	<0.01
		PM ₁₀	<0.01	<0.01
		PM _{2.5}	<0.01	<0.01
MSS-CEMS1/ MSS-CEMS2	Fugitives from CEMS	NO _X	<0.01	<0.01
WIGG CLIVICE	Calibration	со	<0.01	<0.01
	ndard Permit No. 95640	ctive after the combined cyc 0 becomes operational. Cor		
HCCT1	Combustion Turbine	со	58.45	49.69
	- General Electric (GE) 7EA, 73.1	CO (5)	467.60	
	MW (approx)	NO _X	34.57	22.62
	(αμριολ)	NO _x (5)	96.04	
		voc	9.35	6.40
1		VOC (5)	33.40	
		PM ₁₀	13.94	7.93
		SO ₂	1.47	0.84
		H ₂ SO ₄	0.11	0.07
LUBVNT1	Combustion Turbine	PM ₁₀	0.05	0.06
	Lube Vent	VOC	0.05	0.06
LUBVNT2	Combustion Turbine 2	PM ₁₀	0.05	0.06
	Lube Vent	VOC	0.05	0.06
HCHTR1	Fuel Gas Pre-heater	NO _X	0.39	1.72
		со	0.33	1.45
		VOC	0.02	0.10
		PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01

		H ₂ SO ₄	<0.01	<0.01
HCHTR2	Fuel Gas Pre-heater 2	NO _X	0.39	1.72
		СО	0.33	1.45
		voc	0.02	0.10
		PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01
		H ₂ SO ₄	<0.01	<0.01
MSS-FUG1/MSS- FUG2	Fugitive Emissions from Maintenance Activities	VOC	0.08	<0.01
		РМ	<0.01	<0.01
		PM ₁₀	<0.01	<0.01
		PM _{2.5}	<0.01	<0.01
MSS-CEMS1/ MSS-CEMS2	Fugitives from CEMS Calibration	NOx	<0.01	<0.01
		СО	<0.01	<0.01

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1

NO_x - total oxides of nitrogen

SO₂ - sulfur dioxide PM - particulate matter

 PM_{10} - particulate matter equal to or less than 10 microns in diameter $PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter

 $\begin{array}{lll} \text{CO} & & \text{- carbon monoxide} \\ \text{H}_2 \text{SO}_4 & & \text{- sulfuric acid} \\ \end{array}$

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

(5) Start-up, shutdown, and combustion tuning emission rates.