

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 3663

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

| Emission Point No. (1) | Source Name (2) | Air Contaminant Name (3) | Emission Rates * | |
|---------------------------|--------------------|-----------------------------|------------------|-------|
| | | | lb/hr | TPY** |
| Boiler No. 4 | Plant Boiler No. 4 | CO | 2.55 | 11.15 |
| | | NO _x | 10.10 | 44.23 |
| | | PM | 0.61 | 2.68 |
| | | VOC | 0.44 | 1.94 |
| | | SO ₂ | 0.05 | 0.22 |
| Boiler No. 5 | Plant Boiler No. 5 | CO | 12.04 | 52.73 |
| | | NO _x | 3.25 | 14.24 |
| | | PM | 1.12 | 4.91 |
| | | VOC | 0.88 | 3.84 |
| | | SO ₂ | 0.09 | 0.39 |
| Boiler No. 6 | Plant Boiler No. 6 | CO | 1.20 | 5.25 |
| | | NO _x | 10.89 | 47.69 |
| | | PM | 0.74 | 3.26 |
| | | VOC | 0.54 | 2.36 |
| | | SO ₂ | 0.06 | 0.26 |

Standard Permit Number 71568 is hereby incorporated into in this permit:

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3)
 - CO - carbon monoxide
 - NO_x - total oxides of nitrogen
 - PM - particulate matter, suspended in the atmosphere, including PM₁₀.
 - VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1.
 - SO₂ - sulfur dioxide

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Hrs/day____Days/week____Weeks/year____ or Hrs/year 8,760

** Compliance with the annual emission limits is based on a 12-month rolling basis.

Dated: July 30, 2008