

Emission Sources - Maximum Allowable Emission Rates

Permit Number 83551

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
SJCCT1	Combustion Turbine 1 - General Electric (GE) 7EA, 73.1 MW (approx)	CO	58.45	
		CO (5)	467.60	
		NO _x	34.57	
		NO _x (5)	96.04	
		VOC	9.35	
		VOC (5)	33.40	
		PM/PM ₁₀	13.94	
		SO ₂	1.47	
		H ₂ SO ₄	0.11	
SJCCT2	Combustion Turbine 2 - General Electric (GE) 7EA, 73.1 MW (approx)	CO	58.45	
		CO (5)	467.60	
		NO _x	34.57	
		NO _x (5)	96.04	
		VOC	9.35	
		VOC (5)	33.40	
		PM/PM ₁₀	13.94	
		SO ₂	1.47	
		H ₂ SO ₄	0.11	
SJCCT1/SJCCT2	Combustion Turbine 1 and Combustion Turbine 2	CO		245.49
		NO _x		122.63

Emission Sources - Maximum Allowable Emission Rates

		VOC		34.10
		PM/PM ₁₀		45.48
		SO ₂		4.80
		H ₂ SO ₄		0.37
LUBVNT1	Combustion Turbine 1 Lube Vent	PM/PM ₁₀	0.05	0.17
		VOC	0.05	0.17
LUBVNT2	Combustion Turbine 2 Lube Vent	PM/PM ₁₀	0.05	0.17
		VOC	0.05	0.17
SJCHTR1	Fuel Gas Pre-heater 1	NO _x	0.39	1.72
		CO	0.33	1.45
		VOC	0.02	0.09
		PM/PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01
		H ₂ SO ₄	<0.01	<0.01
SJCHTR2	Fuel Gas Pre-heater 2	NO _x	0.39	1.72
		CO	0.33	1.45
		VOC	0.02	0.09
		PM/PM ₁₀	0.03	0.13
		SO ₂	<0.01	0.01
		H ₂ SO ₄	<0.01	<0.01
MSS-FUG1/MSS-FUG2	Fugitive Emissions from Maintenance Activities	VOC	0.08	<0.01
		PM	<0.01	<0.01
		PM ₁₀	<0.01	<0.01
		PM _{2.5}	<0.01	<0.01
MSS-CEMS1/ MSS-CEMS2	Fugitives from CEMS	NO _x	<0.01	<0.01

Emission Sources - Maximum Allowable Emission Rates

		CO	<0.01	<0.01
--	--	----	-------	-------

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
- NO_x - total oxides of nitrogen
- SO₂ - sulfur dioxide
- PM - particulate matter
- PM₁₀ - particulate matter equal to or less than 10 microns in diameter
- PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
- CO - carbon monoxide
- H₂SO₄ - sulfuric acid
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Start-up, shutdown, and combustion tuning emission rates.

Date: _____