

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 25735

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

### AIR CONTAMINANTS DATA

Emission *	Source	Air Contaminant	<u>Emission Rates</u>	
<u>Point No. (1)</u>	<u>Name (2)</u>	<u>Name (3)</u>	<u>lb/hr</u>	
<u>TPY</u>				
B-1	Boiler No. 1	NO <sub>x</sub>	4.89	12.40
		CO	2.77	7.01
		PM	1.08	2.74
		SO <sub>2</sub>	0.05	0.12
		VOC	0.22	0.56
B-2	Boiler No. 2	NO <sub>x</sub>	4.89	12.40
		CO	2.77	7.01
		PM	1.08	2.74
		SO <sub>2</sub>	0.05	0.12
		VOC	0.22	0.56

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name.

(3) NO<sub>x</sub> - total oxides of nitrogen

CO - carbon monoxide

PM - particulate matter

SO<sub>2</sub> - sulfur dioxide

VOC - volatile organic compounds as defined in General Rule 101.1

\* Emission rates are based on and the facilities are limited to the firing of no more than 801 million standard cubic feet of natural gas per consecutive 12 month period at a maximum firing rate per boiler of 81.5 million Btu per hour.

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION  
RATES

DATA

AIR CONTAMINANTS

Emission Rates *	Source	Air Contaminant	<u>Emission</u>
Point No. (1)	Name (2)	Name (3)	lb/hr TPY

Dated \_\_\_\_\_