

# EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 36889

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

## AIR CONTAMINANTS DATA

Emission *	Source	Air Contaminant	<u>Emission Rates</u>	
<u>Point No. (1)</u>	<u>Name (2)</u>	<u>Name (3)</u>	<u>lb/hr</u>	
TPY				
SAB-1	HRSG Stack	NO <sub>x</sub>	23.4	46.4
		CO	23.7	46.4
		VOC 4.2	13.6	
		SO <sub>2</sub>	10.57	1.7
		PM <sub>10</sub> 10.5	42.5	
		NH <sub>3</sub>	9.6	34.6
SAB-2	HRSG Stack	NO <sub>x</sub>	23.4	46.4
		CO	23.7	46.4
		VOC 4.2	13.6	
		SO <sub>2</sub>	10.57	1.7
		PM <sub>10</sub> 10.5	42.5	
		NH <sub>3</sub>	9.6	34.6
FUG	Fugitives (4)	VOC <0.01	<0.01	

(1) Emission point identification - either specific equipment designation or emission point number from plot plan.

(2) Specific point source name. For fugitive sources use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in General Rule 101.1

NO<sub>x</sub> - total oxides of nitrogen

SO<sub>2</sub> - sulfur dioxide

CO - carbon monoxide

PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no

particulate matter greater than 10 microns is emitted.

NH<sub>3</sub> - ammonia

- (4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- \* Gas turbine emission rates are based on and the gas turbine is limited by the following maximum operating schedule:

Hrs/day 24 Days/week 7 Hours/year 8,760

Dated\_\_\_\_\_