

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 48356

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission **	Source	Air Contaminant	<u>Emission Rates</u>	
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY
* —				
DPU-004	No. 3 Steam Boiler	VOC	1.02	4.47
		NO _x	51.7	226.45
		NO _x (5)	11.28	49.41
		SO ₂	0.02	0.09
		CO	15.42	67.54
		PM ₁₀	1.41	6.18
DPU-003	No. 4 Steam Boiler	VOC	1.02	4.47
		NO _x	51.7	226.45
		NO _x (5)	11.28	49.41
		SO ₂	0.02	0.09
		CO	15.42	67.54
		PM ₁₀	1.41	6.18
DPU-002	No. 5 Steam Boiler	VOC	1.02	4.47
		NO _x	51.7	226.45
		NO _x (5)	11.28	49.41
		SO ₂	0.02	0.09
		CO	15.42	67.54
		PM ₁₀	1.41	6.18
F-DP-M02	Abrasive Blasting	PM	3.94	2.43
		PM ₁₀	0.48	0.29
DP-W01A	Clarifier Thickener	VOC	0.32	1.38
		Acetone	0.03	0.10
DP-W01B	North Storage Tank	VOC	0.74	3.25
		Acetone	0.09	0.38
DP-W01C	South Storage Tank	VOC	0.75	3.25
		Acetone	0.09	0.38

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission ** Point No. (1) TPY*	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates</u> lb/hr	
DP-W01D	Rapid Mix Basin	VOC	0.74	3.23
		Acetone	0.01	0.03
DP-W01E	Slow Mix Basin	VOC	0.26	1.15
		Acetone	0.01	0.02
DP-W01F	Primary Clarifier	VOC	0.07	0.34
		Acetone	0.02	0.05
DP-W01G	Aeration Basin	VOC	0.25	1.08
		Acetone	0.01	0.02
DP-W01H	Secondary Clarifier	VOC	0.01	0.03
		Acetone	0.01	0.01
F-DPU-02	Utilities Area Fugitives (4)	Freon-500	0.46	2.00

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 NO_x - total oxides of nitrogen
 CO - carbon monoxide
 SO₂ - sulfur dioxide
 PM - particulate matter, suspended in the atmosphere, including PM₁₀.
 PM₁₀ - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns in emitted.
- (4) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission rate.
- (5) NO_x emissions are effective after new Burner upgrades as required by Special Condition No. 2.

* Annual emissions are based on a rolling 12 month average.

** Emission rates are based on and the facilities are limited by the following maximum operating schedule:

_____ Hrs/day _____ Days/week _____ Weeks/year or 8,760 Hrs/year

Dated August 20, 2002