EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Nos. 41472 and PSD-TX-942

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission *	Source	Air Contaminant	<u>Emissio</u>	n Rates
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY
HRSG-1	GE-7241FA Turbine	NO_x CO VOC PM_{10} SO_2	85.0 70.0 3.0 18.0 10.0	254.0 276.0 12.0 79.0 40.0
HRSG-2	GE-7241FA Turbine	NO_x CO VOC PM_{10} SO_2	85.0 70.0 3.0 18.0 10.0	254.0 276.0 12.0 79.0 40.0
FWP-1	Firewater Pump Engine ($\begin{array}{cc} \text{A1)} & \text{NO}_{x} \\ & \text{CO} \\ & \text{VOC} \\ & \text{PM}_{10} \\ & \text{SO}_{2} \end{array}$	12.4 2.7 1.0 0.9 0.8	3.1 0.7 0.2 0.2 0.2
DIES-TK	Fuel Oil Storage Tank	VOC	0.28	<0.01
ACID-TK	Acid Storage Tank	H ₂ SO ₄	<0.01	<0.01
FUG-1	Power Block 1 Fugitive Emissions (VOC 5)	<0.01	<0.02
FUG-2	Power Block 2 Fugitive Emissions (VOC 5)	<0.01	<0.02
FUG-3	N.G. Meter Skid	VOC	<0.01	<0.02

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission	Source	Ai	r Contaminant	<u>Emission</u>	Rates
<u>*</u> Point No. (1)	Name (2)		Name (3)	lb/hr	TPY
	Fugitive Emissions	(5)	_		
CTVs 1 through 9	Cooling Tower Vents	(6)	PM PM ₁₀	1.4 0.04	6.0 0.15
OWS-1	Oil/Water Separator		VOC	0.12	0.35
B-1	Auxiliary Boiler		NO_x CO VOC PM_{10} SO_2	0.8 0.8 0.4 0.2	0.4 0.4 0.2 0.1 0.02

- (1) Emission point identification either specific equipment designation or emission point number (EPN).
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) VOC volatile organic compounds as defined in 30 Texas Administrative Code Section 101.1
 - NO_x total oxides of nitrogen
 - CO carbon monoxide
 - SO₂ sulfur dioxide
 - PM particulate matter, suspended in the atmosphere, including PM₁₀.
 - PM_{10} particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted.
 - H₂SO₄ sulfuric acid
- (4) Emissions are based on non-emergency operation of <u>500</u> operating hours per year.
- (5) Fugitive emissions are an estimate based on component count and applicable fugitive emission factors.
- (6) Cooling tower PM and PM_{10} emissions are an estimate only based on manufacturers' data. Cooling tower assembly has nine vent fan exhausts; emissions are sum-total of all nine exhausts.
- * Emission rates are based on an operating schedule of 8,760 hours/year.

Permit Nos. 41472 and PSD-TX-942 Page 3

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	<u>Emission</u>	Rates
<u>*</u>				
Point No. (1)	Name (2)	Name (3)	lb/hr	TPY

Compliance with the annual emission limits shall be based on a rolling 12-month year rather than the calendar year.

Note: All sources at the Duke Energy Kaufman plant, represented in the May 1999 permit application, are regulated under PSD and State regulations for NO_x , CO, SO_2 , PM, and PM_{10} .

	Dated	
--	-------	--