#### Permit Number 43833

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

#### Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates		
Politi No. (1)		Name (3)	lb/hour	TPY (4)	
1	Engine Testing Facilities Research Area	NO <sub>x</sub>	640	330	
	, wea	СО	616	318	
		VOC	142	66	
		PM	83	33	
		PM <sub>10</sub>	83	33	
		PM <sub>2.5</sub>	83	33	
		SO <sub>2</sub>	100	39	
		Pb	0.5	0.25	
		Benzene	1	1	
2A	Analytical and Environmental Chemistry Laboratories	voc	12	12	
2В	Chemical Engineering Research Department Laboratories	NO <sub>x</sub>	10	5	
		СО	10	5	
		VOC	20	10	
		PM <sub>10</sub>	0.6	0.3	
		PM <sub>2.5</sub>	0.6	0.3	
		SO <sub>2</sub>	1.0	0.5	
2C	Microencapsulation and Nanotechnology Laboratories	VOC	4.0	2	
	rvanoteennology Laboratories	PM <sub>10</sub>	2.0	1	
		PM <sub>2.5</sub>	2.0	1	

Project Number: 179768 and 179769

3	Fire Technology Research Area	NO <sub>x</sub>	23	2.9
		СО	226	7.0
		VOC	83.5	3.8
		PM	40	15
		PM <sub>10</sub>	4.0	0.21
		PM <sub>2.5</sub>	4.0	0.21
		SO <sub>2</sub>	5.3	1.1
		SiO <sub>2</sub>	2.8	0.14
4	Metering Research Facility Flare	NO <sub>x</sub>	4.28	0.2
		СО	23.3	1.0
		VOC	8.82	0.4
		РМ	0.33	0.03
		PM <sub>10</sub>	0.33	0.03
		PM <sub>2.5</sub>	0.33	0.03
		SO <sub>2</sub>	<0.01	<0.01
5	Metering Research Facility Gas Turbine (1,250 hp)	NO <sub>x</sub>	12	6
	(2,250 1.p)	СО	12	6
		VOC	10	5
		РМ	0.3	0.15
		PM <sub>10</sub>	0.3	0.15
		PM <sub>2.5</sub>	0.3	0.15
		SO <sub>2</sub>	0.2	0.1
50	VOC Storage Tanks Group	VOC	15.5	45
10 thru 20	High Pressure Part Washers (9 Total)	voc	33.6	8.4
23 and 24	Paint Spray Booths - Bldg. 152 Facility Operations	voc	12.0	2.5

ı	ı			
		PM	0.045	<0.01
		PM <sub>10</sub>	0.043	<0.01
		PM <sub>2.5</sub>	0.042	<0.01
27	Paint Spray Booth - Bldg. 173 Signals Research	VOC	7.2	1.5
	Signals Research	PM	0.046	<0.01
		PM <sub>10</sub>	0.044	<0.01
		PM <sub>2.5</sub>	0.042	<0.01
28	Paint Spray Booth - Bldg. 266 Space Sciences	voc	0.5	0.1
	Space Sciences	РМ	<0.01	<0.01
		PM <sub>10</sub>	<0.01	<0.01
		PM <sub>2.5</sub>	<0.01	<0.01
29	Paint Spray Booth - Bldg. 223 Space Sciences	voc	0.5	0.1
	Space delences	PM	<0.01	<0.01
		PM <sub>10</sub>	<0.01	<0.01
		PM <sub>2.5</sub>	<0.01	<0.01
31	Emergency Generator - Bldg. 90	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
32	Emergency Generator - Bldg. 146	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05

		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
33	Emergency Generator - Bldg. 180	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
34	Emergency Generator - Bldg. 146	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
35	Emergency Generator – Bldg. 86B Fire Water Pumps	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
36	Emergency Generator - Bldg. 124	NO <sub>x</sub>	6.0	0.3

		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
37	Emergency Generator – Bldg. 253 West Campus Booster Station	NO <sub>x</sub>	6.0	0.3
	Proof Gampas Bossier Gaasen	СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
38	Emergency Generator – Bldg. 252 Back up for Booster Station	NO <sub>x</sub>	6.0	0.3
	Back up for Booster Station	СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
39	Emergency Generator - Bldg. 261	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05

	ı			
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
40	Emergency Generator - Bldg. 209	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
41	Emergency Generator - Bldg. 242	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
42	Emergency Generator - Bldg. 256	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
43	Emergency Generator - Bldg. 152	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25

		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
44	Emergency Generator - Bldg. 238	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
45	Emergency Generator - Bldg. 263	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
46	Emergency Generator - Bldg. 264	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05

	i			
		SO <sub>2</sub>	1.0	0.05
47	Emergency Generator - Portable No. 3	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
48	Emergency Generator - Portable No. 4	NO <sub>x</sub>	6.0	0.3
		со	5.0	0.25
		VOC	2.0	0.1
		PM	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
49	Emergency Generator - Bldg. 260	NO <sub>x</sub>	6.0	0.3
		СО	5.0	0.25
		VOC	2.0	0.1
		РМ	1.0	0.05
		PM <sub>10</sub>	1.0	0.05
		PM <sub>2.5</sub>	1.0	0.05
		SO <sub>2</sub>	1.0	0.05
99	Miscellaneous Laboratory Sources	VOC	10.0	5.0

<sup>(1)</sup> Emission point identification - either specific equipment designation or emission point number from plot plan.

<sup>(2)</sup> Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1 - total oxides of nitrogen

SO<sub>2</sub> - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including  $PM_{10}$  and  $PM_{2.5}$ , as

represented

PM<sub>10</sub> - total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub>, as

represented

PM<sub>2.5</sub> - particulate matter equal to or less than 2.5 microns in diameter

CO - carbon monoxide  $SiO_2$  - silicon dioxide Pb - lead

(4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

Date:	August 5, 2013	
-------	----------------	--