Permit Number 107518 and PSDTX1383

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

| Emission Point No. | Source Name (2) | Air Contaminant Name (3) | Emission | Rates |
|--|---------------------------------|--------------------------|----------|---------|
| (1) | | | lbs/hour | TPY (4) |
| All Furnace EPNs (OL3- FUR1 through | Pyrolysis Furnace Annual CAP | NOX | | 167.28 |
| OL3-FUR14) | Alliluai CAF | СО | | 472.16 |
| | | VOC | | 165.84 |
| | | PM10 | | 33.73 |
| | | PM2.5 | | 33.73 |
| | | NH3 | | 60.18 |
| | | SO2 | | 13.79 |
| | Pyrolysis Furnace 1 | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| OL3-FUR1 | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| OL3-FUR2 | Pyrolysis Furnace 2 | СО | 7.70 | (6) |
| OLO-I OI(Z | i yroiysis i uiliace 2 | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |

| | | NH3 | 1.47 | (6) |
|-----------|------------------------|--------------------------|-------|-----|
| | | | | |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| OL3-FUR3 | Pyrolysis Furnace 3 | VOC | 2.70 | (6) |
| OL3-1 OK3 | r yrolysis i difface 3 | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| OL3-FUR4 | Pyrolysis Furnace 4 | VOC | 2.70 | (6) |
| OL3-FOR4 | Fylolysis Fulliace 4 | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| OL3-FUR5 | Pyrolysis Furnace 5 | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |

| | | SO2 | 0.22 | (6) |
|----------|------------------------|--------------------------|-------|-----|
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| OL3-FUR6 | Pyrolysis Furnace 6 | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | Pyrolysis Furnace 7 | NOx (startup & shutdown) | 15.00 | (6) |
| | | CO | 7.70 | (6) |
| OL3-FUR7 | | VOC | 2.70 | (6) |
| OLS-FOR7 | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| OL3-FUR8 | Pyrolysis Furnace 8 | NOx (startup & shutdown) | 15.00 | (6) |
| OLS I ON | 1 yrorysis i urriace o | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |

| | | NOx | 5.50 | (6) |
|------------|----------------------|--------------------------|-------|-----|
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| OL3-FUR9 | Pyrolysis Furnace 9 | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| 01.2 EUD10 | Pyrolysis Furnace 10 | VOC | 2.70 | (6) |
| OL3-FUR10 | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| OL3-FUR11 | Pyrolysis Furnace 11 | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | | | |

| | | NOx (startup & shutdown) | 15.00 | (6) |
|------------|--------------------------|--------------------------|-------|--------|
| | | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOx | 5.50 | (6) |
| | | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| OLO ELIDAD | Durch rais Furnis and Co | VOC | 2.70 | (6) |
| OL3-FUR13 | Pyrolysis Furnace 13 | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| OL2 FUD14 | 5 1 . 5 . 11 | NOx | 5.50 | (6) |
| OL3-FUR14 | Pyrolysis Furnace 14 | NOx (startup & shutdown) | 15.00 | (6) |
| | | СО | 7.70 | (6) |
| | | VOC | 2.70 | (6) |
| | | PM10 | 0.55 | (6) |
| | | PM2.5 | 0.55 | (6) |
| | | NH3 | 1.47 | (6) |
| | | SO2 | 0.22 | (6) |
| | | NOX | | 75.51 |
| | | СО | | 279.39 |

| | | VOC | | |
|------------|----------------|----------------------------|-------|-------|
| | | | | 92.83 |
| | | PM10 | | 18.88 |
| | | PM2.5 | | 18.88 |
| | | NH3 | | 36.76 |
| | | SO2 | | 7.72 |
| | | NOX | 6.47 | |
| | | NOX (startup and shutdown) | 43.10 | |
| | | СО | 15.95 | |
| OL 2 DOU 1 | Ctoom Boiler 1 | VOC | 3.04 | |
| OL3-BOIL1 | Steam Boiler 1 | PM10 | 1.08 | |
| | | PM2.5 | 1.08 | |
| | | NH3 | 3.15 | |
| | | SO2 | 0.44 | |
| OL3-BOIL2 | Steam Boiler 2 | NOX | 6.47 | |
| OL3-BOIL2 | Steam boller 2 | NOX (startup and shutdown) | 43.10 | |
| | | СО | 15.95 | |
| | | VOC | 3.04 | |
| | | PM10 | 1.08 | |
| | | PM2.5 | 1.08 | |
| | | NH3 | 3.15 | |
| | | SO2 | 0.44 | |
| | | NOX | 6.47 | |
| | | NOX (startup and shutdown) | 43.10 | |
| | | СО | 15.95 | |
| | | VOC | 3.04 | |

OL3-BOIL3

Steam Boiler 3

| | <u></u> | | |
|-------------------------------|------------------------------------|---|-------|
| | PM10 | 1.08 | |
| | PM2.5 | 1.08 | |
| | NH3 | 3.15 | |
| | SO2 | 0.44 | |
| | NOX | 6.47 | |
| | NOX (startup and shutdown) | 43.10 | |
| | СО | 15.95 | |
| Ctoom Doilor 4 | VOC | 3.04 | |
| Steam Boller 4 | PM10 | 1.08 | |
| | PM2.5 | 1.08 | |
| | NH3 | 3.15 | |
| | SO2 | 0.44 | |
| Decoking Drums 1 and 2 (7) | VOC | <0.01 | <0.01 |
| | СО | 196.07 | 68.66 |
| | PM | 0.52 | 0.18 |
| | PM10 | 0.29 | 0.10 |
| | PM2.5 | 0.25 | 0.09 |
| | VOC | 5.75 | 25.21 |
| Olofine 2 Cooling | HOCI | <0.01 | <0.01 |
| Tower | PM10 | 2.66 | 11.66 |
| | PM2.5 | <0.01 | 0.04 |
| | VOC | 3.75 | 16.44 |
| | HOCI | <0.01 | <0.01 |
| PDH Unit Cooling | PM10 | 1.74 | 7.61 |
| i Owei | PM2.5 | <0.01 | 0.03 |
| | and 2 (7) Olefins 3 Cooling Tower | PM2.5 NH3 SO2 NOX NOX (startup and shutdown) CO | PM2.5 |

| | | \/OO | 00.10 | 00.00 |
|------------------------|---|-------|-------|-------|
| | | VOC | 20.16 | 88.32 |
| OL3-FUG | Olefins 3 Fugitives | CI2 | <0.01 | 0.02 |
| | | NH3 | 0.24 | 1.04 |
| | | VOC | 29.73 | 41.44 |
| OL3-FLRA, OL3- FLRB | Olefins 3 Elevated | NOX | 6.41 | 9.11 |
| FLRD | Flare (1st and 2nd - Stage tips) | CO | 32.79 | 45.97 |
| | | SO2 | <0.01 | <0.01 |
| | | VOC | 0.82 | 2.57 |
| OL3-LPFLR1 | Olefins 3 Low | NOX | 2.48 | 6.98 |
| OL3-LPFLRI | Pressure Flare 1 | CO | 9.82 | 27.50 |
| | | SO2 | <0.01 | <0.01 |
| | | VOC | 0.82 | 2.57 |
| OL3-LPFLR2 | Olefins 3 Low | NOX | 2.48 | 6.98 |
| OL3-LFFLRZ | Pressure Flare 2 | СО | 9.82 | 27.50 |
| | | SO2 | <0.01 | <0.01 |
| OL3-OXIDCC | Oxidation Unit Carbon Canister Vent | VOC | <0.01 | <0.01 |
| OL3-NAOHCC | Caustic Area Carbon Canister Vent | VOC | <0.01 | <0.01 |
| OL3-MAPD | MAPD Regeneration Vent | VOC | 0.21 | <0.01 |
| OL3-MAP D | Vent | СО | 11.55 | 0.05 |
| | | NOX | 4.45 | 0.22 |
| | | CO | 3.90 | 0.20 |
| OL3-GEN | OL3 Unit Diesel | VOC | 4.45 | 0.22 |
| OL3-GEN | Emergency | PM10 | 0.24 | 0.01 |
| | Generator Engine | PM2.5 | 0.24 | 0.01 |

| | | SO2 | 0.01 | <0.01 |
|------------------------------------|--------------------|---------------------------------|-------|--------|
| | | NOX | | 41.52 |
| | | со | | 117.96 |
| All PDH Reactor | Annual PDH Reactor | VOC | | 320.20 |
| EPNs (PDH-REAC1 through PDH-REAC4) | CAP | PM10 | | 8.36 |
| , | | PM2.5 | | 8.36 |
| | | NH3 | | 11.84 |
| | | SO2 | | 0.04 |
| PDH-REAC1 | PDH Reactor 1 | NOX | 4.78 | |
| | | NOX (startup and shutdown) | 15.00 | |
| | | СО | 6.78 | |
| | | VOC | 18.28 | |
| | | PM10 | 0.48 | |
| | | PM2.5 | 0.48 | |
| | | NH3 | 1.01 | |
| | | SO2 | 0.01 | |
| | | SO2 (N.G. startup and shutdown) | 0.16 | |
| | | NOX | 4.78 | |
| | | NOX (startup and shutdown) | 15.00 | |
| | | СО | 6.78 | |
| | | VOC | 18.28 | |
| PDH-REAC2 | PDH Reactor 2 | PM10 | 0.48 | |
| | | PM2.5 | 0.48 | |
| | | NH3 | 1.01 | |
| | | SO2 | 0.01 | |

| | | SO2 (N.G. startup and shutdown) | 0.16 | |
|-----------------------------|--------------------|---------------------------------|-------|--------------|
| | | NOX | 4.78 | |
| | | NOX (startup and shutdown) | 15.00 | |
| 5511 554 66 | 55115 | СО | 6.78 | |
| PDH-REAC3 | PDH Reactor 3 | VOC | 18.28 | |
| | | PM10 | 0.48 | |
| | | PM2.5 | 0.48 | |
| | | NH3 | 1.01 | |
| | | SO2 | 0.01 | |
| | | SO2 (N.G. startup and shutdown) | 0.16 | |
| | | NOX | 4.78 | |
| | | NOX (startup and shutdown) | 15.00 | |
| | | CO | 6.78 | |
| | | VOC | 18.28 | |
| PDH-REAC4 | PDH Reactor 4 | PM10 | 0.48 | |
| | | PM2.5 | 0.48 | |
| | | NH3 | 1.01 | |
| | | SO2 | 0.01 | |
| | | SO2 (N.G. startup and shutdown) | 0.16 | |
| | | VOC | 16.09 | 70.50 |
| PDH-FUG | PDH Unit Fugitives | Cl2 | <0.01 | 0.02 |
| | (5) | NH3 | 0.07 | 0.29 |
| | | NOX | 4.45 | 0.22 |
| | | СО | 3.90 | 0.20 |
| | | VOC | 4.45 | 0.22 |
| Project Number: 186768 & 20 | 3348 | | | |

| | | PM10 | 0.24 | 0.01 |
|-----------|---|-------|------|-------|
| | | PM2.5 | 0.24 | 0.01 |
| | | SO2 | 0.01 | <0.01 |
| OL3-ACID | Sulfuric Acid Tank | H2SO4 | 0.84 | 0.28 |
| OL3-PLO | PGC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| OL3-PRLO | PRC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| OL3-BRLO | BRC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| OL3-Chem1 | Amine Storage Tank | VOC | 0.21 | <0.01 |
| OL3-Chem2 | Amine Storage Tank | VOC | 0.21 | <0.01 |
| OL3-Chem3 | Inhibitor Storage Tank | VOC | 2.07 | 0.08 |
| OL3-Chem4 | Inhibitor Storage Tank | VOC | 2.07 | 0.08 |
| OL3-Chem5 | Product Inhibitor Storage Tank | VOC | 1.17 | 0.03 |
| OL3-DIES | OL3 Emergency Generator Diesel Storage Tank | VOC | 0.18 | <0.01 |
| PDH-PLO | PGC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| PDH-PRLO | PRC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| PDH-ALO | ARC Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| PDH-ELO | Expander Lube Oil Reservoir | VOC | 0.02 | <0.01 |
| PDH-Chem1 | Amine Storage Tank | VOC | 0.21 | <0.01 |
| PDH-Chem2 | Inhibitor Storage Tank | VOC | 2.07 | 0.06 |
| PDH-Chem3 | Inhibitor Storage Tank | VOC | 2.07 | 0.06 |
| PDH-Chem4 | Product Inhibitor Storage Tank | VOC | 0.88 | 0.03 |

| PDH-DIES | Diesel Storage Tank | VOC | 0.16 | <0.01 |
|--------------------------|---------------------|------------------|---------|-------|
| | MSS - Vessel | VOC-MSS | 37.21 | 1.04 |
| PDH-MSSVO | Opening | Inorganics – MSS | 1.63 | <0.01 |
| OL3-MSSVO | MSS - Vessel | VOC-MSS | 46.66 | 4.58 |
| 020 11100 10 | Opening | Inorganics – MSS | 1.06 | <0.01 |
| OL3-FLRA, OL3- | MSS – Degassing to | VOC – MSS | 1833.01 | 83.04 |
| FLRB, OL3-TEMP, PDH-TEMP | Flare | NOx – MSS | 372.74 | 17.05 |
| I DIT I LIVII | | CO – MSS | 1920.15 | 87.84 |

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.

(3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1 NO $_{x}$ - total oxides of nitrogen

SO₂ - sulfur dioxide

PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented

PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented

PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter

CO - carbon monoxide

- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.
- (5) Emission rate is an estimate and is enforceable through compliance with the applicable special condition(s) and permit application representations.
- (6) Annual emissions included in annual compliance CAP for pyrolysis furnaces.
- (7) Maximum emissions from decoking all furnaces to either decoke drum.

Date: <u>August 8, 2014</u>