

## EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 6030

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

### AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY**
2-1	Boiler Generator No. 2	SO <sub>2</sub>	6,108	26,754
		NO <sub>x</sub> 3,561	15,598	
		CO 608	2,662	
		VOC 90.6	397	
		PM 509	2,229	

- (1) Emission point identification - either specific equipment designation or emission point number from a plot plan.
- (2) Specific point source names. For fugitive sources, use an area name or fugitive source name.
- (3) SO<sub>2</sub> - sulfur dioxide  
 NO<sub>x</sub> - total oxides of nitrogen  
 CO - carbon monoxide  
 VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1  
 PM - particulate matter, suspended in the atmosphere, including PM<sub>10</sub>.  
 PM<sub>10</sub> - particulate matter equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no particulate matter greater than 10 microns is emitted

\* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

\_\_\_\_\_Hrs/day \_\_\_\_\_Days/week \_\_\_\_\_Weeks/year or 8,760 Hrs/year

\*\* Compliance with annual emission limits is based on a rolling 12-month period.

Permit No. 18447  
Page 2

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			<u>lb/hr</u>	<u>TPY**</u>

Dated\_\_\_\_\_