

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

9015/PSD-TX-325M3

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates lb/hr	TPY	*
1	Steam Generator	NOx	3,400.0	14,892.0	
	6,800 MMBtu/hr (4)	SO2	3,410.0	14,936.0	
		PM	205.4	900.0	
		CO	444.1	1,945.	0

FUGITIVE PM SOURCES (5)

FS1	Rotary Car Dumper	PM	25.4	18.6	
		Opacity		10 percent	
FS2	Transfer-Coal to Storage	PM	6.0	4.4	
		Opacity		10 percent	
FS3	Transfer-Coal Storage to Boiler Bins	PM	2.0	3.7	
		Opacity		10 percent	
FS4	Active Coal Pile	PM	4.8	20.9	
		Opacity		20 percent	
FS5	Inactive Coal Pile	PM	4.8	21.2	
		Opacity		10 percent	
FS6	Limestone Car Dumper	PM	2.7	0.4	
		No Visible Emissions			
FS7	Transfer-Limestone to Storage	PM	0.4	<0.1	
		No Visible Emissions			
FS8	Transfer-Limestone Storage to Mill Bins	PM	0.2	<0.1	
		No Visible Emissions			
FS9	Inactive Limestone Storage	PM	<0.1	<0.1	
		No Visible Emissions			
FS10A	Fly Ash Handling (ESP)	PM	18.0	3.3	
		Opacity		10 percent	

FS10B	Fly Ash Handling (Economizer/Air Heaters)	PM Opacity	18.0 10 percent	0.6
TOTAL FUGITIVE SOURCE EMISSIONS		PM		73.3

9015/PSD-TX-325M3
Page 2 of 2

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) NOx - total oxides of nitrogen
CO - carbon monoxide
PM - particulate matter
SO2 - sulfur dioxide
- (4) The steam generator is limited to 10 percent opacity with one 6-minute average opacity per hour not to exceed 20 percent in accordance with the exception of 40 CFR 60.42a(b) and in accordance with the limitations and conditions specified in (31 TAC Chapter 111), Rule 111.21.
- (5) Fugitive emissions are an estimate only and should not be considered as a maximum allowable emission limit. Fugitive emission rates are based on the operating schedule shown in the construction permit application.

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day 24 Days/week 7 Weeks/year 52 or Hrs/year 8,760

Revised_____