

8. The Scrubber/Absorber System is subject to the following requirements:

- A. The sulfur dioxide (SO₂) and sulfur trioxide (SO₃) removal efficiency shall be at least 90 percent on an hourly average.
- B. The VOC removal efficiency shall be at least 90 percent on an hourly average.
- C. After the first satisfactory stack test, the minimum liquid flow to the absorber shall be at least equal to that maintained during any satisfactory 3 hours of sampling in the last satisfactory stack test. The circulation rate shall be monitored and recorded at least once an hour.
- D. After the first satisfactory stack test, the maximum absorber exhaust temperature shall be no greater than the average temperature maintained during any satisfactory 3 hours of sampling in the last satisfactory stack test. The exhaust temperature may be allowed to increase up to 10°F above that value if satisfactory removal efficiency and emission rates are demonstrated at the higher temperature by using a computer simulation to ratio stack test results to the higher temperature.
- E. The holder of this permit shall install and maintain a continuous temperature monitor for the scrubber exhaust. The temperature shall be recorded at least every six minutes as six minute averages. Each monitoring device shall be calibrated at a frequency in accordance with the manufacturer's specifications, or at least annually, whichever is more frequent, and shall be accurate to within 2 percent of the reading or 2.5°Celsius.
- F. Quality assured (or valid) temperature data must be generated when the Scrubber/Absorber System is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in hours) that the Scrubber/Absorber System operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded.
[Deleted "except during the performance of the calibration requirements of Special Condition Number 8E". This calibration must be done within the 5 percent of the time which the condition specifies.]
- G. After the first satisfactory stack test, the scrubbing solution pH shall be at or

above the average pH maintained during any satisfactory 3 hours of sampling in the last last satisfactory stack test. The pH shall be continuously analyzed and recorded at least once a minute. Each monitoring device shall be cleaned with an automatic cleaning system, or cleaned weekly using hydraulic, chemical, or mechanical cleaning. Each monitoring device shall be calibrated at a frequency in accordance with the manufacturer's specifications, or at least weekly, whichever is more frequent, and shall be accurate to within + 0.5 pH unit.

- H. Quality assured (or valid) pH data must be generated when the Scrubber/Absorber System is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in hours) that the Scrubber/Absorber System operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded. **(04/06)**
[Deleted "except during the calibration requirements of Special Condition Number 8G". This calibration must be done within the 5 percent of the time which the condition specifies.]

SPECIAL CONDITIONS

Permit Number 56697

7. The Abatement System is subject to the following requirements:

- A. The VOC removal efficiency shall be at least 95 percent on an hourly average.
- B. After the first satisfactory stack test, the minimum liquid flow to the scrubber shall be at least equal to that maintained during any satisfactory 3 hours of sampling in the last satisfactory stack test. The circulation rate shall be monitored and recorded at least once an hour.

~~C. After the first satisfactory stack test, the absorber liquid specific gravity shall be at least equal to the average specific gravity maintained during any satisfactory 3 hours of sampling in the last stack test.~~

[Deleted, because specific gravity will not be monitored.]

- C. After the first satisfactory stack test, the maximum scrubber exhaust temperature shall be no greater than the average temperature maintained during any satisfactory 3 hours of sampling in the last satisfactory stack test. The exhaust temperature may be allowed to increase up to 10°F above that value if satisfactory removal efficiency and emission rates are demonstrated at the higher temperature by using a computer simulation to ratio stack test results to the higher temperature. **[Renumbered to C.]**

- D. The holder of this permit shall install and maintain a continuous temperature monitor for the scrubber exhaust. The temperature shall be recorded at least every six minutes as six-minute averages. Each monitoring device shall be calibrated at a frequency in accordance with the manufacturer's specifications, or at least annually, whichever is more frequent, and shall be accurate to within 2 percent of the reading or 2.5 degrees Celsius. **[Renumbered to D.]**

- E. Quality-assured (or valid) temperature data must be generated when the scrubber/absorber system is operating. Loss of valid data due to periods of monitor break down, out-of-control operation (producing inaccurate data), repair, maintenance, or calibration may be exempted provided it does not exceed 5 percent of the time (in hours) that the scrubber/absorber system operated over the previous rolling 12-month period. The measurements missed shall be estimated using engineering judgement and the methods used recorded. **(04/06)**

[Deleted "except during the performance of the calibration requirements of Special Condition No. 7E". This calibration must be done within the 5

percent of the time which the condition specifies.] [Renumbered to E.]