

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Numbers 44277, PSD-TX-972, and NA-031

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY**
E-1	Engine/Genset No. 1	CO	15.50	
		NO _x	3.10	
	SO ₂	VOC	0.83	
		PM ₁₀	0.49	
			1.27	
		HCl	0.14	
E-2	Engine/Genset No. 2	CO	15.50	
		NO _x	3.10	
	SO ₂	VOC	0.83	
		PM ₁₀	0.49	
			1.27	
		HCl	0.14	
E-3	Engine/Genset No. 3	CO	15.50	
		NO _x	3.10	
	SO ₂	VOC	0.83	
		PM ₁₀	0.49	
			1.27	
		HCl	0.14	
E-4	Engine/Genset No. 4	CO	15.50	
		NO _x	3.10	
	SO ₂	VOC	0.83	
		PM ₁₀	0.49	
			1.27	
		HCl	0.14	

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates *	
			lb/hr	TPY**
E-5	Engine/Genset No. 5	CO	15.50	
		NO _x	3.10	
		VOC	0.83	
	SO ₂	PM ₁₀	0.49	
			1.27	
		HCl	0.14	
E-6	Engine/Genset No. 6	CO	15.50	
		NO _x	3.10	
		VOC	0.83	
	SO ₂	PM ₁₀	0.49	
			1.27	
		HCl	0.14	
E-1, E-2, E-3, E-4, E-5, and E-6	Engine/Gensets Nos. 1-6	CO		407.34
		NO _x		81.47
		VOC	21.81	
	SO ₂	PM ₁₀	12.88	
			33.38	
		HCl	3.68	

- (1) Emission point identification - either specific equipment designation or emission point number from a plot plan.
- (2) Specific point source names. For fugitive sources, use an area name or fugitive source name.
- (3) CO - carbon monoxide
NO_x - total oxides of nitrogen
VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
PM₁₀ - particulate matter (PM) equal to or less than 10 microns in diameter. Where PM is not listed, it shall be assumed that no PM greater than 10 microns is emitted.
SO₂ - sulfur dioxide
HCl - hydrogen chloride

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- * Emission rates are based on and the facilities are limited by the following maximum operating schedule:

24 Hrs/day 7 Days/week 52 Weeks/year

- ** Compliance with annual emission limits is based on a rolling 12-month period.

Dated January 29, 2004