Emission Sources - Maximum Allowable Emission Rates

Permit Numbers 119365 and PSDTX1410

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

Air Contaminants Data

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
CTDB3-A	GE Model 7HA.02 Combustion Turbine (CT) and 770 MMBtu/hr Duct Burner	NO _x (Normal Operation) (5)	28.2	184
		NO _x (MSS Operation) (6)	512	
		CO (Normal Operation) (5)	34	875
		CO (MSS Operation) (6)	7,637	
		VOC (Normal Operation) (5)	19.7	179
		VOC (MSS Operation) (6)	1,324	
		SO ₂	22	23.5
		PM (7)	43	110
		PM ₁₀ (7)	43	110
		PM _{2.5} (7)	43	110
		H ₂ SO ₄	17.3	18.4
		(NH ₄) ₂ SO ₄	23.3	25
		NH ₃	52.2	223
CTDB3-B	GE Model 7HA.02 CT and 770 MMBtu/hr Duct Burner	NO _x (Normal Operation) (5)	28.2	184
		NO _x (MSS Operation) (6)	512	
		CO (Normal Operation) (5)	34	875
		CO (MSS Operation) (6)	7,637	
		VOC (Normal Operation) (5)	19.7	179
		VOC (MSS Operation) (6)	1,324	
		SO ₂	22	23.5
		PM (7)	43	110
		PM ₁₀ (7)	43	110
		PM _{2.5} (7)	43	110
		H ₂ SO ₄	17.3	18.4
		(NH ₄) ₂ SO ₄	23.3	25
		NH ₃	52.2	223

Project Numbers: 209419 and 209431

Emission Sources - Maximum Allowable Emission Rates

CT3-ALOV-VNT	CT 1 Lube Oil Vent	VOC	<0.01	0.013
		PM	<0.01	0.013
		PM ₁₀	<0.01	0.013
		PM _{2.5}	<0.01	0.013
CT3-BLOV-VNT	CT 2 Lube Oil Vent	VOC	<0.01	0.013
		PM	<0.01	0.013
		PM ₁₀	<0.01	0.013
		PM _{2.5}	<0.01	0.013
ST3LOV-VNT	Steam Turbine Lube Oil Vent	VOC	<0.01	0.013
		PM	<0.01	0.013
		PM ₁₀	<0.01	0.013
		PM _{2.5}	<0.01	0.013
FWP2	Fire Water Pump	NO _x	1.5	0.07
	250 Horsepower Diesel	СО	0.22	0.01
	Engine	VOC	0.06	<0.01
		PM	0.03	<0.01
		PM ₁₀	0.03	<0.01
		PM _{2.5}	0.03	<0.01
		SO ₂	<0.01	<0.01
EG3	2.0 MW Emergency Generator Diesel Engine	NO _x	35.3	1.8
		СО	1.9	0.10
		VOC	0.71	0.04
		PM	0.16	<0.01
		PM ₁₀	0.16	<0.01
		PM _{2.5}	0.16	<0.01
		SO ₂	0.03	<0.01
AUX3	Auxiliary Boiler 40 MMBtu/hr (8)	NO _x	1.5	6.5
		CO	1.5	6.5
		VOC	0.22	0.96
		PM	0.20	0.88
		PM ₁₀	0.20	0.88
		PM _{2.5}	0.20	0.88
		SO ₂	0.23	0.25
NG-FUG	Natural Gas Fugitives (9)	VOC	0.05	0.22
NH3-FUG	Ammonia Fugitives (9)	NH ₃	0.12	0.51
DSL-TK1	Diesel Fuel Storage Tank for Emergency Generator	voc	0.11	<0.01
DSL-TK2 Project Numbers: 2094:	Diesel Fuel Storage Tank for	VOC	0.02	<0.01

Emission Sources - Maximum Allowable Emission Rates

	Fire Pump Engine			
MSS FUG Inherently Low-Emitting Maintenance Activities (9)		NO _x	<0.01	<0.01
		СО	<0.01	<0.01
	VOC	0.08	<0.01	
	PM	0.09	0.02	
	PM ₁₀	0.09	0.02	
		PM _{2.5}	0.09	0.02
		NH ₃	<0.01	<0.01

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) NO_x total oxides of nitrogen
 - CO carbon monoxide
 - VOC volatile organic compounds as defined in Title 30 Texas Administrative Code (TAC) § 101.1
 - SO₂ sulfur dioxide
 - PM particulate matter emissions, as defined in Title 30 TAC § 101.1, including PM_{10} and $PM_{2.5}$ PM₁₀ particulate matter emissions equal to or less than 10 microns in diameter, including $PM_{2.5}$
 - PM_{2.5} direct particulate matter emissions equal to or less than 2.5 microns in diameter
 - NH_3 ammonia H_2SO_4 sulfuric acid
 - (NH₄)₂SO₄ ammonium sulfate
- (4) Compliance with annual emission limits (tons per year) is based on a 12-month rolling period.
- (5) Normal operation is defined in Special Condition No. 4.
- (6) MSS operation is defined in Special Condition No. 21. For pollutants whose emissions during planned MSS activities are measured using a CEMS, the MSS lbs/hr limits apply during each clock hour that includes one or more minutes of MSS activities. During all other clock hours, the normal lbs/hr limits apply. Annual emission limits include both normal and MSS operation emissions.
- (7) $PM/PM_{10}/PM_{2.5}$ includes H_2SO_4 and $(NH_4)_2SO_4$.
- (8) Auxiliary boiler hourly and annual limits include both normal and MSS operation emissions.
- (9) Fugitive emission rates are estimates and are enforceable through compliance with the applicable special conditions and permit application representations.

Draft Date:	April 1, 2015
Dian Date.	/ \pin ±, _0±0

Project Numbers: 209419 & 209431