

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 2565

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission * Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lb/hr	TPY
EB-110	126.6 MM Btu/Hr Boiler	NO _x	25.0	109.0
		CO	4.0	17.5
		VOC	0.19	0.82
		SO ₂	0.08	0.35
		PM	0.4	1.75
EB-111	126.6 MM Btu/Hr Boiler	NO _x	25.0	109.0
		CO	4.0	17.5
		VOC	0.19	0.82
		SO ₂	0.08	0.35
		PM	0.4	1.75
EB-111	72.18 MMBtu/hr Temporary Packaged Boiler (4)	NO _x	5.42	9.10
		CO	5.42	9.10
		VOC	0.4	0.67
		SO ₂	0.05	0.09
		PM	0.55	0.93
EB-113	126.6 MM Btu/Hr Boiler	NO _x	25.0	109.0
		CO	4.0	17.5
		VOC	0.19	0.82
		SO ₂	0.08	0.35
		PM	0.4	1.75
EB-114	126.6 MM Btu/Hr Boiler	NO _x	25.0	109.0
		CO	4.0	17.5

VOC	0.19	0.82
SO ₂	0.08	0.35
PM	0.4	1.75

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name.
- (3) VOC -volatile organic compounds as defined in General Rule 101.1
NO_x -total oxides of nitrogen
SO₂ -sulfur dioxide
PM -particulate matter
CO -carbon monoxide
- (4) The temporary packaged boiler will replace the Boiler B-111 for a maximum of five months from the issue date of this permit.

* Annual emission rates are based on, and the facilities are limited by, the following maximum operating schedule:

Hrs/day 24 Days/week 7 Weeks/year 52 or Hrs/year 8,760

Dated _____