

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 1867A

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Rates *	Source	Air Contaminant	Emission	
			lb/hr	TPY
Point No. (1)	Name (2)	Name (3)		
EPN 119/120	Boiler Stacks	SO ₂	2880.0	12,615.0
		NO _x	257.6	1128.3
		CO	850.0	3723.0
		VOC	8.8	38.5
		PM	57.0	249.7

Note that the total emissions from EPNs 119 and 120 combined may not exceed the listed rates.

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name.
- (3) VOC - volatile organic compounds as defined in General Rule 101.1
 - NO_x - total oxides of nitrogen
 - SO₂ - sulfur dioxide
 - PM - particulate matter including TSP
 - CO - carbon monoxide
 - TSP - total suspended particulate matter

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

_____Hrs/day _____Days/week _____Weeks/year or 8,760
Hrs/year

Permit No. 18447
Page 2

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	<u>Emission Rates *</u>	
			<u>lb/hr</u>	<u>TPY</u>

Dated _____