EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit No. 21429

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission	Source	Air Contaminant	<u>Emission Rates</u>					
<u>*</u> Point No. (1)	Name (2)	Name (3)	1b/hr	TPY				
CASE I: TURBINE	WITH DUCT BURNER FIRED							
EPN-1	GE Frame 6 Turbine and 128 MMBtu/hr Duct Burner	NO_x CO SO_2 PM VOC SO_3 NH_3	20.8 24.52 8.0 6.82 7.84 0.24 8.40	75.0 103.0 32.0 26.9 30.0 1.1 30.5				
CASE II: TURBINE ONLY - DUCT BURNER UNFIRED								
EPN-1	GE Frame 6 Turbine and 128 MMBtu/hr Duct Burner	NO_{\times} CO SO_{2} PM VOC SO_{3} NH_{3}	16.2 16.0 6.0 5.5 7.0 0.2 6.6	56.0 66.0 26.3 26.0 17.5 0.9 22.7				

- (1) Emission point identification either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name.
- (3) PM particulate matter
 - VOC volatile organic compounds as defined in General Rule 101.1
 - NO_x total oxides of nitrogen
 - SO₂ sulfur dioxide
 - CO carbon monoxide
 - SO₃ sulfur trioxide
 - NH₃ ammonia

^{*} Emission rates are based on and the facilities are limited by the following maximum operating schedule:

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

AIR CONTAMINANTS DATA

Emission Source		urce	Air Contaminant		Emission Rates *	
Point No. (1)	Name (2)		Na	ıme (3)	lb/hr	TPY
24	Hrs/day	7_Days/week	52	_Weeks/year or	8,760	Hrs/year
	Dated					