

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

T-19071

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source		Air Contaminant		<u>Emission Rates *</u>	
	Name (2)	Name (3)	lb/hr	TPY		
9	HOSPITAL WASTE INCINERATOR			NOX	1.08	1.15
				SO2	0.07	0.08
				PM	0.16	0.17
				HCl	0.19	0.20

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources use area name or fugitive source name.
- (3) PM - particulate matter
 NOx - total oxides of nitrogen
 SO2 - sulfur dioxide
 HCl - hydrogen chloride

* Emission rates are based on and the facilities are limited by the following maximum operating schedule:

Hrs/day 8 Days/week 5 Weeks/year 52 or Hrs/year 2080

Revised _____