

EMISSION SOURCES - MAXIMUM ALLOWABLE EMISSION RATES

Permit Number 42976

This table lists the maximum allowable emission rates and all sources of air contaminants on the applicant's property covered by this permit. The emission rates shown are those derived from information submitted as part of the application for permit and are the maximum rates allowed for these facilities, sources, and related activities. Any proposed increase in emission rates may require an application for a modification of the facilities covered by this permit.

AIR CONTAMINANTS DATA

Emission Point No. (1)	Source Name (2)	Air Contaminant Name (3)	Emission Rates	
			lbs/hour	TPY (4)
1 and 2	Boiler 1 and Boiler 2 Natural Gas Fired	NO _x	8.82	17.64
		CO	5.44	10.88
		VOC	0.59	1.18
		PM/PM ₁₀ /PM _{2.5}	1.10	2.19
		SO ₂	0.09	0.18
2	Boiler 2 Fuel Oil Fired	NO _x	9.81	0.22
		CO	2.73	0.06
		VOC	0.63	0.014
		PM/PM ₁₀ /PM _{2.5}	1.65	0.04
		SO ₂	0.11	0.0025

- (1) Emission point identification - either specific equipment designation or emission point number from plot plan.
- (2) Specific point source name. For fugitive sources, use area name or fugitive source name.
- (3) VOC - volatile organic compounds as defined in Title 30 Texas Administrative Code § 101.1
 NO_x - total oxides of nitrogen
 SO₂ - sulfur dioxide
 PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5}, as represented.
 PM_{2.5} - total particulate matter equal to or less than 2.5 microns in diameter.
 CO - carbon monoxide
 NH₃ - ammonia
- (4) Compliance with annual emission limits (tons per year) is based on a 12 month rolling period.

Date June 17, 2011
 :

